



STATE OF NORTH CAROLINA

The University of North Carolina at Chapel Hill

Invitation for Bid #: 3000012452

Chilled Water Infrastructure Expansion Bernard Chiller Plant

Date Issued: 08/08/2025

Submit Written Questions: 08/20/2025 at 1:00PM EST

Bid Opening Date: 09/12/2025

At 01:00 PM EST

Direct all inquiries concerning this IFB to:

Marcy Moore

MRO Category Manager

Email: Mmrowlan@unc.edu



STATE OF NORTH CAROLINA

Invitation for Bids

3000012452

For internal State agency processing, including tabulation of bids, provide your company's eVP (Electronic Vendor Portal) Number. Pursuant to G.S. 132-1.10(b) this identification number shall not be released to the public. **This page will be removed and shredded, or otherwise kept confidential**, before the procurement file is made available for public inspection.

**This page shall be filled out and returned with your bid.
Failure to do so shall be sufficient cause to reject your bid.**

Vendor Name

Vendor eVP #

Note: For a contract to be awarded to you, your company (you) must be a North Carolina registered vendor in good standing. You must enter the vendor number assigned through eVP (Electronic Vendor Portal). If you do not have a vendor number, register at <https://vendor.ncgov.com/vendor/login>

STATE OF NORTH CAROLINA
The University of North Carolina at Chapel Hill

Refer <u>ALL</u> Inquiries regarding this IFB to: Marcy Moore	Invitation for Bids # 3000012452
	Bids will be publicly opened: 09/12/2025 at 1:00PM EST
Using Agency: University of Chapel Hill	Commodity No. and Description: Prepurchased Equipment Cooling Towers
Requisition No.: 1001070670	

Zoom Link for Opening if you would like to join:

<https://us04web.zoom.us/j/79380989608?pwd=nWg7IH8QrYLQOjCxCcFarogLDbY3b0.1>

EXECUTION

In compliance with this Invitation for Bids (IFB), and subject to all the conditions herein, the undersigned Vendor offers and agrees to furnish and deliver any or all items upon which prices are bid, at the prices set opposite each item within the time specified herein.

By executing this bid, the undersigned Vendor understands that false certification is a Class I felony and certifies that:

- this bid is submitted competitively and without collusion (G.S. 143-54),
- that none of its officers, directors, or owners of an unincorporated business entity has been convicted of any violations of Chapter 78A of the General Statutes, the Securities Act of 1933, or the Securities Exchange Act of 1934 (G.S. 143-59.2), and
- it is not an ineligible Vendor as set forth in G.S. 143-59.1.

Furthermore, by executing this bid, the undersigned certifies to the best of Vendor’s knowledge and belief, that:

- it and its principals are not presently debarred, suspended, proposed for debarment, declared ineligible or voluntarily excluded from covered transactions by any Federal or State department or agency.

As required by G.S. 143-48.5, the undersigned Vendor certifies that it, and each of its sub-Contractors for any Contract awarded as a result of this IFB, complies with the requirements of Article 2 of Chapter 64 of the NC General Statutes, including the requirement for each employer with more than 25 employees in North Carolina to verify the work authorization of its employees through the federal E-Verify system.

As required by Executive Order 24 (2017), the undersigned vendor certifies will comply with all Federal and State requirements concerning fair employment and that it does not and will not discriminate, harass, or retaliate against any employee in connection with performance of any Contract arising from this solicitation.

G.S. 133-32 and Executive Order 24 (2009) prohibit the offer to, or acceptance by, any State Employee associated with the preparing plans, specifications, estimates for public Contract; or awarding or administering public Contracts; or inspecting or supervising delivery of the public Contract of any gift from anyone with a Contract with the State, or from any person seeking to do business with the State. By execution of this bid response to the IFB, the undersigned certifies, for Vendor’s entire organization and its employees or agents, that Vendor are not aware that any such gift has been offered, accepted, or promised by any employees or agents of Vendor’s organization.

By executing this bid, Vendor certifies that it has read and agreed to the **INSTRUCTION TO VENDORS** and the **NORTH CAROLINA GENERAL TERMS AND CONDITIONS incorporated herein**. These documents can be accessed from the ATTACHMENTS page within this document.

Failure to execute/sign bid prior to submittal may render bid invalid and it MAY BE REJECTED. Late bids cannot be accepted.

COMPLETE/FORMAL NAME OF VENDOR:		
STREET ADDRESS:	P.O. BOX:	ZIP:
CITY & STATE & ZIP:	TELEPHONE NUMBER:	TOLL FREE TEL. NO:
PRINCIPAL PLACE OF BUSINESS ADDRESS IF DIFFERENT FROM ABOVE (SEE INSTRUCTIONS TO VENDORS ITEM #21):		
PRINT NAME & TITLE OF PERSON SIGNING ON BEHALF OF VENDOR:	FAX NUMBER:	
VENDOR’S AUTHORIZED SIGNATURE:	DATE:	E-MAIL:

Bid Number: 65-3000012452

Vendor: _____

VALIDITY PERIOD

Offer shall be valid for at least sixty (60) days from date of bid opening, unless otherwise stated here: _____ days, or if extended by mutual agreement of the parties. Any withdrawal of this offer shall be made in writing, effective upon receipt by the agency issuing this IFB.

BID ACCEPTANCE

If your bid is accepted, all provisions of this IFB, along with the written results of any negotiations, shall constitute the written agreement between the parties ("Contract"). THE UNIVERSITY OF NORTH CAROLINA AT CHAPEL HILL GENERAL TERMS AND CONDITIONS are incorporated herein and shall apply. Depending upon the Goods or Services being offered, other terms and conditions may apply, as mutually agreed.

FOR STATE USE ONLY: Offer accepted and Contract awarded this ____ day of _____, 20____, as indicated on the attached certification, by _____
(Authorized Representative of University of Chapel Hill)

1.0 PURPOSE AND BACKGROUND 5

1.1 CONTRACT TERM..... 5

2.0 GENERAL INFORMATION 5

2.1 INVITATION FOR BID DOCUMENT 5

2.2 E-PROCUREMENT FEE 5

2.3 NOTICE TO VENDORS REGARDING IFB TERMS AND CONDITIONS..... 5

2.4 IFB SCHEDULE 6

2.5 SITE VISIT or PRE-BID CONFERENCE 6

2.6 BID QUESTIONS 6

2.7 BID SUBMITTAL 6

2.8 BID CONTENTS..... 7

2.9 ALTERNATE BIDS 7

2.10 DEFINITIONS, ACRONYMS, AND ABBREVIATIONS..... 7

3.0 METHOD OF AWARD AND BID EVALUATION PROCESS..... 8

3.1 METHOD OF AWARD..... 8

3.2 CONFIDENTIALITY AND PROHIBITED COMMUNICATIONS DURING EVALUATION..... 8

3.3 BID EVALUATION PROCESS..... 8

3.4 PERFORMANCE OUTSIDE THE UNITED STATES 9

3.5 INTERPRETATION OF TERMS AND PHRASES..... 9

4.0 REQUIREMENTS..... 10

4.1 PRICING 10

4.2 ESTIMATED QUANTITIES..... 10

4.3 PRODUCT IDENTIFICATION..... 10

4.4 TRANSPORTATION AND IDENTIFICATION 10

4.5 DELIVERY AND INSTALLATION 10

4.6 AUTHORIZED RESELLER..... 11

4.7 WARRANTY 11

4.8 MAINTENANCE OPTION..... 12

4.9 DESCRIPTIVE LITERATURE..... 12

4.10 HUB PARTICIPATION..... 12

4.11 REFERENCES 12

4.12 VENDOR’S REPRESENTATIONS 12

4.13 FINANCIAL STABILITY 12

4.14 AGENCY INSURANCE REQUIREMENTS MODIFICATION 13

4.15 NC COVID-19 VACCINATION AND TESTING REQUIREMENT 13

4.16 FEDERAL COVID-19 VACCINATION REQUIREMENT 13

4.17 LOBBYING ACTIVITY CERTIFICATION FOR FEDERAL GRANTS..... 13

5.0 PRODUCT SPECIFICATIONS 13

5.1 SPECIFICATIONS..... 13

5.2 CERTIFICATION AND SAFETY LABELS..... 14

5.3 DEVIATIONS..... 14

6.0 CONTRACT ADMINISTRATION..... 14

6.1 CONTRACT MANAGER AND CUSTOMER SERVICE..... 14

6.2 POST AWARD PROJECT REVIEW MEETINGS..... 14

6.3 CONTINUOUS IMPROVEMENT 15

6.4 PERIODIC STATUS REPORTS 15

6.5 ACCEPTANCE OF WORK 15

6.6 INVOICES 15

6.7 DISPUTE RESOLUTION..... 15

6.8 PRODUCT RECALL 16

6.9.1 PRICE ADJUSTMENTS 16

6.10 CONTRACT CHANGES 16

7.0 ATTACHMENTS 17

ATTACHMENT A: PRICING..... 17

ATTACHMENT B: INSTRUCTIONS TO VENDORS 17

ATTACHMENT C: NORTH CAROLINA GENERAL TERMS & CONDITIONS..... 17

ATTACHMENT D: HUB SUPPLEMENTAL VENDOR INFORMATION 17

ATTACHMENT E: CUSTOMER REFERENCE FORM 17

ATTACHMENT F: LOCATION OF WORKERS UTILIZED BY VENDOR 17

ATTACHMENT G: CERTIFICATION OF FINANCIAL CONDITION 17

ATTACHMENT H: VENDOR REQUEST FOR EO50 PRICE-MATCHING..... 17

1.0 PURPOSE AND BACKGROUND

OWNER PRE-PURCHASED EQUIPMENT

A. This equipment will be prepurchased by the Owner with the cooling tower and furnished to the successful Contractor after award for expediting delivery and installation as if the Contractor purchased the equipment directly.

B. Owner will make available manufacturer provided shop drawings of Owner prepurchased equipment for review by the Contractor. Contractor shall review shop drawings to ascertain that Contractor has included necessary labor and materials to install equipment and complete system it serves.

C. Contractor shall be responsible for arranging/coordinating delivery of Owner prepurchased equipment and all other related logistics and activities. This includes directing the delivery truck to the jobsite, coordinating the date and time of delivery, and receipt of the equipment at the jobsite. Manufacturer is responsible for equipment until it is unloaded at the jobsite by the Contractor.

D. Contractor shall install Owner prepurchased equipment and all appurtenances. This shall include, but not be limited to; unloading, rigging and setting equipment in place, making connections, starting, testing and installing equipment in accordance with manufacturer's recommendations, and maintaining equipment until such time as project is accepted by Owner. Perform all work and provide materials and connections for Owner furnished equipment in accordance with drawings and scope of work under all related specifications.

E. The following summarizes the general responsibilities of the equipment manufacturer:

1. Provide shop drawings and submittal data.
2. Manufacture and delivery of equipment including coordination of exact delivery date and supervision of rigging, unloading, and setting.
3. Lead equipment check-out, testing, and start-up process and submit report(s).
4. Provide touch up paint. Provide O&M documentation.
5. Provide Owner training and participate in commissioning process.

1.1 CONTRACT TERM

This section intentionally omitted

2.0 GENERAL INFORMATION

2.1 INVITATION FOR BID DOCUMENT

The IFB is comprised of the base IFB document, any attachments, and any addenda released before Contract award, which are incorporated herein by reference.

2.2 E-PROCUREMENT FEE

This section is intentionally omitted.

2.3 NOTICE TO VENDORS REGARDING IFB TERMS AND CONDITIONS

It shall be the Vendor's responsibility to read the Instructions to Vendors, the University of North Carolina at Chapel Hill General Terms and Conditions, all relevant exhibits and attachments, and any other components made a part of this IFB and comply with all requirements and specifications herein. Vendors also are responsible for obtaining and complying with all Addenda and other changes that may be issued in connection with this IFB.

If Vendors have questions or issues, or exceptions regarding any component within this IFB, those must be submitted as questions in accordance with the instructions in the BID QUESTIONS Section. If the University determines that any changes will be made as a result of the questions asked, then such decisions will be communicated in the form of an IFB addendum. The University may also elect to leave open the possibility for later negotiation of specific provisions of the Contract that have been addressed during the question-and-answer period, prior to contact award.

Other than through this process or negotiation under 01 NCAC 05B.0503, the State rejects and will not be required to evaluate or consider any additional or modified terms and conditions submitted with Vendor’s bid. This applies to any language appearing in or attached to the document as part of the Vendor’s bid that purport to vary any terms and conditions or Vendors’ instructions herein or to render the bid non-binding or subject to further negotiation. Vendor’s bid shall constitute a firm offer that shall be held open for the period required herein (“Validity Period” above).

The University may exercise its discretion to consider Vendor proposed modifications. By execution and delivery of this IFB Response, the Vendor agrees that any additional or modified terms and conditions, whether submitted purposely or inadvertently, shall have no force or effect, and will be disregarded unless expressly agreed upon through negotiations and incorporated by way of a Best and Final Offer (BAFO). Noncompliance with, or any attempt to alter or delete, this paragraph shall constitute sufficient grounds to reject Vendor’s bid as nonresponsive.

2.4 IFB SCHEDULE

The table below shows the *intended* schedule for this IFB. The State will make every effort to adhere to this schedule.

Event	Responsibility	Date and Time
Issue IFB	University	08/08/2025
Hold Pre-Bid Conference/Site Visit	University	N/A
Submit Written Questions	Vendor	08/20/2025 at 1:00PM EST
Provide Responses to Questions	University	ASAP
Submit Bids	Vendor	09/12/2025 at 1:00PM EST
Contract Award	University	ASAP
Contract Effective Date	University	ASAP

2.5 SITE VISIT or PRE-BID CONFERENCE

This section is intentionally omitted.

2.6 BID QUESTIONS

Upon review of the IFB documents, Vendors may have questions to clarify or interpret the IFB in order to submit the best bid possible. To accommodate the Bid Questions process, Vendors shall submit any such questions by the “Submit Written Questions” date and time provided in the IFB SCHEDULE Section above, unless modified by Addendum.

Written questions shall be e-mailed to *mmrowlan@unc.edu* by the date and time specified above. Vendors will enter “IFB - 3000012452: Questions” as the subject for the email. Question submittals will include a reference to the applicable IFB section and be submitted in a format shown below:

Reference	Vendor Question
IFB Section, Page Number	Vendor question ...?

Questions received prior to the submission deadline date, the University’s response, and any additional terms deemed necessary by the University will be posted in the form of an addendum to *the electronic Vendor Portal (eVP)*, <https://evp.nc.gov>, and shall become an Addendum to this IFB. No information, instruction or advice provided orally or informally by any University personnel, whether made in response to a question or otherwise in connection with this IFB, shall be considered authoritative or binding. Vendors shall rely *only* on written material contained in an Addendum to this IFB.

2.7 BID SUBMITTAL

IMPORTANT NOTE: This is an absolute requirement. Vendor shall bear the risk of late submission due to unintended or unanticipated delay. It is the Vendor’s sole responsibility to ensure its bid has been received as described in this IFB by the

specified time and date of opening. The date and time of receipt will be marked on each bid when received. Any bid or portion thereof received after the bid submission deadline will be rejected.

If applicable to this IFB and using eVP, all proposal responses shall be submitted electronically via the electronic Vendor Portal (eVP). Additional information can be found at the eVP updates for Vendors link: <https://eprocurement.nc.gov/news-events/evp-updates-vendors>.

Failure to submit a bid in strict accordance with these instructions shall constitute sufficient cause to reject a Vendor's bid(s). Vendors are strongly encouraged to allow sufficient time to upload bids.

Critical updated information may be included in Addenda to this IFB. It is important that all Vendors responding on this IFB periodically check the State's eVP website for any Addenda that may be issued prior to the bid opening date. All Vendors shall be deemed to have read and understood all information in this IFB and all Addenda thereto.

2.8 BID CONTENTS

Vendors shall populate all attachments of this IFB that require the Vendor to provide information and include an authorized signature where requested. Failure to provide all required items, or Vendor's submission of incomplete items, may result in the University rejecting Vendor's bid, in the University's sole discretion

Vendor IFB responses shall include the following items and attachments, which shall be arranged in the following order:

- a) Cover Letter, which must contain all of the following; (i) a statement that confirms that the Vendor has read the IFB in its entirety, including all links, and all Addenda released in conjunction with the IFB; (ii) a statement that the Vendor agrees to perform in accordance with the scope of work, requirements, and specifications contained herein; and (iii) Vendor's agreement to comply with all instructions, terms and conditions, and attachments.
- b) Title Page: Include the company name, address, phone number and authorized representative along with the Bid Number.
- c) Completed and signed version of EXECUTION PAGES, along with the body of the IFB.
- d) Signed receipt pages of any addenda released in conjunction with this IFB, if required to be returned.
- e) Completed version of ATTACHMENT A: PRICING
- f) Completed version of ATTACHMENT D: HUB SUPPLEMENTAL VENDOR INFORMATION
- g) Completed version of ATTACHMENT E: CUSTOMER REFERENCE FORM
- h) Completed version of ATTACHMENT F: LOCATION OF WORKERS UTILIZED BY VENDOR
- i) Completed and signed version of ATTACHMENT G: CERTIFICATION OF FINANCIAL CONDITION
- j) Completed and signed version of ATTACHMENT H: VENDOR REQUEST FOR EO50 PRICE-MATCHING, if applicable

2.9 ALTERNATE BIDS

Unless provided otherwise in this IFB, Vendor may submit alternate bids for comparable Goods, various methods or levels of Service(s), or that propose different options. Alternate bids must specifically identify the IFB requirements and advantage(s) addressed by the alternate bid. Any alternate bid, in addition to the marking described above, must be clearly marked with the legend: "Alternate Bid # ___ [for 'name of Vendor']". Each bid must be for a specific set of Goods and Services and must include specific pricing. If a Vendor chooses to respond with various offerings, each must be offered with a separate price and be contained in a separate bid. Each bid must be complete and independent of other bids offered.

2.10 DEFINITIONS, ACRONYMS, AND ABBREVIATIONS

Relevant definitions for this IFB are provided in 01 NCAC 05A .0112 and in the Instructions to Vendors referenced below which are incorporated herein by this reference.

3.0 METHOD OF AWARD AND BID EVALUATION PROCESS

3.1 METHOD OF AWARD

North Carolina G.S. 143-52 provides a general list of criteria the University shall use to award contracts, as supplemented by the additional criteria herein. The Goods or Services being procured shall dictate the application and order of criteria; however, all award decisions shall be in the University's best interest.

All responsive bids will be reviewed, and award or awards will be based on the responsive bid(s) offering the lowest price that meets the specifications to include any required verifications set out herein such as but not limited to past performance, references, and financial documents.

While the intent of this IFB is to award a Contract(s) to a single Vendor for all line items the University reserves the right to make separate awards to different Vendors for one or more line items, to not award one or more line items or to cancel this IFB in its entirety without awarding a Contract, if it is considered to be most advantageous to the University to do so.

If a Vendor selected for award is determined by the University to be a non-resident of North Carolina, all responsive bids will be reviewed to determine if any of them were submitted by a North Carolina resident Vendor who requested an opportunity to match the price of the winning bid, pursuant to Executive Order #50 and G.S. 143-59 (for more information, please refer to ATTACHMENT H: VENDOR REQUEST FOR EXECUTIVE ORDER #50 PRICE MATCHING. If such bid(s) are identified, the University will then determine whether any such bid falls within the price-match range, and, if so, make a Contract award in accordance with the process that implements G.S. 143-59 and Executive Order #50.

The University reserves the right to waive any minor informality or technicality in bids received.

3.2 CONFIDENTIALITY AND PROHIBITED COMMUNICATIONS DURING EVALUATION

While this IFB is under evaluation, the responding Vendor, including any subcontractors and suppliers, is prohibited from engaging in conversations intended to influence the outcome of the evaluation. See the Paragraph 29 of the Instructions To Vendors entitled COMMUNICATIONS BY VENDORS.

Each Vendor submitting a bid to this IFB, including its employees, agents, subcontractors, suppliers, subsidiaries and affiliates, is prohibited from having any communications with any person inside or outside the using agency; issuing agency; other government agency office or body (including the purchaser named above, any department secretary, agency head, members of the General Assembly and Governor's office); or private entity, if the communication refers to the content of Vendor's bid or qualifications, the content of another Vendor's proposal, another Vendor's qualifications or ability to perform a resulting contract, and/or the transmittal of any other communication of information that could be reasonably considered to have the effect of directly or indirectly influencing the evaluation of proposals, the award of a contract, or both.

Any Vendor not in compliance with this provision shall be disqualified from evaluation and award. A Vendor's proposal may be disqualified if its subcontractor and/or supplier engage in any of the foregoing communications during the time that the procurement is active (*i.e.*, the issuance date of the procurement until the date of contract award or cancellation of the procurement). Only those discussions, communications or transmittals of information authorized or initiated by the issuing agency for this IFB or inquiries directed to the purchaser named in this IFB regarding requirements of the IFB (prior to proposal submission) or the status of the award (after submission) are excepted from this provision.

3.3 BID EVALUATION PROCESS

Only responsive submissions will be evaluated.

The University will conduct an evaluation of responsive Bids, as follows:

Bids will be received according to the method stated in the Bid Submittal section above.

All bids must be received by the issuing agency not later than the date and time specified in the IFB SCHEDULE Section above, unless modified by Addendum. Vendors are cautioned that this is a request for offers, not an offer or request to contract, and the University reserves the unqualified right to reject any and all offers at any time if such rejection is deemed to be in the best interest of the University.

At the date and time provided in the IFB SCHEDULE Section above, unless modified by Addendum, the bids from each responding Vendor will be opened publicly and all offers (except those that have been previously withdrawn, or voided bids) will be tabulated. The tabulation shall be made public at the time it is created. When negotiations after receipt of bids is authorized pursuant to G.S. 143-49 and 01 NCAC 05B.0503, only the names of offerors and the Goods and Services offered shall be tabulated at the time of opening. If negotiation is anticipated, cost and price shall become available for public inspection at the time of the award. Interested parties are cautioned that these costs and their components are subject to further evaluation for completeness and correctness and therefore may not be an exact indicator of a Vendor's pricing position.

At their option, the evaluators may request oral presentations or discussions with any or all Vendors for clarification or to amplify the materials presented in any part of the bid. Vendors are cautioned, however, that the evaluators are not required to request presentations or other clarification—and often do not. Therefore, all bids should be complete and reflect the most favorable terms available from the Vendor. Prices bid cannot be altered or modified as part of a clarification.

Bids will generally be evaluated, based on completeness, content, cost and responsibility of the Vendor to supply the requested Goods and Services. Specific evaluation criteria are listed in Section 3.1 METHOD OF AWARD.

Upon completion of the evaluation process, the University will make Award(s) based on the evaluation and post the award(s) to the State's eVP website under the IFB number for this solicitation. Award of a Contract to one Vendor does not mean that the other bids lacked merit, but that, all factors considered, the selected bid was deemed most advantageous and represented the best value to the University.

The University reserves the right to negotiate with one or more Vendors, or to reject all original offers and negotiate with one or more sources of supply that may be capable of satisfying the requirement, and in either case to require Vendor to submit a Best and Final Offer (BAFO) based on discussions and negotiations with the University.

3.4 PERFORMANCE OUTSIDE THE UNITED STATES

Vendor shall complete ATTACHMENT F: LOCATION OF WORKERS UTILIZED BY VENDOR. In addition to any other evaluation criteria identified in this IFB, the University may also consider, for purposes of evaluating proposed or actual contract performance outside of the United States, how that performance may affect the following factors to ensure that any award will be in the best interest of the University:

- a) Total cost to the University
- b) Level of quality provided by the Vendor
- c) Process and performance capability across multiple jurisdictions
- d) Protection of the University's information and intellectual property
- e) Availability of pertinent skills
- f) Ability to understand the University's business requirements and internal operational culture
- g) Particular risk factors such as the security of the University's information technology
- h) Relations with citizens and employees
- i) Contract enforcement jurisdictional issues

3.5 INTERPRETATION OF TERMS AND PHRASES

This IFB serves two functions: (1) to advise potential Vendors of the parameters of the solution being sought by the University; and (2) to provide (together with other specified documents) the terms of the Contract resulting from this procurement. The use of phrases such as "shall," "must," and "requirements" are intended to create enforceable contract conditions. In

determining whether bids should be evaluated or rejected, the University will take into consideration the degree to which Vendors have proposed or failed to propose solutions that will satisfy the University’s needs as described in the IFB. Except as specifically stated in the IFB, no one requirement shall automatically disqualify a Vendor from consideration. However, failure to comply with any single requirement may result in the University exercising its discretion to reject a bid in its entirety.

4.0 REQUIREMENTS

This Section lists the requirements related to this IFB. By submitting a bid, the Vendor agrees to meet all stated requirements in this Section, as well as any other specifications, requirements, and terms and conditions stated in this IFB. If a Vendor is unclear about a requirement or specification or believes a change in a requirement would allow for the University to receive a better bid, the Vendor is encouraged to submit these items in the form of a question during the question and answer period in accordance with the Bid Questions Section above.

4.1 PRICING

Bid price shall constitute the total cost to the University for delivery fully assembled and ready for use, including all applicable charges for shipping, delivery, handling, administrative and other similar fees. Complete ATTACHMENT A: PRICING FORM and include in Vendor’s response.

4.2 ESTIMATED QUANTITIES

This section is intentionally omitted.

4.3 PRODUCT IDENTIFICATION

SUITABILITY FOR INTENDED USE

Vendors are requested to offer only items directly complying with the specifications herein or comparable items which will provide the equivalent capabilities, features and diversity called for herein. The University reserves the right to evaluate all bids for suitability for the required use and to award the one best meeting requirements and considered to be in the University’s best interest.

4.4 TRANSPORTATION AND IDENTIFICATION

The Vendor shall deliver Free-On-Board (FOB) Destination to any requested location within the State of North Carolina with all transportation costs and fees included in the total bid price.

When an order is placed using a purchase order, the purchase order number shall be shown on all packages and shipping manifests to ensure proper identification and payment of invoices. If an order is placed without using a purchase order, such as via phone, the Buyer’s name shall be show on all packages. A complete packing list shall accompany each shipment. Vendors shall not ship any products until they have received an order.

4.5 DELIVERY AND INSTALLATION

DELIVERY

The Vendor shall deliver Free-On-Board (FOB) Destination to the following location(s): **For completion by Vendor:** Delivery will be made from _____ (city, state) within _____ consecutive calendar days after receipt of purchase order. Promptness of delivery may be used as a factor in the award criteria.

Delivery shall not be considered to have occurred until installation has been completed. Upon completion of the installation, the Vendor shall remove and properly dispose of all waste and debris from the installation site. The Vendor shall be responsible for leaving the installation area clean and ready to use.

INSTALLATION BY THE INSTALLING CONTRACTOR

A. Install VFD system in accordance with details, approved submittals and manufacturer's instructions and recommendations.

B. Provide field low voltage wiring of VFD system components. Provide field interconnecting wiring between VFD and filters, line reactors and/or by-pass starter if bypass starter is specified and the wiring is not installed at factory. Install wiring in metal conduit and in accordance with Electrical sections of Division 26 and applicable Electrical Code.

C. Provide control wiring between interlocks in VFD control circuits and driven motor's disconnect switches. Interlock VFD control circuits with driven motor's disconnect switches where such motor disconnect switches are provided. Disconnecting on-line motor shall shut down VFD. VFD shall restart upon reconnection of motor.

D. Do not connect ground from one unit to another unit's cabinet.

E. Use separate conduits for incoming and outgoing power conductors from each unit.

F. Use separate conduit for control wiring for each unit. Do not combine control wiring with power wiring.

G. Use minimum 18 ga shielded wiring with ground for control wiring.

H. Install floor mounted drives on concrete housekeeping pad and minimum 3/4" thick 50 durometer, neoprene rubber isolation pad. Install wall-mounted drives on metal framing in accordance with Section 26 0529.

Please see attached Chilled Water Infrastructure Expansion Bernard Chiller Plant – Pre-purchased Equipment Cooling Towers for additional details.

4.6 AUTHORIZED RESELLER

This section is intentionally omitted

4.7 WARRANTY

Manufacturer’s standard warranty shall apply. Vendors shall include a copy of the manufacturer’s standard warranty with the bid response.

Vendor warrants that all equipment furnished under this IFB will be newly manufactured, of good material and workmanship. The warranty will apply from date equipment is put into operation for a minimum period of twelve (12) months or the length of the manufacturer’s warranty, whichever is longer. Such warranty shall cover the cost of all defective parts replacement, labor, freight, and technicians’ travel at no additional cost to the University, or as specified by the Purchasing Agency herein. To the extent not superseded by the terms of this paragraph, manufacturer’s warranty terms shall apply. Vendor’s warranty shall be at least the level of coverage provided for its comparable customers.

The report of a problem does not presuppose that every call must result in an “on-site” visit for service/repair. The Vendor and/or service sub-contractor shall utilize best efforts to resolve problems in a timely fashion by using acceptable servicing methods to include, but not limited to, verbal problem analysis and remote diagnosis. The warranty requirement does not impose any additional duty on the University to make other than normal and good faith problem resolution efforts or expenditures of time. Vendor shall be responsible for compliance with warranty terms by any third-party service provider. Vendor shall provide contact information for warranty service provider, below.

Vendor is authorized by manufacturer to repair equipment offered during the warranty period? YES NO

Will the Vendor provide warranty service? YES NO, a manufacturer-authorized third party will perform warranty service.

Contact information for warranty service provider:

Company Name: _____

Company Address: _____

Contact Person (name): _____

Bid Number: 65-3000012452

Vendor: _____

Contact Person (phone number): _____

Contact Person (email): _____

4.8 MAINTENANCE OPTION

This section is intentionally removed.

4.9 DESCRIPTIVE LITERATURE

DESCRIPTIVE LITERATURE/CERTIFICATION

Each bid shall be accompanied by complete descriptive literature, specifications, certifications, and all other pertinent data necessary for thorough evaluation of the item(s) offered and sufficient to determine compliance of the item(s) with the specifications. Failure to include such information shall be a sufficient basis for rejection of the bid.

4.10 HUB PARTICIPATION

Pursuant to North Carolina General Statute G.S. 143-48, it is State policy to encourage and promote the use of small, minority, physically handicapped, and women contractors in purchasing Goods and Services. As such, this IFB will serve to identify those Vendors that are minority owned or have a strategic plan to support the State's Historically Underutilized Business program by meeting or exceeding the goal of 10% utilization of diverse firms as 1st or 2nd tier subcontractors. Vendor shall complete ATTACHMENT D: HUB SUPPLEMENTAL VENDOR INFORMATION.

4.11 REFERENCES

Vendors shall provide at least three (3) references, using ATTACHMENT E: CUSTOMER REFERENCE FORM, for which your company has supplied the exact model of equipment offered. The University *may* contact these users to determine quality level of the offered equipment; as well as, but not limited to user satisfaction with Vendor performance. Information obtained *may* be considered in the evaluation of the bid.

4.12 VENDOR'S REPRESENTATIONS

If the bid results in an award, Vendor agrees that it will not enter any agreement with a third party that may abridge any rights of the University under the Contract. If any Services, deliverables, functions, or responsibilities not specifically described in this solicitation are required for Vendor's proper performance, provision and delivery of the Service and deliverables under a resulting Contract, or are an inherent part of or necessary sub-task included within such service, they will be deemed to be implied by and included within the scope of the contract to the same extent and in the same manner as if specifically described in the Contract. Unless otherwise expressly provided herein, Vendor will furnish all of its own necessary management, supervision, labor, facilities, furniture, computer and telecommunications equipment, software, supplies and materials necessary for the Vendor to provide and deliver the Services and/or other Deliverables.

4.13 FINANCIAL STABILITY

As a condition of contract award, the Vendor must certify that it has the financial capacity to perform and to continue to perform its obligations under the Contract; that Vendor has no constructive or actual knowledge of an actual or potential legal proceeding being brought against Vendor that could materially adversely affect performance of this Contract; and that entering into this Contract is not prohibited by any contract, or order by any court of competent jurisdiction

Each Vendor shall certify it is financially stable by completing the ATTACHMENT G: CERTIFICATION OF FINANCIAL CONDITION. The University is requiring this certification to minimize potential performance issues from contracting with a Vendor that is financially unstable. This Certification shall be deemed continuing, and from the date of the Certification to the expiration of the Contract, the Vendor shall notify the University within thirty (30) days of any occurrence or condition that materially alters the truth of any statement made in this Certification.

4.14 AGENCY INSURANCE REQUIREMENTS MODIFICATION

This section is intentionally omitted. Please see standard Terms and Conditions attached.

4.15 NC COVID-19 VACCINATION AND TESTING REQUIREMENT

This section is intentionally omitted.

4.16 FEDERAL COVID-19 VACCINATION REQUIREMENT

This section is intentionally omitted.

4.17 LOBBYING ACTIVITY CERTIFICATION FOR FEDERAL GRANTS

This section is intentionally omitted.

5.0 PRODUCT SPECIFICATIONS

5.1 SPECIFICATIONS

See the Scope of Work document, Chilled Water Infrastructure Expansion Bernard Chiller Plant

SCO ID 22-25588-02H, Code: 42123-355/42323-305

Pre-purchased Equipment Cooling Towers

VFD DESCRIPTION

Manufacturers: ABB, Danfoss, Yaskawa

A. Variable-frequency power converter (rectifier, dc bus, and IGBT, PWM inverter) factory packaged in an enclosure, with integral disconnecting means and overcurrent and overload protection, arranged to provide self-protection, and variable-speed control of one three-phase induction motors by adjusting output voltage and frequency.

1. Units suitable for operation of NEMA MG 1, Design A and Design B motors as defined by NEMA MG 1, Section IV, Part 30, "Application Considerations for Constant Speed Motors Used on a Sinusoidal Bus with Harmonic Content and General Purpose Motors Used with Adjustable-Voltage or Adjustable-Frequency Controls or Both."

2. Units suitable for operation of inverter-duty motors as defined by NEMA MG 1, Section IV, Part 31, "Definite-Purpose Inverter-Fed Polyphase Motors."

3. Units shall be fully rated to withstand integrated short-circuit current.

COOLING TOWER (FIELD_ERECTED< INDUCED_DRAFT< COUNTERFLOR TYPE)

Acceptable Manufacturers:

- 1. Composite Cooling Solutions (CCS)
- 2. EvapTech, Inc. (EvapTech)
- 3. Marley/SPX Cooling Technologies (SPX)

B. General

1. Provide field erected induced draft, vertical discharge, fiberglass structure, doublesided air inlet, counterflow type cooling tower as shown.

2. Work shall include, but is not limited to, providing design services, field erection labor, field supervision, materials, equipment and ancillaries to design, fabricate, deliver, erect, start-up, and test the cooling tower as specified herein. Tower manufacturer shall correct all deficiencies at no additional cost to the Owner. Tower shall be field erected by factory trained representatives of the manufacturer.

3. Tower shall be complete and shall include, but not be limited to, stainless steel basin, basin heater system, frame structure, casings, and partitions, fill material and fill support system, circulating water distribution system, drift eliminators, motors, fan stacks, air inlet sound attenuators, vibration switches, supports, hardware, bolts, nuts, connectors, anchor bolts, etc.
4. Manufacturer shall be responsible for just-in-time delivery, unloading and storage of materials and equipment at jobsite. There is limited laydown space available at the site and all materials must be stored off-site and brought to the site on a just-in-time basis. The location of space for laydown of tower materials shall be coordinated with all trades. Provide laydown plan to Contractor for review and approval.
5. Cooling towers shall be Factory Mutual (FM) approved as noncombustible in the arrangement shown on the drawings with adjacent cells directly connected to each other. Cooling tower design shall comply with FM Global Standard for Cooling Towers Class Number 4930 for Multi-cell towers. Cooling tower design shall comply with FM 4930 for fire, materials and testing requirements. Wind design shall be in accordance with FM Global data sheet 1-28.
6. Tower to be fiberglass-reinforced polyester (FRP) or vinyl resins with PVC fill, with capacity and operating characteristics as specified herein. All fiberglass shall be impregnated with fire retardant and self-extinguishing additives.
7. All components, including fill material, shall possess flame spread rating of not over 25, without evidence of continued progressive combustion, and smoke developed rating no higher than 50 in accordance with NFPA 90A.
8. No plain steel or galvanized steel components will be allowed in the tower

Please see attached Chilled Water Infrastructure Expansion Bernard Chiller Plant – Prepurchased Equipment Cooling Towers Bid Document for additional details.

5.2 CERTIFICATION AND SAFETY LABELS

All manufactured items and/or fabricated assemblies subject to operation under pressure, operation by connection to an electric source, or operation involving a connection to a manufactured, natural, or LP gas source shall be constructed and approved in a manner acceptable to the appropriate state inspector which customarily requires the label or re-examination listing or identification marking of the appropriate safety standard organization; such as the American Society of Mechanical Engineers for pressure vessels; the Underwriters Laboratories and /or National Electrical Manufacturers' Association for electrically operated assemblies; or the American Gas Association for gas operated assemblies, where such approvals of listings have been established for the type of device offered and furnished. Further, all items furnished shall meet all requirements of the Occupational Safety and Health Act (OSHA), and state and federal requirements relating to clean air and water pollution.

5.3 DEVIATIONS

The nature of all deviations from the Specifications listed herein shall be clearly described by the Vendor. Otherwise, it will be considered that items offered by the Vendor are in strict compliance with the Specifications provided herein, and the successful Vendor shall be required to supply conforming goods. Deviations shall be explained in detail on an attached sheet. However, no implication is made or intended by the University that any deviation will be acceptable. Do not list objections to the North Carolina General Terms and Conditions in this section.

6.0 CONTRACT ADMINISTRATION

All Contract Administration requirements are conditioned on an award resulting from this solicitation. This information is provided for the Vendor's planning purposes

6.1 CONTRACT MANAGER AND CUSTOMER SERVICE

This section is intentionally omitted.

6.2 POST AWARD PROJECT REVIEW MEETINGS

This section is intentionally omitted.

6.3 CONTINUOUS IMPROVEMENT

The University encourages the Vendor to identify opportunities to reduce the total cost the University. A continuous improvement effort consisting of various ideas to enhance business efficiencies as performance progresses.

6.4 PERIODIC STATUS REPORTS

This section is intentionally omitted.

6.5 ACCEPTANCE OF WORK

Performance of the work and delivery of Goods shall be conducted and completed at least in accordance with the Contract requirements and recognized and customarily accepted industry practices. Performance shall be considered complete when the Services or Goods are approved as acceptable by the Contract Administrator.

Acceptance of work products shall be based on the following criteria: See Scope of work.

The University shall have the obligation to notify Vendor, in writing ten (10) calendar days following completion of such work or delivery of a deliverable described in the Contract that it is not acceptable. The notice shall specify in reasonable detail the reason(s) it is unacceptable. Acceptance by the University shall not be unreasonably withheld; but may be conditioned or delayed as required for reasonable review, evaluation, installation, or testing, as applicable to the work or deliverable. Final acceptance is expressly conditioned upon completion of all applicable assessment procedures. Should the work or deliverables fail to meet any specifications, acceptance criteria or otherwise fail to conform to the Contract, the University may exercise any and all rights hereunder, including, for Goods deliverables, such rights provided by the Uniform Commercial Code, as adopted in North Carolina.

6.6 INVOICES

Vendor shall invoice the Purchasing Agency. The standard format for invoicing shall be Single Invoices meaning that the Vendor shall provide the Purchasing Agency with an invoice for each order. Invoices shall include detailed line item information to allow Purchasing Agency to verify pricing at point of receipt matches the correct price from the original date of order. At a minimum, the following fields shall be included on all invoices:

Vendor’s Billing Address, Customer Account Number, NC Contract Number, Order Date, Buyer’s Order Number, Manufacturer Part Numbers, Vendor Part Numbers, Item Descriptions, Price, Quantity, and Unit of Measure.

INVOICES MAY NOT BE PAID UNTIL AN INSPECTION HAS OCCURRED AND THE GOODS ACCEPTED.

6.7 DISPUTE RESOLUTION

During the performance of the Contract, the Parties agree that it is in their mutual interest to resolve disputes informally. Any claims by the Vendor shall be submitted in writing to the University’s Contract Manager for resolution. Any claims by the University shall be submitted in writing to the Vendor’s Project Manager for resolution. The Parties shall agree to negotiate in good faith and use all reasonable efforts to resolve such dispute(s).

During the time the Parties are attempting to resolve any dispute, each shall proceed diligently to perform their respective duties and responsibilities under this Contract. The Parties will agree on a reasonable amount of time to resolve a dispute. If a dispute cannot be resolved between the Parties within the agreed upon period, either Party may elect to exercise any other remedies available under the Contract, or at law. This provision, when agreed in the Contract, shall not constitute an agreement by either party to mediate or arbitrate any dispute.

6.8 PRODUCT RECALL

Vendor expressly assumes full responsibility for prompt notification to the Buyer listed on the face of this IFB of any product recall in accordance with the applicable state or federal regulations. The Vendor shall support the University, as necessary, to promptly replace any such products, at no cost to the University.

6.9.1 PRICE ADJUSTMENTS

Prices proposed by the Vendor shall be firm against any increase for 60 days from the effective date of the Contract.

Price increase requests shall be submitted in writing to the Contract Lead, which shall include the reason(s) for the request and contain supporting documentation for the need. Price increases will be negotiated and agreed to by both the University and Vendor in advance of any price increase going into effect. The University is not obligated to accept pricing adjustments or increases and reserves the right to accept or reject them in part or in whole. Price de-escalation or decreases may be requested by the University at any time.

It is understood and agreed that orders will be shipped at the established Contract prices in effect on the date an order is placed. Invoicing that deviates from this provision may result in Contract to cancellation.

6.10 CONTRACT CHANGES

Contract changes, if any, over the life of the Contract shall be implemented by contract amendments agreed to in writing by the University and Vendor. Amendments to the contract can only be made through the contract administrator.

The remainder of this page is intentionally left blank

7.0 ATTACHMENTS

****IMPORTANT NOTICE****

RETURN THE REQUIRED ATTACHMENTS WITH YOUR RESPONSE
FOLLOW THE LINKS TO ACCESS EACH ATTACHMENT

ATTACHMENT A: PRICING

No attachment associated with this IFB. **Please submit all costs including transportation on a standard company quote document with a line for "TOTAL COST TO THE UNIVERSITY".**

ATTACHMENT B: INSTRUCTIONS TO VENDORS

The Instructions to Vendors, which are incorporated herein by this reference, may be found here:

<https://www.doa.nc.gov/divisions/purchase-contract/vendor-forms>

ATTACHMENT C: NORTH CAROLINA GENERAL TERMS & CONDITIONS

The North Carolina General Terms and Conditions, which are incorporated herein by this reference, may be found here:

<https://www.doa.nc.gov/divisions/purchase-contract/vendor-forms>

ATTACHMENT D: HUB SUPPLEMENTAL VENDOR INFORMATION

Complete and return the Historically Underutilized Businesses (HUB) Vendor Information form, which can be found at the following link:

<https://www.doa.nc.gov/divisions/purchase-contract/vendor-forms>

ATTACHMENT E: CUSTOMER REFERENCE FORM

Complete and return the Customer Reference Form, which can be found at the following link:

<https://www.doa.nc.gov/divisions/purchase-contract/vendor-forms>

ATTACHMENT F: LOCATION OF WORKERS UTILIZED BY VENDOR

Complete and return the Location of Workers Utilized by Vendor, which can be found at the following link:

<https://www.doa.nc.gov/divisions/purchase-contract/vendor-forms>

ATTACHMENT G: CERTIFICATION OF FINANCIAL CONDITION

Complete, sign, and return the Certification of Financial Condition, which can be found at the following link:

<https://www.doa.nc.gov/divisions/purchase-contract/vendor-forms>

ATTACHMENT H: VENDOR REQUEST FOR EO50 PRICE-MATCHING

Complete, sign, and return the Vendor Request for EO50 Price-Matching, which can be found at the following link:

<https://www.doa.nc.gov/divisions/purchase-contract/vendor-forms>

***** Failure to Return the Required Attachments May Eliminate
Your Response from Further Consideration *****



THE UNIVERSITY
of **NORTH CAROLINA**
at **CHAPEL HILL**

Chilled Water Infrastructure Expansion Bernard Chiller Plant

SCO ID 22-25588-02H, Code: 42123-355 / 42323-305
UNC Bldg. No. xxx

Prepurchased Equipment Cooling Towers Bid Set

Submitted by:



1414 Raleigh Road, Suite 305
Chapel Hill, North Carolina 27517
(919) 419-9802
License No. C-2982

AEI Project No. 23480-01

July 22, 2025

TABLE OF CONTENTS

SPECIFICATIONS

SECTION TITLE

DIVISION 23 - HEATING, VENTILATING, AND AIR-CONDITIONING

23 0514	Process Variable Frequency Drive (VFD) System
23 6510	Cooling Towers

DRAWINGS

SHEET TITLE

B.M.204	Overall Equipment Plan – Roof Level
B.M.214.A	Mechanical Piping Plan – Roof Level - Area A
B.M.214.B	Mechanical Piping Plan – Roof Level - Area B
B.M.215.A	Mechanical Piping Plan – Dunnage Level - Area A
B.M.215.B	Mechanical Piping Plan – Dunnage Level - Area B
B.M.216.A	Mechanical Piping Plan – Fan Deck Level - Area A
B.M.216.B	Mechanical Piping Plan – Fan Deck Level - Area B
B.M.306	Mechanical Sections
B.M.307	Mechanical Sections
B.M.403	Condenser Water P&ID
B.M.601	Mechanical Schedules

CERTIFICATION



07/22/25

END OF TABLE OF CONTENTS

**SECTION 23 0514
PROCESS VARIABLE FREQUENCY DRIVE (VFD) SYSTEM**

PART 1 - GENERAL

1.1 OWNER PRE-PURCHASED EQUIPMENT

- A. This equipment will be prepurchased by the Owner with the cooling tower and furnished to the successful Contractor after award for expediting delivery and installation as if the Contractor purchased the equipment directly.
- B. Owner will make available manufacturer provided shop drawings of Owner prepurchased equipment for review by the Contractor. Contractor shall review shop drawings to ascertain that Contractor has included necessary labor and materials to install equipment and complete system it serves.
- C. Contractor shall be responsible for arranging/coordinating delivery of Owner prepurchased equipment and all other related logistics and activities. This includes directing the delivery truck to the jobsite, coordinating the date and time of delivery, and receipt of the equipment at the jobsite. Manufacturer is responsible for equipment until it is unloaded at the jobsite by the Contractor.
- D. Contractor shall install Owner prepurchased equipment and all appurtenances. This shall include, but not be limited to; unloading, rigging and setting equipment in place, making connections, starting, testing and installing equipment in accordance with manufacturer's recommendations, and maintaining equipment until such time as project is accepted by Owner. Perform all work and provide materials and connections for Owner furnished equipment in accordance with drawings and scope of work under all related specifications.
- E. The following summarizes the general responsibilities of the equipment manufacturer:
 - 1. Provide shop drawings and submittal data.
 - 2. Manufacture and delivery of equipment including coordination of exact delivery date and supervision of rigging, unloading, and setting.
 - 3. Lead equipment check-out, testing, and start-up process and submit report(s).
 - 4. Provide touch up paint.
 - 5. Provide O&M documentation.
 - 6. Provide Owner training and participate in commissioning process.

1.2 SCHEDULE

A. Schedule:

- 1. The following schedule is anticipated relative to this prepurchased equipment delivery, installation and activation. This is a preliminary schedule and exact dates are to be coordinated with the Owner and Contractor.
 - a. Tower Materials Delivery and Erection: March 2027 – July 2027
 - b. Installation Work By Contractor: July 2027 – November 2027
 - c. Start-Up & Commissioning: November 2027– March 2028
 - d. Vibration and Acoustical Testing ... December 2027

UNC - Chapel Hill

CHW Infrastructure Expansion – BCP
Prepurchased Equipment – Cooling Towers

07/22/25

Process Variable Frequency Drive (VFD)
System

23 0514 - 1

e. Thermal Performance Testing July 2028

- B. Contractor shall plan construction to allow for equipment to be received and installed at the job site within the above delivery window. If Contractor is unable to install equipment upon coordinated delivery date(s), it is the Contractor's responsibility to provide appropriate storage for equipment, local to the University, and provide transportation of equipment from storage site to job site.

1.3 SYSTEM DESCRIPTION

- A. Provide Variable Frequency Drives (VFD) for each cooling tower fan sized to accommodate motors shown on drawings or schedules. All VFDs shall be from the same manufacturer. Refer to the drawings for the VFD schedule.
- B. VFD manufacturer shall confirm compatibility of driven equipment and motors with VFD. Submit written statement from manufacturer of driven equipment along with VFD shop drawing submittals, indicating verification of compatibility.
- C. VFD shall vary speed of its respective fan, pump or other driven equipment motor in response to either 4-20 mA control signal provided by Controls Contractor.
- D. VFD system shall consist of the following:
 - 1. Variable frequency drive(s).
 - 2. UL Listed disconnect device.
 - 3. NEC recognized disconnect device (circuit breaker).
 - 4. Internal reactor with minimum 5% impedance or equivalent input line reactor.
 - 5. Operator keypad and display unit.
 - 6. All components shall be in a common enclosure with single point wiring.
 - 7. All auxiliary power shall be derived locally from a CPT inside the enclosure.
 - 8. Provide internal fan(s) for cooling.
- E. Drives shall have SCCR (short circuit current rating) of 65 kA.
- F. All VFD system components, including (but not limited to) input filters, drive, output filters, harmonic filters, etc. shall be located within a common enclosure, with a single point electrical connection for supply wiring and a single point electrical connection for wiring to load (motor). Enclosure shall be properly sized and equipped with fans for cooling all components required.

1.4 QUALIFICATIONS

- A. VFD system shall be furnished by a manufacturer with at least 10 years experience in design, construction and application of VFD equipment.

1.5 BID SUBMITTALS

- A. The following shall be provided with the equipment bid proposal:
 - 1. Cover letter with compliance table listing each specification section and indicating compliance "C", deviation for alternate "D", or exception with explanation "E". Any deviation or exception shall be accompanied with detailed explanation of how design intent is being upheld for evaluation by the Owner and Designer.

UNC - Chapel Hill

CHW Infrastructure Expansion – BCP
Prepurchased Equipment – Cooling Towers

07/22/25

Process Variable Frequency Drive (VFD)
System

23 0514 - 2

2. Product data including:
 - a. Manufacturer's name
 - b. Identification of system components
 - c. Type of enclosure, dimensioned front elevation and plan view, equipment weight, conduit and cabling access locations.
 - d. Physical installation requirements for service access and ventilation.
 - e. Capacities/ratings/SCCR
 - f. System wiring and block diagram showing system components.

- B. References: a complete list of references shall be provided with each Proposal. The list shall include a minimum of five (5) references where equipment of similar manufacturer type and capacity has been installed. The list shall indicate the name of the facility where the equipment has been installed, location (city and state) of the equipment, installation date, equipment capacity, contact name and contact telephone number of each reference.

- C. Scheduled Maintenance Requirements: A complete list of the recommended scheduled maintenance requirements for the equipment shall be provided with each Proposal. The list shall identify each recommended service item and its recommended frequency (monthly, quarterly, etc.). The list shall, at a minimum, include the scheduled maintenance items identified.

- D. Other information to verify compliance with the Invitation for Bids.

- E. Award will be based on specification compliance and best overall value for the Owner.

1.6 FABRICATION SUBMITTALS

- A. Product Data for each VFD system including the following:
 1. Complete technical description of the VFD system.
 2. Manufacturer's name.
 3. Identification of system components.
 4. 3-Wire system wiring and block diagram showing all system components.
 5. LV controls wiring schematic, terminations, DI/DO/AI/AO points, interface requirements with DCS system via MODBUS TCP/IP.
 6. Type of enclosure, dimensioned front elevation and plan view, equipment weight, conduit access locations.
 7. Physical installation requirements for access and ventilation.
 8. Capacities/ratings/SCCR.
 9. Cabling entry/exit and size requirements.
 10. System wiring and block diagram showing system components.
 11. Performance, control and protection data with specified features clearly shown.
 12. Operating and monitoring devices with specified features clearly indicated.
 13. Manufacturer's installation instructions.
 14. Start-up operation, maintenance, spare parts, and field tests.
 15. Other appropriate data.

- B. After quality assurance tests are complete, submit written certification that drive and components have passed factory quality assurance tests.
- C. Submit product and performance data on electrical noise attenuation device if required to meet electrical noise criteria specified. Isolation transformer is not electrical noise attenuation device.
- D. Submit printed list of settings for all items that require setting during startup or list of Factory Default Parameters.

1.7 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data:
 - 1. Include manufacturer's recommended operating instructions, maintenance procedures and intervals, and preventive maintenance instructions.
 - 2. Include manufacturer's written instructions for testing and adjusting system.
 - 3. Include spare parts data listing, source, and current prices of replacement parts and supplies.
 - 4. Include copy of equipment warranty.

1.8 SPARE PARTS

- A. Three (3) spare fuses for each size or type of VFD.
- B. One (1) spare enclosure cooling fan for each different type of drive.
- C. Three (3) spare sets of ventilation air filters for each drive.
- D. One (1) spare key pad/touch screen for each different type of drive.

1.9 WARRANTY

- A. Manufacturer shall provide a five year warranty against defects in materials and workmanship for products specified in this Section. Warranty period shall begin on date of project final acceptance.

PART 2 - PRODUCTS

2.1 MANUFACTURER

- A. Manufacturers: ABB, Danfoss, Yaskawa

2.2 VFD DESCRIPTION

- A. Variable-frequency power converter (rectifier, dc bus, and IGBT, PWM inverter) factory packaged in an enclosure, with integral disconnecting means and overcurrent and overload protection, arranged to provide self-protection, and variable-speed control of one three-phase induction motors by adjusting output voltage and frequency.

1. Units suitable for operation of NEMA MG 1, Design A and Design B motors as defined by NEMA MG 1, Section IV, Part 30, "Application Considerations for Constant Speed Motors Used on a Sinusoidal Bus with Harmonic Content and General Purpose Motors Used with Adjustable-Voltage or Adjustable-Frequency Controls or Both."
2. Units suitable for operation of inverter-duty motors as defined by NEMA MG 1, Section IV, Part 31, "Definite-Purpose Inverter-Fed Polyphase Motors."
3. Units shall be fully rated to withstand integrated short-circuit current.

2.3 FABRICATION

- A. VFD shall be of a fixed DC bus type with a full wave input diode bridge. The VFD shall convert 3 phase 60 Hz input power to three phase adjustable voltage, adjustable frequency output power using Pulse Width Modulation (PWM) switching techniques and third generation I.G.B.T.'s.
- B. VFD shall be variable torque, solid state, microprocessor-based control, modular design for standard induction AC motor.
- C. For maintenance purposes, VFD shall be capable of stable operation, (starting, stopping and running), with the motor completely disconnected (no load).
- D. Refer to the VFD schedule for maximum dimensions for the enclosure as well as cable entry/exit requirements.
- E. VFD shall be capable of operating any standard "off-the-shelf" squirrel cage induction motor with a full load rating within the capacity of the VFD. Therefore, at any time in the future it shall be possible to install a standard new or rewound motor in the field without requiring modification of the VFD.
- F. Circuitry shall be plug-in, plug-out modular. Printed circuit boards shall have protective coating to reduce corrosion.
- G. Complete unit shall conform to NEMA and NEC standards and control circuitry shall be electrically isolated from power circuitry. Entire assembly panel shall be third party listed. Third party agency shall be amongst those accredited by the North Carolina Building Code Council (NCBCC) to label electrical and mechanical equipment.
<https://www.ncosfm.gov/codes/state-electrical-division/qualified-testing-laboratories>
- H. Provide control power transformer to serve enclosure auxiliary power requirements.

2.4 PERFORMANCE REQUIREMENTS

- A. Input: 460 (+10%, -10%) VAC, 3 Ph, 60 (\pm 2) Hz
- B. Output: 460 VAC, 3 Ph, 10 to 60 Hz
- C. Operating Environment: VFD Manufacturer shall rate VFDs for specific environment in which they will operate.
 1. Ambient temperature:
 - a. Indoor applications: 14°F to 104°F
 2. Relative humidity: 95% non-condensing

3. Elevation above sea level: 0 ft to 3280 ft

- D. Linear acceleration and deceleration adjustable from 5 to 60 seconds. Provide adjustable v/Hz ratio and low speed boost features.
- E. Output Current Rating: Continuous full load output current rating of drive shall not be less than that listed for motor of equivalent horsepower in NEC table 430-150.
- F. Drive overload capacity to be minimum 110% of motor FLA based on NEC ratings for one minute.
- G. Time to Shutdown: Inversely proportional to square of overload current ($t = k/I^2$).
- H. Motor Regeneration Protection: Unit shall have capacity of dissipating regeneration energy up to VFD current rating without damage to or shutdown of drive. Unit shall be capable of starting into rotating load.
- I. Output Frequency Stability: $\pm 0.5\%$ of base frequency in 24 h throughout range of rated operating conditions.
- J. Output Voltage Regulation: $\pm 2\%$ of maximum rated output voltage.
- K. Output voltage rise time shall be no faster than 1000 V/micro sec measured at the motor terminals.
- L. Power Loss Ride-Through: 1 cycle.
- M. Linearity (speed reference to output frequency): $\pm 1.0\%$
- N. Input Power Factor: Minimum of 0.95 regardless of speed and load.
- O. Minimum drive efficiency as percent of input power shall be as follows:

<u>Percent Load</u>	<u>Frequency (Hz)</u>			
	<u>60</u>	<u>50</u>	<u>30</u>	<u>15</u>
100	97	96	95	90
75	97	96	94	90
50	97	96	94	90
25	96	95	91	84

2.5 CONTROL FEATURES

- A. VFD shall have a door mounted digital operator interface with an 8-Line, 32-character HOA LCD display providing readout functions that include output frequency, output voltage, output current, output power, DC bus voltage, interface terminal status, PI feedback and fault status.
- B. Main Printed Circuit Board (PCB) must be common throughout the various horsepower models. The main PCB must be able to be quickly removed from the drive chassis via the use of plug-in connectors and removable terminal blocks.

- C. Main PCB must have at least three programmable multi-function output relays (Form A or Form C, rated 2 A @ 250 VAC & 30 VDC)VFD shall have an enclosure constructed from metal to reduce E.M.I.
- D. Main PCB shall be constructed with isolated control circuitry.
- E. VFD must have bi-directional auto-speed search for starting into rotating loads spinning in any direction and returning the motor is desired speed in the proper direction.
- F. VFD speed control circuit shall accept either 4-20 mA DC isolated ungrounded transmitter signal in automatic mode and from manual speed control keypad in manual mode.
- G. Provide adjustable minimum and maximum speed settings (0 - 100%) for both auto and manual mode. Initial minimum setting shall be 25%.
- H. Provide adjustable automatic reset for fault trips, except short circuit type faults. After selected number of unsuccessful restart attempts, drive shall be shut down. Number of restart attempts and time interval between resets shall be selective.
- I. When unit shuts down due to power outage, unit shall be capable of being restarted manually or automatically.
- J. VFD shall be capable of starting into rotating loads spinning in any direction.
- K. Provide critical frequency avoidance circuit with at least 3 field adjustable bands to avoid operation at speeds, which cause excessive vibration in driven equipment.
- L. Minimum drive efficiency as percent of input power shall be as follows: 96% at half-speed; 98% at full-speed.
- M. Provide drive with provisions to accept an ungrounded 4-20 mA output signal..
- N. For exposed outdoor motors VFD controller shall receive signals from motor winding thermostats to shut motor off due to overheating and energize 120V motor heater based on run status and low winding temperature to prevent internal motor condensation.

2.6 INTEGRATION WITH DISTRIBUTED CONTROL SYSTEM (DCS)

- A. Furnish each VFD with digital communication bus card for connection to DCS use via MODBUS TCP/IP. No third-party translator is permitted. Coordinate with Control Contractor for specific interface requirement.
- B. The VFD shall be capable of communicating all available information all operational and safety information/control information that VFD utilizes to operate to the DCS including Manual-Off-Automatic status.
- C. Provide four pre-programmed relay/contacts for remote output indication of VFD fault condition, motor run status based on current or torque above minimum threshold, and one spare.

- D. In addition to the above communication, the VFD shall be capable of communicating the following hard wired input/output signals with the DCS. Provide all required wiring, relays, contacts, terminal strips, etc. to support this communication.
1. VFD start/stop
 2. VFD status
 3. VFD fault
 4. VFD speed
 5. Motor kW
 6. Forward Rotation (Cooling Towers Only)
 7. Reverse Rotation (Cooling Towers Only)

2.7 PROTECTION FEATURES

- A. Power circuits shall be protected by electronic protection circuits. Electronic protection circuits shall provide orderly shutdown without blowing fuses and prevent component loss under the following abnormal conditions.
1. Overcurrent protection shall be via circuit breaker. The use of fused disconnect is not allowed.
 2. Instantaneous overcurrent and over voltage trip of output.
 3. Solid state protective circuit shall provide NEC motor running overload protection tested in accordance with UL 991.
 4. Power line overvoltage or undervoltage.
 5. Phase sequence detection or insensitivity to incoming power phase sequence.
 6. Single and 3 Ph short circuit protection.
 7. Control circuit malfunction.
 8. Overtemperature.
 9. Ground fault for all 3 phases.
- B. VFD shall protect itself from damage due to phase-to-phase or phase-to-ground faults without fuse blowing or use of isolation transformers. VFDs which require isolation transformers to provide ground fault protection are not acceptable.
- C. In addition, provide the following protection features.
1. Input line-to-line and line-to-ground transient protection
 2. Control circuit transformer fusing.
 3. Grounded control chassis.
 4. Diagnostic indication.
- D. VFD shall employ adjustable torque limit control, which shall override speed command and decrease frequency while maintaining correct volts/hertz ratio whenever load level surpasses VFD design level or set point.
- E. VFD shall employ adjustable torque limit control which shall override the speed command and decrease the frequency while maintaining the correct volts/hertz ratio whenever the load level surpasses the VFD design level or set point.

- F. The AC drive shall have a minimum AC undervoltage power loss ride-through of 200 msec.

2.8 OPERATING AND MONITORING DEVICES

- A. The following functionality shall be provided and may be controlled via touchscreen/keypad:
 - 1. Hand-Off-Auto device.
 - 2. Operating mode selector device marked "Hand-Off-Auto".
 - 3. Manual speed control keypad.
 - 4. Power on indication.
 - 5. Drive run indication.
 - 6. Drive fault indication with testable feature.
 - 7. Fault reset device.
- B. Speed indicating meter or digital indication (0 - 100%) calibrated in percent speed or frequency meter with 0 to 90 Hz scale to indicate motor speed.
- C. Integral digital programming and operating display which shows Hz, Percent Output Current, Output Voltage, Percent Output Power, Operating Parameters and their values, and Diagnostic Fault Codes. In addition, Keypads shall be incorporated to facilitate digital programming of drive adjustments. Analog potentiometer adjustments are not acceptable.
- D. Provision shall be included to provide selectable programming security by inhibiting program parameter changes with password security.
- E. Control shall incorporate microprocessors for operator interface, diagnostics, and fault managements, and power management.
- F. Optional programming software, which includes provision for serial communication with drive, shall be available for shipment at time of equipment order placement.
- G. Fault buffers to sequentially store last four faults. Parameter and fault information to be stored in non-volatile memory.

2.9 QUALITY ASSURANCE TESTS

- A. Complete drive assembly shall be factory tested with actual AC induction motor, 100% load and temperature cycled within environment chamber at 104°F. Documentation of test shall be furnished to verify successful completion of test at Engineer's request.

2.10 DISCONNECT DEVICE

- A. Provide integral switch to disconnect incoming electrical power to units. Disconnect device shall be UL Listed devices:
 - 1. Enclosed molded case breaker; ampere rated and providing over current protection

- B. Disconnect device shall be capable of being padlocked in OFF position and complying with OSHA Requirements. Operating handle shall indicate whether switch is "ON" or "OFF".
- C. Switch shall have cover interlock to prevent unauthorized opening of switch door when handle is in "ON" position and to prevent closing of switch mechanism with door open. Provide defeater mechanism to defeat the interlock for user required access.

2.11 INPUT LINE REACTORS

- A. Series line reactors shall be designed for harmonic filtering service and shall be UL component recognized. Construction shall be copper wire wound on steel cores. Inductors shall be 3-phase. Design maximum temperature rise for inductors shall be 239°F.
- B. Inductors shall be air-gapped to avoid saturation. Inductance shall be measured under full load and shall be within $\pm 5\%$ of design value.
- C. Line reactor shall be included integral to drive enclosure.
 - 1. Where mounting line reactor in VFD enclosure is not possible, enclosure shall be steel with enamel finish and no knockouts. Enclosure shall match construction of VFD enclosure and shall have hinged lockable cover. Screened openings shall be provided for enclosure ventilation. Enclosure shall be built with integral mounting brackets for platform or wall mounting. Coordinate location with other trades. Provide disconnect switch for line side filters.
- D. Internal DC bus chokes are acceptable when providing equivalent performance to AC line reactors specified.

PART 3 – EXECUTION – BY THE EQUIPMENT MANUFACTURER

3.1 START-UP

- A. Provide services of factory trained engineer or technician to approve installation; start-up test and adjust for proper operation.
- B. Should drive operation be deficient, make changes necessary to bring units into compliance with specified performance requirements. Cost of changes and retest shall be borne by drive manufacturer.
- C. Upon completion of this service, submit report signed by manufacturer's service representative, including start-up and test log.

3.2 TRAINING

- A. The equipment manufacturer shall provide full operating, service and maintenance training programs for the Owner's maintenance personnel. All costs associated with Owner Training shall be included in the base proposal, including travel and per diem expenses. Training shall occur at the Owners facility. Training will be scheduled separately at a time determined by the Owner.

- B. Training shall only occur after the systems provided are installed by the Contractor, started up by the Manufacturer, and made ready for proper operation.
- C. Manufacturer shall instruct and train Owner's representative in operation and maintenance and participate in any commissioning of each system provided for the project.
- D. A complete syllabus and O&M Manuals shall be submitted and approved by Owner four weeks prior to training.
- E. Include minimum of 8 hours of start-up and Owner training and a minimum of an additional 8 hours of commissioning support time for each system.
- F. Owner may video tape training sessions for their use in future training of their operations and maintenance staff.

PART 4 – EXECUTION - BY THE INSTALLING CONTRACTOR

4.1 INSPECTION

- A. Visually inspect equipment and components at time of delivery. Submit report to Owner and Designer with list of items or deficiencies to be corrected.

4.2 PROTECTION

- A. Protect VFD cabinets from dust/dirt during storage and operation until turned over to Owner.
- B. If VFDs are not furnished with internal air filter racks, provide temporary filter media to protect VFD cabinets and replace filter media as required.

4.3 INSTALLATION

- A. Install VFD system in accordance with details, approved submittals and manufacturer's instructions and recommendations.
- B. Provide field low voltage wiring of VFD system components. Provide field interconnecting wiring between VFD and filters, line reactors and/or by-pass starter if bypass starter is specified and the wiring is not installed at factory. Install wiring in metal conduit and in accordance with Electrical sections of Division 26 and applicable Electrical Code.
- C. Provide control wiring between interlocks in VFD control circuits and driven motor's disconnect switches. Interlock VFD control circuits with driven motor's disconnect switches where such motor disconnect switches are provided. Disconnecting on-line motor shall shut down VFD. VFD shall restart upon reconnection of motor.
- D. Do not connect ground from one unit to another unit's cabinet.
- E. Use separate conduits for incoming and outgoing power conductors from each unit.
- F. Use separate conduit for control wiring for each unit. Do not combine control wiring with power wiring.

UNC - Chapel Hill

CHW Infrastructure Expansion – BCP
Prepurchased Equipment – Cooling Towers

07/22/25

Process Variable Frequency Drive (VFD)
System

23 0514 - 11

- G. Use minimum 18 ga shielded wiring with ground for control wiring.
- H. Install floor mounted drives on concrete housekeeping pad and minimum 3/4" thick 50 durometer, neoprene rubber isolation pad. Install wall-mounted drives on metal framing in accordance with Section 26 0529.

4.4 START UP

- A. Assist manufacturer with start-up of VFD in accordance with procedures as defined by manufacturer for proper operation.
- B. Adjust critical frequency avoidance feature to step over frequencies which cause excessive vibration in driven equipment.
- C. Adjust passive harmonic filter capacitor contactor setpoint to ensure drives do not present leading power factor to electrical systems during low-load conditions.
- D. Contractor shall schedule and expedite the manufacturers start-up process and support the Owners commissioning activities. Contractor shall coordinate exact timing of these activities and arrange for appropriate manufacturer personnel to be on-site.
- E. After successful completion of equipment installation, the Contractor shall assemble and incorporate equipment shop drawings, operating/maintenance instructions, and part lists into the Contractor's project operation/maintenance manuals.

END OF SECTION

**SECTION 23 6510
COOLING TOWERS**

PART 1 – GENERAL

1.1 OWNER PRE-PURCHASED EQUIPMENT

- A. This equipment will be prepurchased by the Owner and furnished to the successful Contractor after award for expediting delivery, erection by the manufacturer, and installation or construction of the stainless steel basin, connecting piping, power and other appurtenances as if the Contractor purchased the equipment directly.
- B. Owner will make available manufacturer provided shop drawings of Owner prepurchased equipment for review by the Contractor. Contractor shall review shop drawings to ascertain that Contractor has included necessary labor and materials to install equipment and complete system it serves.
- C. Contractor shall be responsible for arranging/coordinating delivery of Owner prepurchased equipment and all other related logistics and activities. This includes directing the delivery trucks to the jobsite, coordinating the date and time of deliveries with other ongoing activities and allocating available laydown space at the jobsite.
- D. Due to the limited space on the jobsite, materials will be required to be delivered on an as needed basis. Manufacturer is responsible for unloading of the equipment and related materials at the jobsite.
- E. Once the stainless steel basin is constructed and the cooling tower is erected by the Manufacturer on the dunnage steel, that is constructed by the Contractor, the Contractor shall complete the installation process by connecting the cooling towers to the related utility systems. This shall include, but not be limited to; making piping, power, and controls connections, and supporting the start-up, testing, and commissioning of the cooling towers in accordance with manufacturer's recommendations, and maintaining equipment until such time as project is accepted by Owner. Perform all work and provide materials and connections for Owner furnished equipment in accordance with drawings and scope of work under all related specifications.
- F. The following summarizes the general responsibilities of the equipment manufacturer:
 - 1. Provide shop drawings and submittal data.
 - 2. Procurement, manufacture and delivery of equipment and related cooling tower materials including coordination of exact delivery dates, rigging, unloading, and erection of the cooling towers.
 - 3. Lead equipment check-out, start-up, and testing process and submit report(s).
 - 4. Provide O&M documentation.
 - 5. Provide Owner training and participate in commissioning process.

1.2 SCHEDULE

A. Schedule:

1. The following schedule is anticipated relative to this prepurchased equipment delivery, installation and activation. This is a preliminary schedule and exact dates are to be coordinated with the Owner and Contractor.
 - a. Tower Materials Delivery and Erection: March 2027 – July 2027
 - b. Installation Work By Contractor: July 2027 – November 2027
 - c. Start-Up & Commissioning: November 2027– March 2028
 - d. Vibration and Acoustical Testing ... December 2027
 - e. Thermal Performance Testing July 2028

1.3 DESCRIPTION

- A. The project shall include a five-cell, field erected, cooling tower. Tower cells shall be constructed complete by the manufacturer, including stainless steel basin on top of dunnage steel provided on top of the Bernard Chiller Plant (BCP). Tower shall be provided with access and service provisions as specified herein.
- B. The layout on the drawings is based on an induced-draft, counterflow, fiberglass cooling tower. Any variances in capacities, configuration, and operating characteristics than those shown and specified shall be indicated at time of bidding. Bid shall include any additional materials and/or work required to make equipment and installation complete, such as modification to proposed basin, additional structure, piping and electrical upgrades.
- C. The tower cells shall be field erected over a steel dunnage structure on the roof of the BPC. The tower manufacturer shall carefully review the cooling tower support structure design. Tower Manufacturer shall coordinate required modifications with the Contractor or provide any miscellaneous steel or fiberglass penetrations and connections required to connect and anchor the tower to the support structure. All support structure materials shall match those specified for the structure.
- D. Cooling tower connection / transition points to the Contractors mechanical piping systems shall be coordinated to avoid field offset piping.

1.4 DEFINITIONS

- A. Cooling Tower Manufacturer - Manufacturer of the cooling tower who is responsible for a complete turn-key cooling tower installation as specified herein.
- B. Installing Contractor - Contractor who is responsible for the overall coordination of the project and completion of the project scope, including final piping, electrical and controls connections to the cooling tower.

1.5 BID SUBMITTALS

- A. The following shall be provided with the equipment bid proposal:
 1. Completed Life Cycle Cost Analysis, Acoustical Performance, and Bid Cost forms included in Part 5 of this section shall be submitted with other bid documentation to allow for evaluation and analysis by the Designer and selection of the best overall value by the Owner.

2. Cover letter with compliance table listing each specification section and indicating compliance "C", deviation for alternate "D", or exception with explanation "E". Any deviation or exception shall be accompanied with detailed explanation of how design intent is being upheld for evaluation by the Owner and Designer.
- B. Product data including:
1. CTI data sheet.
 2. Dimensioned general arrangement drawings.
 3. List of manufactures and cut sheets for major components – structure, casing, fill, drift eliminators, water distribution, sound attenuators, fan stacks, fans, motor, and VFD.
 4. Dead and wind loading at each column support.
- C. References: a complete list of references shall be provided with each Proposal. The list shall include a minimum of five (5) references where equipment of similar manufacturer type and capacity has been installed. The list shall indicate the name of the facility where the equipment has been installed, location (city and state) of the equipment, installation date, equipment capacity, contact name and contact telephone number of each reference.
- D. Scheduled Maintenance Requirements: A complete list of the recommended scheduled maintenance requirements for the equipment shall be provided with each Proposal. The list shall identify each recommended service item and its recommended frequency (monthly, quarterly, etc.). The list shall, at a minimum, include the scheduled maintenance items identified.
- E. Other information to verify compliance with the Request for Bids.
- F. Award will be based on specification compliance and best overall value for the Owner.

1.6 FABRICATION SUBMITTALS

- A. Shop drawings for all items in this Section including, but not limited to, the following:
1. Manufacturer's name and model number.
 2. Identification as referenced in the documents.
 3. Performance data including certified letter of guarantee from Cooling Tower Manufacturer that the cooling tower being provided for the project will meet or exceed the specified performance criteria at design conditions.
 4. Sound ratings for fan and composite cooling tower.
 5. Materials of construction.
 6. Dimensions and weights.
 7. Wiring and interlocking diagrams.
 8. Motor data.
 9. Complete a CTI data sheet for each cooling tower and submit with shop drawings. Shop drawings will be returned without review if data sheets are not provided and if data sheet is not filled out completely.
 10. Cooling tower performance of characteristic curves.

11. Cooling tower nozzle coverage curves.
12. Cooling tower water distribution system layout.
13. Fan performance curves and construction details.
14. Piping layouts, connection and support details.
15. Design loads and calculations for supporting structure including dead load and wind loading at each support column sealed by a professional engineer licensed in the State of North Carolina.
16. Construction and fabrication drawings.
17. Samples of wall panel materials.
18. Complete description of proposed maintenance training program.
19. FM Approval Certification Documents

1.7 OPERATION AND MAINTENANCE DATA

- A. Prior to start-up of the equipment and related Owner Training, submit operations and maintenance manual in accordance with the following.
- B. Manual shall include:
 1. Manufacturer's name, model number, service manual, spare parts list, and descriptive literature.
 2. Names, addresses and contact information for equipment local service representative(s).
 3. Copies of final approved Shop Drawings and Product Data Submittals.
 4. Instructions for starting and operating the equipment provided.
 5. Complete maintenance instructions including preventive maintenance instructions and schedules for equipment.
 6. Detailed one-line, color-coded wiring diagrams.
 7. Inspection procedures.
 8. List of most frequently encountered repairs and trouble-shooting manual(s).
 9. Copies of warranties.
- C. Manual submission process:
 1. Submit a bookmarked digital draft file (.pdf) of the O&M Manual to the Designer for review and comment.
 2. Upon acceptance by the Designer submit the final digital file (.pdf) of the O&M Manual along with two (2) hard copies bound in heavy duty 3-ring binders with table of contents and appropriate dividers to the Owner for use/reference during Owner Training sessions.

1.8 SPARE PARTS

- A. Furnish one complete set of replacement nozzles for one cooling tower cell to the Owner.
- B. Cooling tower fan VFD spare parts as specified in Section 23 0514.

- C. At the conclusion training provide a list of additional recommended spare parts for purchase by the Owner.

1.9 WARRANTY

- A. The Cooling Tower Manufacturer shall guarantee the complete cooling tower, including the permanent magnet rotor (PMR) motors, will be free from defects in workmanship and materials for a period of five (5) years from the date of project final acceptance. Should any such defects be found and reported during this warranty period, the Manufacturer shall correct such defects by furnishing replacement parts FOB shipping point and all required labor, equipment and materials required to correct the defect.
- B. All written warranty claims by the Owner shall be responded to by the manufacturer within 24 hours including a site visit and diagnosis. Prior to leaving the site, a repair schedule shall be mutually established between the Owner and the manufacturer. If the manufacturer fails to meet the repair schedule, the Owner reserves the right to make the necessary repairs. The cost for the Owner to make the repairs shall be invoiced to the manufacturer by the Owner. Through submittal of a bid on this project, the manufacturer is obligated to reimburse the Owner for such repairs (Net 30 days).

PART 2 - PRODUCTS

2.1 COOLING TOWER (FIELD-ERECTED, INDUCED-DRAFT, COUNTERFLOW TYPE)

- A. Acceptable Manufacturers:
 - 1. Composite Cooling Solutions (CCS)
 - 2. EvapTech, Inc. (EvapTech)
 - 3. Marley/SPX Cooling Technologies (SPX)
- B. General
 - 1. Provide field erected induced draft, vertical discharge, fiberglass structure, double-sided air inlet, counterflow type cooling tower as shown.
 - 2. Work shall include, but is not limited to, providing design services, field erection labor, field supervision, materials, equipment and ancillaries to design, fabricate, deliver, erect, start-up, and test the cooling tower as specified herein. Tower manufacturer shall correct all deficiencies at no additional cost to the Owner. Tower shall be field erected by factory trained representatives of the manufacturer.
 - 3. Tower shall be complete and shall include, but not be limited to, stainless steel basin, basin heater system, frame structure, casings, and partitions, fill material and fill support system, circulating water distribution system, drift eliminators, motors, fan stacks, air inlet sound attenuators, vibration switches, supports, hardware, bolts, nuts, connectors, anchor bolts, etc.
 - 4. Manufacturer shall be responsible for just-in-time delivery, unloading and storage of materials and equipment at jobsite. There is limited laydown space available at the site and all materials must be stored off-site and brought to the site on a just-in-time basis. The location of space for laydown of tower materials shall be coordinated with all trades. Provide laydown plan to Contractor for review and approval.

5. Cooling towers shall be Factory Mutual (FM) approved as noncombustible in the arrangement shown on the drawings with adjacent cells directly connected to each other. Cooling tower design shall comply with FM Global Standard for Cooling Towers Class Number 4930 for Multi-cell towers. Cooling tower design shall comply with FM 4930 for fire, materials and testing requirements. Wind design shall be in accordance with FM Global data sheet 1-28.
6. Tower to be fiberglass-reinforced polyester (FRP) or vinyl resins with PVC fill, with capacity and operating characteristics as specified herein. All fiberglass shall be impregnated with fire retardant and self-extinguishing additives.
7. All components, including fill material, shall possess flame spread rating of not over 25, without evidence of continued progressive combustion, and smoke developed rating no higher than 50 in accordance with NFPA 90A.
8. No plain steel or galvanized steel components will be allowed in the tower.

C. Basin

1. Tower shall be provided with and erected in a 1/4" thick, 36" deep stainless steel collection basin. The collection basin is to be provided by the Tower Manufacturer and shall be configured in five (5) compartments to separate the towers. Each tower cell shall have its own basin or basin divider walls so that the basin section can be isolated and drained for maintenance while adjacent tower cells remain operational/wet. Basin plates shall be butt-welded and shall be provided with interior stiffeners/gusset plates as necessary to allow for basin to be completely filled with water. Lap welds will not be allowed. Top perimeter edges of basin shall be stiffened with double 90 degree bends for additional rigidity. Basin side walls shall not deflect more than 1/8" when filled with water.
2. Basin compartments shall be interconnected by an equalizer pipe installed by the Contractor, but Cooling Tower Manufacturer shall provide piping connection in each basin consisting of NPS Schedule 10 Type 304 stainless steel pipe and external 36" diameter ANSI Class 150 weld-neck flange. The flange shall be provided at a location and elevation coordinated with the Contractor. Provide FRP handrail between the adjacent tower columns to surround the equalizer line floor penetration to protect/barricade the opening.
3. Each basin shall have a 4'-0" x 4'-0" square outlet box/sump that extends 7'-0" deep from the bottom of the basin, constructed of welded 1/4" thick stainless steel, and located in coordination with the Contractor and structural support dunnage. An external 24" diameter ANSI Class 150 weld-neck flange connection for outlet piping shall be supplied by Cooling Tower Manufacturer on side of outlet box. An external 4" diameter ANSI Class 150 weld-neck flange connection for drain piping shall be supplied by Cooling Tower Manufacturer on side of outlet box as low as possible. Stainless steel anti-vortex 1/4" thick plates and cover screen shall be provided for each outlet box/sump.

4. Provide an internal vertical overflow pipe assembly in each new basin compartment. The basin overflow pipe shall be 8" NPS Schedule 10 Type 304 stainless steel pipe, top of pipe 34" above bottom of basin (2" below top of basin wall), welded and watertight where penetrating the basin floor, and extending below the bottom of the basin terminating with a ANSI Class 150 weld-neck flange. The flange shall be provided at a location and elevation coordinated with the Contractor. A stainless-steel water protection hood (doghouse) shall be provided above the overflow pipe inlet to prevent circulating water from entering the open end of the pipe. The bottom of the hood shall be minimum 6" above the top of the overflow pipe.
5. Provide three condenser water header vent pipes in locations shown on drawings. The vent pipes shall be 6" NPS Schedule 10 Type 304 stainless steel pipe with goose neck terminating with outlet 38" above bottom of basin (2" above top of basin wall), welded and watertight where penetrating the basin floor, and extending below the bottom of the basin terminating with a ANSI Class 150 weld-neck flange. The flange shall be provided at a location and elevation coordinated with the Contractor.
6. Provide an internal vertical potable water and reclaimed water makeup line in each new basin compartment. The makeup water pipes shall be 4" NPS Schedule 10 Type 304 stainless steel pipe with goose neck terminating with outlet 38 inches above bottom of basin (2" above top of basin wall), welded and watertight where penetrating the basin floor, and extending below the bottom of the basin terminating with a ANSI Class 150 weld-neck flange. The flange shall be provided at a location and elevation coordinated with the Contractor.
7. Passivation of all welded areas on stainless steel material surfaces is required to restore chromium oxide layer.

D. Performance - BCP:

1. The minimum performance for each cooling tower cell shall be as follows:
 - a. Maximum Flow Rate (flow across one cell) 7,500 gpm
 - b. Minimum Flow Rate (flow across one cell) 3,750 gpm
 - c. Entering Water Temperature 95°F EWT
 - d. Leaving Water Temperature 85°F LWT
 - e. Ambient Wet Bulb 80°F
 - f. Maximum Fan HP 200 HP
 - g. Maximum Size per Cell 36'-0" L x 30'-0" W
 - h. Cooling Tower Basin Depth 3'-0" Min.
 - i. Maximum Fan deck height from top of Basin 28'-0"
 - j. Maximum Air Inlet Height from top of Basin 13'-6"
 - k. Maximum Fan Stack Height 10'-0"
 - l. Number of Air Inlets 2 air inlets
 - m. Air Inlet Sound Attenuators
 - 1) Base Bid None – Cellular Louvers
 - 2) Alternate Bid No. 1 South Inlets Only
 - 3) Alternate Bid No. 2 South and North Inlets

2. The full build-out arrangement of the cooling towers shall be a linear arrangement of five cooling tower cells.
3. Drift Loss, other than Evaporation, Maximum Guaranteed Percent of total water flow shall not exceed 0.0005%.
4. Tower performance shall be based on a wind velocity of 0-10 mph.
5. Design and construction of cooling tower cells shall accommodate site conditions which includes being located in the roof of the plant and surrounded by partial height screen wall.
6. The tower cell dimensions shall not exceed the dimensions listed above.
7. All cooling tower materials and methods of construction shall be rated or de-rated as necessary to accommodate a normal over-the-tower water temperature and normal chemical treatment exposure.
8. Tower design wind loading shall be per CTI recommendation or 2018 North Carolina State Building Code, whichever is greater.
9. Tower seismic design shall be in accordance with 2018 North Carolina State Building Code.
10. Fan deck live load (at 100°F) shall be 60 PSF plus the concentrated load of the motor over the entire fan deck area.
11. Maximum pumping head, from the inlet flange connection, including all distribution system pressure drops and nozzle pressure drop shall not exceed the maximum pressure drop in feet of water at the design flow rate scheduled on the drawings.
12. The tower structure and components shall be designed to operate in freezing conditions.
13. The air inlets and fans shall be sized to accommodate the installation of the specified air inlet sound attenuators (Alternate Bid) with this project construction or in the future.

E. Structure:

1. Structural Analysis: Manufacturer shall provide detailed structural calculations for all connections, signed and sealed by a professional engineer registered in the state of North Carolina. Manufacturer shall prove with test data that the connections and design meet the strength characteristics to provide minimum specified service factors as required.
2. Furnish the dead and wind loading at each column support as part of the bid and fabrication submittal data.
3. Unless required otherwise by the Manufacturer, the following minimum service factors shall be used in all structural designs:
 - a. Dead Loads
 - 1) Bearing Service Factor: 4.0
 - 2) Shear Service Factor: 3.0 minimum
 - 3) Bending/Flexural Service Factor: 2.5 minimum
 - 4) Deflection Limits: L/D ratio of 180.
 - b. Live Loads
 - 1) Bearing Service Factor: 2.5 when applied to a fastener group
 - 2) Shear Service Factor: 2.0 minimum.

- 3) Bending/Flexural Service Factor: 2.0 minimum
- 4) Deflection Limits: L/D ratio of 180.
4. The minimum service factor for dead loads that shall be allowed for a connection is 4.0. The service factor for connections with temporary loads due to wind, seismic, etc. may be reduced to 2.5. Provide mechanically bolted joints using type 304 stainless steel materials.
5. When connecting hollow type structural members by the use of bolted joint, the service factor for bearing dead loads must be 4.0 minimum and 2.5 minimum for live and dead loads.
6. On bolted joints, stainless washers are required.
7. The field erected FRP composite cooling tower structure shall meet all applicable building codes.
8. Maximum Water Absorption (24-hour immersion) per ASTM D-570 shall be in accordance with CTI STD-137.
9. Tower casing, fan stack, fan deck, beams, lintels, seismic bracing, columns, supports and partition walls shall be constructed of corrosion resistant, fire-retardant, self-extinguishing, manufacturers standard color (selected by Designer) fiberglass reinforced polyester or vinyl resin and contain an ultraviolet ray inhibitor as per CTI Standard-137.
10. The cooling tower FRP structure walls, roof deck, support beams and columns shall be fabricated from composite continuous fiberglass pultruded sections specifically designed for cooling tower application.
 - a. The exterior wall sections for double wall construction units and shall weigh not less than 32 ounces per square foot.
 - b. The exterior wall section for single wall construction units shall weigh not less than 14 ounces per square foot.
11. The exterior casing panels shall be extended up from the basin to the height of the fan deck. All end walls and partition walls shall be extended down to the top of the basin walls or column support piers to eliminate the airflow and water flow between cells. The area between the perimeter sidewalls and the basin shall be covered with FRP casing or stainless steel flashing material equal to that used on the tower. Pitch the material to the tower wall with a 1/8" per 1'-0" slope.
12. The tower structure and exterior casing panels shall be extended up from the fan deck to match the top of the fan stack and be trimmed out to match the tower casing in finish and color. Provide access openings in this casing extension as required for fan deck access as specified herein.
13. Seal all joints in the outer casing and interior partition walls to be watertight at the time of erection. Any leakage shall be repaired by the manufacturer.
14. Provide wind walls, deflector plates and baffles in interior of cooling tower to eliminate water spill out and mist carryover.
15. Pultruded FRP box beams and wide flange I-beams shall be used for fan deck support.

16. All of the exterior and interior surfaces of the fiberglass structural members and components shall be protected from Ultraviolet (UV) rays as well as water migration by gel coat or polyester surfacing veils molded internally into the composite part. On pultruded members the UV protectors and color pigments shall be formulated in the resin matrix.
17. Each tower shall be supported by a limited number of support columns. Where cells are adjacently located, the towers shall share columns for structural support. Refer to the drawings for the general tower/cell basin layout.
18. All support columns shall rest on basin floor and be anchored to the tower dunnage support structure.
19. Provisions shall be made on the exterior and interior of the tower structure to accommodate supporting / bracing piping risers and conduits that serve the tower with power, lighting, lightning protection, and controls. Manufacturer to coordinate exact connection requirements and details with the Contractor.
20. A minimum 2'-6" access aisle is required around the fan deck. If required due to fan stack dimension, provide cantilevered catwalk around perimeter of cooling tower to provide required access aisle.

F. Fill Support System

1. Structural Analysis: The vendor shall provide detailed structural calculations for all connections, signed and sealed by a professional engineer registered in the state of North Carolina. The vendor shall prove with test data that the connections and design meet the strength characteristics to provide minimum specified service factors as required.
2. The fill pack shall be bottom supported by pultruded FRP support lintels or heavy duty type 304 stainless steel lintels. Lintels shall be designed to support the fill and include a design safety factor of 3.0.
3. Structural Performance: Supports shall withstand the effects of gravity loads and the following loads and stresses within limits and under conditions indicated according to SEI/ASCE 7.
 - a. Fill Support Dead Load: Dry weight of fill material plus water hold up weight plus 15% additional allowance for fill clogging.
 - b. Fill support Live Loads: 300 lbs. of concentrated load for temporary maintenance foot traffic.
 - c. Fill supports shall be capable of supporting all loads expected when the tower is operating, including ice loading.

G. Fill

1. The fill shall be wave-formed sheets, cross-corrugated film type, high grade polyvinyl chloride (PVC), conforming to ASTM D-1784, type 1, grade 1 with a flame spread rating of 25 or less per ASTM E-84.
2. The fill material shall be of minimum 15 mil thickness after forming and shall be adequately supported to provide the necessary rigidity to be free from sagging and channeling of water.
3. The design of the fill system shall be such to provide freedom to expand and contract without over stressing.

4. The fill material must be easily replaceable. The fill material shall be suitable for continuous water temperatures to 120°F.
5. Each successive layer of fill packs should be installed at right angles to the lower layer to ensure proper water dispersal.
6. The fill PVC material shall have additives to prevent damage to the fill from ultraviolet radiation.

H. Drift Eliminator Support System

1. Structural Analysis: The vendor shall provide detailed structural calculations for all connections, signed and sealed by a professional engineer registered in the state of North Carolina. The vendor shall prove with test data that the connections and design meet the strength characteristics to provide minimum specified service factors as required.
2. The drift eliminators shall be supported by a separate support system connected to the tower structure and shall not be supported by the distribution piping or from the fill pack.
3. The drift eliminators shall be bottom supported by pultruded FRP support lintels or heavy duty type 304 stainless steel lintels. Lintels shall be designed to support the fill and include a design safety factor of 3.0.
4. Structural Performance: Supports shall withstand the effects of gravity loads and the following loads and stresses within limits and under conditions indicated according to SEI/ASCE 7.
 - a. Fill Support Dead Load: Dry weight of fill material plus water hold up weight plus 15% additional allowance for fill clogging.
 - b. Fill supports shall be capable of supporting all loads expected when the tower is operating.

I. Drift Eliminators:

1. Drift Eliminators shall be designed and arranged to limit the drift loss to a guaranteed performance value of 0.0005% of circulating water flow.
2. The drift eliminators shall be constructed of PVC with similar physical properties to those of the cooling tower fill material, but have additional ultraviolet light inhibitor. The drift eliminators shall be a proven design.
3. The drift eliminators shall be designed to allow trapped water to drain into the fill area.
4. The drift eliminators shall be designed so they nest or interlock with the module next to them, eliminating interfaces between modules, conforming to ASTM D-1784, Type 1, Grade 1, with a flame spread rating of 15 or less per ASTM E-84.
5. Drift eliminators shall utilize 0.020" stiffener sheets after forming.
6. The eliminators shall be installed with air seals around the tower structure to properly direct the flow of air through the panels and to prevent edge wear due to handling of eliminators.

J. Inlet Louvers (Base Bid)

1. Provide air inlet louvers constructed of cellular PVC with similar physical properties to those of the cooling drift eliminator material including additional ultraviolet light inhibitor.

2. Louvers shall be supported in removable FRP frames to accommodate the alternate installation of inlet sound attenuators.
3. Louvers shall conform to ASTM D-1784, Type 1, Grade 1, with a flame spread rating of 15 or less per ASTM E-84.
4. Louvers sections shall utilize 0.020” stiffener sheets.

K. Inlet Sound Attenuators (Alternate Bids No. 1 and 2)

1. Manufacturers: Aeroacoustic, Aerosonics, Commercial Acoustics, Industrial Acoustics Company, Price Industries, Rink Corporation, Semco, United McGill, Vibro-Acoustics, VAW Systems or. Basis of Design: Price Industries, Rectangular Silencer Packless, 36 inches long.
 - a. Submit independently certified test data on dynamic insertion loss, self-noise power levels, and aerodynamic performance.
 - b. Outer casing of units shall be not less than 22 ga 304 stainless steel in accordance with recommendations in the latest edition of ASHRAE Guide and Data Book for high pressure rectangular ductwork for 4" WG pressure class. Seams shall be lock formed or continuously welded and mastic filled. Units shall be packless and lined with not less than 26 gauge perforated 304 stainless steel.
 - c. Ends of attenuators shall be covered at factory with plastic to prevent entrance of dirt, water, or any other foreign matter to inside of attenuators. Caps shall not be removed until attenuator is installed.
 - d. Unless otherwise indicated, sound attenuating devices shall be 36 inches long and shall meet acoustical performance requirements as follows for each octave band frequency at -1000 silencer face velocity flow conditions.

Octave Band	63	125	250	500	1000	2000	4000	8000
DIL (dB)	8	8	13	19	14	12	11	10

L. Hardware:

1. All bolts, anchor bolts, nuts, washers, hangers, connectors and other similar hardware shall be stainless steel. All bolts shall be full body design in accordance with CTI Standard STD-119.
2. Self-tapping screws are prohibited for structural connections.
3. Cooling tower manufacturer to provide a detailed drawing of the basin anchor bolt locations and furnish/install the anchor bolts at the time of the cooling tower installation. Holes for anchor bolts shall be drilled, and bolts installed, tightened, and sealed in place by Manufacturer.

M. Water Distribution System:

1. Distribution system for each cell shall have an external Class 150 ANSI flange connection complete with header, side laterals, fittings, and nozzles supplied by tower manufacturer. The face of the flange shall be located 12" beyond the exterior face of the tower casing. All distribution system piping shall be either PVC or fiberglass. Fittings and nozzles shall be FRP, PVC, or polypropylene. Connection flange shall be located as indicated on drawings and shall be on the side of the tower. No internal center risers will be allowed.
2. Side laterals shall connect to header with a flange, PVC welded or clamp-on saddle. All saddle hardware shall be stainless steel and saddle gaskets shall be EPDM.
3. The distribution system for each cell shall be capable of uniformly distributing the supply water over the entire cross-sectional area of the tower fill material at +10% to -50% of design flow conditions.
4. The distribution system shall be arranged to allow complete automatic drainage of distribution piping when the tower is shutdown.
5. The distribution system shall be designed to prevent clogging of distribution nozzles with silt or other debris. A clean-out provision shall be located at the terminal end of each lateral and each header to provide a convenient means of inspection and removing silt accumulations.
6. The nozzles shall be large orifice design, to prevent clogging. Each nozzle shall be easily removable without the use of special tools for cleaning and replacement. Up spray nozzles shall not be allowed.
7. Nozzles shall connect to side laterals with a clamp-on saddle with stainless steel nozzle thread reinforcing. All saddle hardware shall be stainless steel and saddle gaskets shall be EPDM.
8. Provide a pressure vs. nozzle flow curve with the shop drawing submittal.
9. The distribution piping system shall be supported from the tower structure (beams or columns) with stainless steel hangers and supports and attachments. The use of bent rods, plastic zip ties and other strapping materials for hangers and supports shall not be allowed.

N. Fan Stacks:

1. Fan stacks (cylinders) shall be constructed of manufacturers standard color (selected by Designer) fiberglass reinforced polyester with stiffening ribs and shall be of the same quality resin and glass as specified for the tower structure. The fan stacks shall be venturi shaped. Interior and exterior surfaces shall be protected from ultraviolet radiation and water migration.
2. Provide sealant between fan stack sections and fan deck to eliminate bypass airflow.
3. Provide a removable hatch (minimum size 3'-0" x 6'-0") in each fan. Hatch shall be gasketed and provided with a series of 90 degree turn handle latches or similar permanent devices for securing hatch in place during operation.
4. Provide one heavy duty clear plastic observation port in the fan stack to allow for visual inspection of the fan assembly while in operation. Port shall be a minimum of 4 inches in diameter.
5. Provide EPDM grommets to seal all penetrations (conduits, piping, etc.) of fan stack.

O. Fan Assemblies

1. Fans shall be ultra low noise type.
2. Each fan blade shall be of adjustable pitch individually clamped in a common hub. The entire fan assembly shall be statically and dynamically balanced and tested in the field.
3. The fan blades shall be fabricated from a one-piece fiberglass-reinforced system with a protective stainless steel leading edge.
4. Hubs, coupling flanges, and associated bolts shall be 304 stainless steel and shall be furnished with hub covers.
5. The complete fan assembly (fan and mounting) shall be designed to give maximum fan efficiency and long life when handling saturated air at high velocities.
6. Provide the required blade pitch installation data at the time of start-up and adjust as required during commissioning and thermal, vibration and acoustical testing to achieve design performance.
7. Fan blades shall be interchangeable with no balancing required. Weights are not allowed on fan blades for balancing purposes.

P. Vibration Safety Switch

1. Two outdoor rated 24VDC (SPDT) safety switches with reset shall be supplied for each motor. The switches shall be mounted, accessible from the service platform inside the cooling tower fan stack. Install one switch on two adjacent sides of the fan motor. Any excessive vibration of motor and assembly shall automatically cut off the driver. Switches shall be supplied with a manual reset on face of switch. Each switch shall be installed by cooling tower manufacturer and wired by the Contractor with one contact to the tower VFD and the second contact to the plant control system. Basis of design: Metrix Model M5550-111-020.

Q. Electric Motors and Variable Frequency Drives:

1. Manufacturer shall furnish the electric motors and companion VFDs for each cooling tower fan. Manufacturer will install the fan motors on the tower and deliver the VFDs to the Contractor for installation. Contractor shall set VFDs and provide all power and control wiring required for operation of the cooling tower motor and VFD as coordinated with the Manufacturer.
2. Motors shall comply with NEMA MG 1 part 31 standards for definite-purpose inverter-fed motors and shall be 3 phase, 460V construction. The motor shall utilize low profile finned laminate frame construction for direct, vertical shaft up mounting to the cooling tower fan assembly. The opposite motor end shall be flange bolted to a stainless steel base plate which is through-bolted securely to the cooling tower structure.

3. Cooling tower motors shall have two internal thermostats in the stator windings with normally closed contacts. One contact shall open if temperature rises above (overtemperature) setpoint and the other shall open when below (low temperature) setpoint determined by motor manufacturer. This shall be via digital input arranged to coordinate with normally closed contacts for motor thermostats. Outdoor motors shall also be provided with 120V heating elements to eliminate moisture in motor when fan is not being operated during and low temperature conditions. Thermostats shall be monitored and heaters activated by associated VFD controller. Heater power shall be provided and extended separately through the VFD.
4. VFDs for direct-drive fan motors shall be furnished by cooling tower manufacturer and installed by the Contractor. Refer to Specification Section 23 0514 Process Variable Frequency Drive (VFD) System. VFD shall have capability to operate motor in forward or reverse rotation. VFD shall receive forward and reverse signal from the plant control system.
5. The cooling tower manufacturer shall furnish data on critical speeds to be locked out by the VFD system. The minimum fan speed shall be above the lock-out frequencies of the fan/VFD system.

R. Access Provisions:

1. The towers shall be furnished with the following access provisions for proper operation, inspection and maintenance. All access related provisions shall comply with OSHA requirements and shall be generally located as shown on the drawings unless approved otherwise by the Designer.
 - a. One stairway on exterior of the tower from extending from the dunnage catwalk level to fan deck level. Stairway to be constructed of manufacturer standard color (selected by Designer) FRP to match the cooling tower structure and be freestanding and anchored to the dunnage platform, but may be braced to the tower structure if required. Provide 7'-0" wide (min.) connector bridge from top stair landing area to fan deck. Provide stairs and connector bridge with 3'-6" tall handrails. Stair tower and bridge shall be enclosed with tower casing material from top of air inlets to top of the stair and bridge handrail and trimmed out to match the tower casing in finish and color. Stair tower structure shall be left exposed below the top of the building parapet to minimize impact on air flow to the tower. All stairs and landings shall be designed for a live load of 100 PSF plus other code required loads. Provide one 3'-0" x 7'-0" hinged, gasketed, and latched door with door handle and retainer chain in fan deck wall as shown on the drawings. Door and frame materials shall match those provided for the walls. Materials and hardware shall match those used for the cooling tower.
 - b. Provide two (2) fiberglass ladders with fall protection system including safety gates at fan deck level and intermediate offset standoff platforms with handrails above the air inlets. Provide two (2) additional ladders offset from the standoff platforms to the catwalk level. Ladders and platforms shall be painted to match the color selected for the cooling tower casing and structure.

- c. Provide a 3'-0" x 7'-0" hinged and latched door with door handle and retainer chain in exterior end walls (2) and partition walls of each cell (4). Door and frame materials shall match those provided for the walls. Provide flashing, deflectors and sealant around the doors to prevent water and air leakage. Doors shall be aligned to allow for a continuous internal 4'-0" wide non-slip FRP walkway with handrails to be provided end to end inside the cooling tower above the basin. Provide access ladders on both sides of walkway in each cell to provide access to the basin from the walkway. Materials and hardware shall match those used for the cooling tower. Ladders shall be anchored to the walkway structure and the basin as appropriate. Access walkway and associated doors and ladders shall be coordinated with and not be impeded by internal structural members, piping, basin openings, etc..
- d. One fiberglass access hatch (minimum size 2'-6"x2'-6") and ladder per cell shall be provided on the fan deck and at the drift eliminator levels of the tower complete with compatible frame and gasketed door to provide access to the tower interior below the fan deck and the drift eliminator level and to the fill and distribution system. Hatch in fan deck shall be hinged and hatch in drift eliminator level shall be a framed removable section of drift eliminators. All hatch door and ladder hardware shall be stainless steel. Hatch access location shall be coordinated with and not be impeded by internal distribution piping and electrical and controls conduits.
- e. Inside the fan stack perimeter provide a continuous fiberglass non-slip service platform at the fan deck elevation. Platform shall be supported from cooling tower structure with stainless steel hardware and shall not rest on the drift eliminators.

S. Basin Heater System:

- a. Provide a separate basin heater system for each tower cell complete with 460 volt, 3 phase, coupling mounted heater elements, thermostat, low water cut-out, GFI and overcurrent protection, thermal cutoff, wiring, contactors, relays, circuit breakers and integral disconnect in NEMA 4x control panel for single point of power connection by the Contractor. For multiple heater element systems the tower manufacturer shall be responsible for all wiring and conduit from the element(s) to the control panel.
- b. Elements shall be 80/20 nickel/chromium construction strung through cylindrical ceramic cores encased in a 304 stainless steel sheath. All voids shall be filled with magnesium oxide. Element outlet boxes shall be liquid-proof/explosion-resistant construction.
- c. Heater system capacity shall be sized to maintain cold water basin temperature at 40°F when the outside ambient temperature is 15°F with winds up to 15 mph.
- d. Basin heater system shall be third party listed. Third party agency shall be amongst those accredited by the North Carolina Building Code Council (NCBCC) to label electrical and mechanical equipment. <https://www.ncosfm.gov/codes/state-electrical-division/qualified-testing-laboratories>.

- T. Jib Crane:
 - 1. Provide 1/4 ton manual jib crane on the bridge connector deck between the stair tower and the fan deck of the cooling tower capable of lifting tools and equipment from the roof level, over the bridge handrail, to the bridge/fan deck level through a hatch in the dunnage level catwalk.
 - 2. Jib crane surfaces shall be 2-part epoxy coated. No bare steel is allowed.
 - 3. Locate jib crane as shown on the drawings.
- U. Acoustical Performance:
 - 1. Refer to requirements in Part 5 of this section.

PART 3 – EXECUTION – BY EQUIPMENT MANUFACTURER

3.1 COOLING TOWER INSTALLATION

- A. General:
 - 1. Manufacturer is completely responsible for field erecting the cooling tower including all assembly, rigging and performance testing as specified herein.
 - 2. Prior to the start of field erection, the Cooling Tower Manufacturer shall visit the site and verify the site is ready for tower installation.
 - 3. Manufacturer shall provide all tools, hoist, rigging equipment, and test instrumentation to make the tower operational.
 - 4. Manufacturer shall coordinate and cooperate with the Contractor related to the construction of the basin and access/use of the jobsite so as to not impede the Contractor's construction activities.
 - 5. Manufacturer shall coordinate requirements for taps in piping system required for measuring flow, temperature, pressure, etc. associated with thermal performance testing.
- B. Workmanship and Materials:
 - 1. All materials used in the tower shall be manufactured for the tower specified. The use of parts which contain bolt holes, cuts, etc. that are not specifically for the specified tower shall not be allowed.
 - 2. All equipment, materials, etc., required by these specifications shall be in compliance with the Federal Occupational Safety and Health Act.
- C. Erection:
 - 1. All materials specified herein and furnished by the manufacturer shall be erected in place by the manufacturer.
 - 2. Cooling tower fan VFDs shall be furnished to the Contractor to install.
 - 3. Manufacturer shall furnish a competent and experienced crew, and superintendent to supervise the work. Manufacturer's crew shall cooperate at all times with the Owner and Designer representatives and all other Contractors.
 - 4. Delivery, unloading and storage of materials and equipment, including any weather protection required, shall be done by the manufacturer.

5. Manufacturer shall provide scaffolding, all erection hoists, jacks, lifting lugs, tools, and equipment required for proper execution of the work. Remove all such temporary measures prior to completion of erection process.
6. Based on sound data submitted by the Manufacturer with their bid, air inlet sound attenuators may be required to be provided on the tower inlets to comply with local noise ordinances as specified herein. If required, attenuators shall be independently supported from the structural steel dunnage and shall be attached to the tower framing/casing to prohibit any bypass air and escaping sound. The air inlets and fans shall be sized to accommodate the installation of the specified air inlet sound attenuators (Alternate Bid) with this project construction or in the future. Manufacturer to coordinate exact elevations and details of the support structure with the Contractor as required.
7. Any stainless steel members that require welding shall be passivated to restore chromium oxide layer.

3.2 START UP

- A. Manufacturer shall provide for services of factory trained service engineer to supervise and approve installation and perform cooling tower start-up and testing prior to beginning of field testing.
 1. Provide information and assistance as required, during start-up.
 2. Cooperate and coordinate with Owner and Contractor.
 3. Provide all inspection, test, adjustment, and balancing services including but not limited to, inspection of all critical tolerances, proper fan/motor operation, VFD programming, and proper safety device operation.
 4. Start-up services shall be an addition to performance testing, training, and commissioning requirements.
 5. Submit inspection start-up and checklist log showing all initial settings and readings; signed by manufacturer's service representative.
- B. Manufacturer shall provide the Contractor and Designer twenty days written notice of the commencement of start-up procedures, a list of deficiencies and corrective steps, which need to be completed by others.
- C. Include appropriate Owner's personnel during start-up procedures. Demonstrate methods of starting up equipment and normal operating techniques. Coordinate start-up date with Owner and Designer. Provide a minimum notice of 10 days prior to anticipated start-up.
- D. Inspect, adjust, clean, service, calibrate and repair any and all elements of the cooling tower prior to start-up. Provide all tools, ladders, etc. as required in starting all equipment and clean-up of debris.
- E. Prior to acceptance by Owner, unit manufacturer shall approve, in writing, the complete installation, including piping and wiring connections, and proper functioning of all operational and safety controls.

3.3 FIELD PERFORMANCE TESTS

A. General:

1. Manufacturer shall acquire the services of independent third-party testing agency or agencies to conduct the performance tests specified herein. Qualifications for each testing agency shall be submitted prior to commencement of testing to the Owner/Designer for review and approval. Each testing agency shall have conducted similar testing on at least five cooling towers of similar construction in last five years.
2. All field performance tests shall be conducted in the presence of the Owner/Designer representatives. Manufacturer shall notify Owner/Designer of the desire to test a minimum of two weeks prior to any proposed date. Owner/Designer shall review and approve the desired date prior to commencement of testing. Approval to test may be withheld due to the operational status of the plant due to incomplete construction of required systems of controls, Owner maintenance, cold weather conditions which prohibit water flow over the tower, or availability of staff to witness test or operate equipment for testing. If unable to approve desired test date, Owner and Designer shall respond with an appropriate time frame as to when testing can be completed.
3. Within two weeks of completion of testing, the testing agency shall submit a complete bound report including all readings, a summary of findings and recommendations. Report shall be reviewed and approved by Owner/Designer and if found unacceptable, additional readings, adjustments, repairs, testing, and resubmission of the report may be required.
4. In the case of the tower failing to meet specified requirements, the manufacturer shall promptly make the necessary corrections. Such corrections, as may be required, and the expense of re-testing to verify improvements, shall be made at no cost to the Owner.
5. If larger size motors and VFD's are required the manufacturer shall also pay for all materials and installation of all electrical components to accommodate the increased size.

B. Vibration Testing:

1. Thermal performance tests shall be conducted to demonstrate the performance of each cell with design water flow and air flow.
2. Testing shall be completed utilizing a vibration analyzer which is NIST certified and calibrated.
3. The fan motor bearings vibration testing shall be in accordance with the CTI manual, Chapter 10. Additionally, other testing shall be performed on both the fan stack and the fan deck/structure as noted below. All readings shall be equal to or less than the values indicated below. Note that all values are "filtered" type, unless noted otherwise.

Location	Fan Speed	Motor Speed	Blade Pass Frequency	"Unfiltered" Value
Fan Motor Bearings	0.07in/sec.	0.15 in/sec.	--	--
Fan Stack	--	--	2.0 in/sec.	--
Structure/Deck	--	--	--	15 mils

- a. Fan bearing readings shall be taken in the horizontal, vertical and axial directions.
- b. Fan stack readings shall be taken in four locations, at 90 degree intervals, at the midpoint of the stack and shall be taken in the horizontal direction.
- c. Fan deck readings shall be taken in the vertical and axial directions, at a minimum of four (one per side) locations to be selected by the Owner/Designer.

C. Thermal Performance Test:

1. Thermal performance tests shall be conducted to demonstrate the performance of each cell.
2. The performance tests shall be conducted in accordance with the most current version of Cooling Tower Institute Test ATC-105 and associated tolerances. All instrumentation for testing shall be provided by the testing agency.
3. The field assembled cooling tower shall be field tested to confirm the ability to meet the 100% load condition. Note that the timing of this test is weather dependent to ensure that adequate load is available and to reduce the need to apply correction factors to the measure test data due to lower ambient air temperatures. Weather and load conditions are typically appropriate for the test between mid-June and mid-September. Based on the anticipated project schedule, it is expected that a separate site visit by the tower manufacturer to properly test the tower after the contract completion date. A sum of \$50,000 will be retained to cover the cost of these tests and potential tower enhancements. These funds will only be released upon successful completion of the tests and approval of the test reports by the Owner/Designer. At conclusion of the field test, guarantee to Owner that cooling tower meets the 100% load condition.

D. Acoustical Performance Test:

1. Acoustical performance tests shall be conducted to demonstrate the performance of the new cooling tower and verify compliance with the Town of Chapel Hill Noise Ordinance. The nearest property lines are residences at 1207 and 1307 Mason Farm Road, at distances of 890 and 950 feet, and are designated as receptor 4 and 5 in the following aerial image with blue thumbtacks.



- The following table below specifies the GPS and UTM coordinates for receptors 4 and 5.

Address:	1207 Mason Farm Road	1307 Mason Farm Road
Receptor ID:	4	5
GPS Latitude:	35.8989253°	35.898759°
GPS Longitudinal:	-79.0488493°	-79.0471105°
UTM Easting, Zone 17 S:	676087.00 m E	676245.00 m E
UTM Northing, Zone 17 S:	3974497.00 m N	3974481.00 m N

- Overall Sound Pressure Level Requirement: Not to exceed an overall A-weighted of 45 dBA when all five cells are operating at 100% design water flow and fan speed.
- Low frequency noise level requirement: In 1/3 octave frequency bands to have Unweighted 3rd octave band SPL to be less than or equal to values in table below.

One-Third Octave-Band Center Frequency, Hertz	One-Third Octave-Band SPL, dBL
	<u>Residential Nighttime</u>
16	78
20	70
25	62
31.5	55
40	52
50	51
63	50
80	49
100	48
125	47
160	46
200	45
250	44
315	42
400	40
500	38
630	36

5. Manufacturer will be required to provide 3rd party field testing using a Type 1 sound level meter calibrated within the last 12 months verifying conformance with the above ordinance limits (background noise corrections to measurement data is permitted as long as background noise is steady and at least 2 dB lower than the measurement level to be corrected in the particular band or overall level) at receptor these locations. Measurements should be made when background noise does not interfere with demonstrating compliance.

3.4 OWNER TRAINING

- A. The equipment manufacturer shall provide full operating, service and maintenance training programs for the Owner's maintenance personnel. All costs associated with Owner Training shall be included in the base proposal, including travel and per diem expenses. Training shall occur at the Owners facility.
- B. Instruction time periods shall be approved by the Owner and conducted during normal working hours of 8:00 AM to 3:00 PM Monday through Friday. Instruction shall be a combination of classroom instruction and hands-on training.
- C. The training course shall focus on equipment fundamentals and operation and shall include:
 1. Start-up, check-out and routine inspections and maintenance.
 2. Electrical and controls sequencing and trouble shooting.
 3. Nozzle removal and replacement.
 4. Motor servicing.

5. VFD operation and maintenance in accordance with Section 23 0514.
- D. The training course shall include a minimum of up to 16 hours of training time. The course shall be conducted at the University for up to ten (10) personnel.
- E. A complete syllabus and O&M Manuals shall be submitted and approved by Owner four weeks prior to training.
- F. At the end of each training course, the manufacturer shall provide to the Owner complete service manuals and bulletins that would be equal to the manuals that would be provided to the manufacturer's own service technicians. The manufacturer shall include the Owner on their update mailing list to make available for purchase by the Owner, all updates to the service manuals and new service bulletins that are issued after the completion of the training program.
- G. Owner may video tape training sessions for their use in future training of their operations and maintenance staff.

3.5 COMMISSIONING

- A. Upon construction completion, the chiller plant and associated equipment will be commissioned by the Owner. Manufacturer will be responsible for providing a factory trained technician on site for a minimum of 40 hours during this commissioning process. This time shall be in addition to any other start-up, training, etc. Scheduling of commissioning will be by the Owner.
- B. The field performance tests specified herein shall be completed after successful commissioning. The 40 hours above does not include the time for that testing and will require a separate trip.

PART 4 – EXECUTION – BY INSTALLING CONTRACTOR

- A. The Contractor will perform the following work associated with the new cooling towers:
 1. Provide basin and associated appurtenances shown on the drawings.
 2. Rigging and setting of VFDs furnished by the cooling tower supplier.
 3. Extend condenser water and other auxiliary water piping to the cooling towers.
 4. Piping connections to cooling towers shall not create stress on connection point. After final connections are completed, Contractor shall remove bolts from flanged connections at cooling towers. Piping shall remain aligned with cooling tower connections after bolts have been removed. If piping becomes misaligned after bolts have been removed, or if bolts cannot be removed by hand, Contractor shall revise piping to align piping with cooling tower connection. Piping/cooling tower alignment verification shall be completed in the presence of the Owner's representative. If after completion of the strain-free verification the piping system must be disassembled at any point in the system, the strain-free verification shall be repeated.
 5. Install control devices, raceway systems and/or wiring between the cooling towers and VFD's and the Owners control system.

6. Extend electrical service to the cooling towers including feeders to the VFD's, motors and associated auxiliary devices including but limited to convenience power, lighting, and lightning protection.
 7. Provide all taps in piping systems required for measuring flow, temperature, pressure, etc. associated with Manufacturers thermal performance testing.
- B. Secure any installation permits required by the State and local authorities and complete these requirements before system is placed in operation.
 - C. Contractor shall schedule and expedite the manufacturers start-up process and support the Owners commissioning activities. Contractor shall coordinate exact timing of these activities and arrange for appropriate manufacturer personnel to be on-site.
 - D. After successful completion of equipment installation, the Contractor shall assemble and incorporate equipment shop drawings, operating/maintenance instructions, and part lists into the Contractor's project operation/maintenance manuals.

PART 5 – PERFORMANCE

5.1 LIFE CYCLE COST ANALYSIS FORM

- A. Complete and submit the following tables **with Bid** submittal for the **Base Bid Tower** (with inlet louvers on north and south inlets).

Cooling tower selection data is as follows.

Cooling Tower Technical Requirements	Design Conditions - Per Cell
Nominal Capacity (Tons)	2,500
Flow (gpm)	7,500
Maximum Pressure Drop From Inlet Flange (ft)	25
Entering Water Temperature (deg F)	95
Leaving Water Temperature (deg F)	85
Outdoor Air Wet Bulb Temperature (deg F)	80
Fan Electrical (Max Hp/V/Ph/Hz)	200HP / 480V / 3Ph / 60Hz, VFD

Cooling load profile that will be utilized to evaluate the cooling tower(s) proposed by the manufacturers at bid time is as follows.

Expected Cooling Tower Utilization Profile - Per Cell				
Water Flow (GPM)	Fan Speed (%)	Hours Per Year	Entering Water Temp. (°F)	Outdoor Air Wet Bulb Temp. (°F)
7,500	100	500	95	80
7,500	100	2,000	85	70
7,500	75	1,500	75	60
3,750	50	1,000	65	50

Manufacturer shall input the operating data (kW and LWT) for the proposed cooling tower, in the following table.

Manufacturer Data – Proposed Cooling Tower Performance - Per Cell					
Water Flow (GPM)	Fan Speed (%)	Power Input (kW)	Entering Water Temp. (°F)	Leaving Water Temp. (°F)	Outdoor Air Wet Bulb Temp. (°F)
7,500	100		95		80
7,500	100		85		70
7,500	75		75		60
3,750	50		65		50

Life Cycle Calculation (To Be Completed by Designer) - Per Cell				
Manufacturer				
1st Year Op. Cost (\$)				
1st Year Op. Cost x 20 (\$)				
Total Bid Price (\$) / 5 Cells				
LCC (\$)				
Formula: LCC = Bid Price (\$) + 1st Year (\$) x 20 Years				
Electricity Cost Calculated Based on \$0.08 / kWh				

5.2 ACOUSTICAL PERFORMANCE FORM

- A. Complete and submit the following tables **with Bid** submittal.
- B. Base Bid: With cellular louvers on north and south inlets.
1. Single tower cell, air inlet sound power levels (SWL) including water and fan noise with cellular louvers installed on north and south air inlets.

Input air inlet sound power level (SWL) for one cell operating at full design capacity in the following table. The cooling tower shall be designed to limit noise generation through lower fan tip speeds, specified ultra low sound fans and fan deck barrier wall, oversizing, and other techniques other than the use of fan inlet or outlet sound attenuators. Water fall area or cold water basin treatments will also not be allowed.

Octave Band SWL @ 50 feet (dBL)					(dBA)
Frequency	63	125	250	500	OA SWL
Sound Pressure Levels Input from Manufacturer					

- a. Octave band SWL are un-weighted (dBL), overall SWL is A-weighted (dBA).
- b. Manufacturer shall indicate/input expected noise levels (from measurements or calculations) in table above and provide supporting documentation (such as calculation sheets or measurement reports).

2. Single tower cell, fan outlet sound power levels (SWL) including water and fan noise with cellular louvers installed on north and south air inlets.

Input fan outlet sound power level (SWL) for one cell operating at full design capacity in the following table.

Octave Band SWL (dBL)					(dBA)
Frequency	63	125	250	500	OA SWL
Sound Power Levels Input from Manufacturer					

- a. Octave band SWL are un-weighted (dBL), overall SWL is A-weighted (dBA).
- b. Manufacturer shall indicate/input expected noise levels (from measurements or calculations) in table above and provide supporting documentation (such as calculation sheets or measurement reports).

- C. Alternate Bid No. 1: With attenuators on south inlets and cellular louvers on north inlets.
1. Single tower cell, air inlet sound power levels (SWL) including water and fan noise with cellular louvers installed on north inlets and inlet attenuators installed on south inlets.

Input air inlet sound power level (SWL) for one cell operating at full design capacity in the following table. The cooling tower shall be designed to limit noise generation through lower fan tip speeds, specified ultra low sound fans, inlet sound attenuators, and fan deck barrier wall, oversizing, and other techniques other than the use of fan outlet sound attenuators. Water fall area or cold water basin treatments will also not be allowed.

Octave Band SWL @ 50 feet (dBL)					(dBA)
Frequency	63	125	250	500	OA SWL
Sound Power Levels Input from Manufacturer					

- a. Octave band SWL are un-weighted (dBL), overall SWL is A-weighted (dBA).
- b. Manufacturer shall indicate/input expected noise levels (from measurements or calculations) in table above and provide supporting documentation (such as calculation sheets or measurement reports).

2. Single tower cell, fan outlet sound power levels (SWL) including water and fan noise with cellular louvers installed on north inlets and inlet attenuators installed on south inlets.

Input fan outlet sound power level (SWL) for one cell operating at full design capacity in the following table.

Octave Band SWL (dBL)					(dBA)
Frequency	63	125	250	500	OA SWL
Sound Power Levels Input from Manufacturer					

- a. Octave band SWL are un-weighted (dBL), overall SWL is A-weighted (dBA).
- b. Manufacturer shall indicate/input expected noise levels (from measurements or calculations) in table above and provide supporting documentation (such as calculation sheets or measurement reports).

D. Alternate Bid No. 2: With attenuators on south and north inlets.

1. Single tower cell, air inlet sound power levels (SWL) including water and fan noise with inlet attenuators installed on north and south air inlets.

Input air inlet sound power level (SWL) for one cell operating at full design capacity in the following table. The cooling tower shall be designed to limit noise generation through lower fan tip speeds, specified ultra low sound fans, inlet sound attenuators, and fan deck barrier wall, oversizing, and other techniques other than the use of fan outlet sound attenuators. Water fall area or cold water basin treatments will also not be allowed.

Octave Band SWL @ 50 feet (dBL)					(dBA)
Frequency	63	125	250	500	OA SWL
Sound Power Levels Input from Manufacturer					

- a. Octave band SWL are un-weighted (dBL), overall SWL is A-weighted (dBA).
- b. Manufacturer shall indicate/input expected noise levels (from measurements or calculations) in table above and provide supporting documentation (such as calculation sheets or measurement reports).

2. Single tower cell, fan outlet sound power levels (SWL) including water and fan noise with inlet attenuators installed on north and south air inlets.

Input fan outlet sound power level (SWL) for one cell operating at full design capacity in the following table.

Octave Band SWL (dBL)					(dBA)
Frequency	63	125	250	500	OA SWL
Sound Power Levels Input from Manufacturer					

- a. Octave band SWL are un-weighted (dBL), overall SWL is A-weighted (dBA).
- b. Manufacturer shall indicate/input expected noise levels (from measurements or calculations) in table above and provide supporting documentation (such as calculation sheets or measurement reports).

5.3 BID COST FORM

A. Complete and submit the following **with Bid** submittal.

B. Base Bid: With cellular louvers on south and north inlets.

Dollars (\$_____).

C. Alternate Bids:

1. Should any of the alternates as described in the Contract Documents be accepted, the amount written below shall be the amount to be added to the Base Bid.

2. Alternate Bid No. 1: With attenuators on south inlets and cellular louvers on north inlets.

State the amount to be added to the base bid:

Dollars (\$_____).

3. Alternate Bid No. 2: With attenuators on south and north inlets.

State the amount to be added to the base bid:

Dollars (\$_____).



5 VIEW FROM BLYTHE DR.
SCALE: N.T.S.



4 VIEW FROM HIBBARD DR.
SCALE: N.T.S.



3 VIEW FROM MANNING DR.
SCALE: N.T.S.



2 AXONOMETRIC VIEW
SCALE: N.T.S.



1 VIEW FROM FUTURE BUSINESS SCHOOL EXPANSION
SCALE: N.T.S.



Sheet Keynotes:

Rev	Date	Description of Issue
C	07/11/25	CD FOR REVIEW
B	12/08/24	DESIGN DEVELOPMENT
A	06/14/24	SCHEMATIC DESIGN



THE UNIVERSITY
of NORTH CAROLINA
at CHAPEL HILL

**Chilled
Water
Infrastructure
Expansion**
SC# 22-25588-02A
CODE# 42123-355 / 42323-305
UNC BLDG. NO XXX

Sheet Title
**AXONOMETRIC SITE
DIAGRAM AND
PERSPECTIVE VIEWS**

Scale

As indicated


Date: 07/11/25
Drawn By: ND

Project No.: 23480-01
Checked By: KJB



Sheet No.: **B.A.901**



Sheet Keynotes:




1 OVERALL EQUIPMENT PLAN - ROOF LEVEL
 SCALE: 1/8" = 1'-0"



FIRE SEPARATION LEGEND

	1 HR RATED FIRE SEPARATION
	2 HR RATED FIRE SEPARATION



KEYPLAN

Rev	Date	Description of Issue
C	07/11/25	CD FOR REVIEW
B	12/06/24	DESIGN DEVELOPMENT
A	06/14/24	SCHEMATIC DESIGN



THE UNIVERSITY
 of NORTH CAROLINA
 at CHAPEL HILL

**Chilled
 Water
 Infrastructure
 Expansion**
 SCO# 22-25588-02A
 CODE# 42123-355 / 42323-305
 UNC BLDG. NO XXX

Sheet Title
**OVERALL
 EQUIPMENT PLAN -
 ROOF LEVEL**

Scale	As indicated
Date	07/11/25
Drawn By	JBG
Project No.	23480-01
Checked By	GAH

Sheet No.
B.M.204



- Sheet Notations:**
- ◇ TRAPEZE SUPPORT FOR CONDENSER WATER PIPING. REFER TO 018.M.502.
 - ◇ PROVIDE SUPPLEMENTAL STEEL AND TRAPEZE SUPPORT FOR KNIFE GATE VALVE STEMS.
 - ◇ 8" OVERFLOW UP TO BASIN.
 - ◇ TERMINATE PIPING WITH GOOSENECK 2" ABOVE TOP OF BASIN WALL.

Rev	Date	Description of Issue
C	07/11/25	CD FOR REVIEW
B	12/06/24	DESIGN DEVELOPMENT
A	06/14/24	SCHEMATIC DESIGN



THE UNIVERSITY
 of NORTH CAROLINA
 at CHAPEL HILL

Chilled Water Infrastructure Expansion
 SC0# 22-25588-02A
 CODE# 42123-355 / 42323-305
 UNC BLDG. NO XXX

Sheet Title

MECHANICAL PIPING PLAN - ROOF LEVEL - AREA A

Scale: As Indicated


Date	Drawn By
07/11/25	JBG

Project No.	Checked By
23480-01	GAH


Sheet No.
B.M.214A

FIRE SEPARATION LEGEND

- 1 HR RATED FIRE SEPARATION
- 2 HR RATED FIRE SEPARATION



KEYPLAN



1 MECHANICAL PIPING PLAN - ROOF LEVEL - AREA A
 SCALE: 1/4" = 1'-0"





- Sheet Remarks:
- ◇ TRAPEZE SUPPORT FOR CONDENSER WATER PIPING. REFER TO 218.M.502.
 - ◇ PROVIDE SUPPLEMENTAL STEEL AND TRAPEZE SUPPORT FOR KNIFE GATE VALVE STEMS.
 - ◇ 8" OVERFLOW UP TO BASIN.
 - ◇ TERMINATE PIPING WITH GOOSENECK 2" ABOVE TOP OF BASIN WALL.

Rev	Date	Description of Issue
C	07/11/25	CD FOR REVIEW
B	12/06/24	DESIGN DEVELOPMENT
A	06/14/24	SCHEMATIC DESIGN

Project



THE UNIVERSITY of NORTH CAROLINA at CHAPEL HILL


Chilled Water Infrastructure Expansion
 SCD# 22-25588-02A
 CODE# 42123-355 / 42323-305
 UNC BLDG. NO XXX

Sheet Title
MECHANICAL PIPING PLAN - ROOF LEVEL - AREA B


Scale	As Indicated
Date	Drawn By
07/11/25	JBG
Project No.	Checked By
23480-01	GAH

Sheet No.
B.M.214B



FIRE SEPARATION LEGEND
 - - - - - 1 HR RATED FIRE SEPARATION
 - - - - - 2 HR RATED FIRE SEPARATION



KEYPLAN



1 MECHANICAL PIPING PLAN - ROOF LEVEL - AREA B
 SCALE: 1/4" = 1'-0"





Sheet Keynotes:

- ◆ CONTRACTOR TO ROTATE CONTROL VALVE SUCH THAT ACTUATOR IS OUT OF WALKWAY. COORDINATE ROTATION IN THE FIELD WITH THE OWNER.
- ◆ TERMINATE PIPING WITH GOOSENECK 2" ABOVE TOP OF BASIN WALL.

Rev	Date	Description of Issue
A	07/11/25	CD FOR REVIEW



THE UNIVERSITY
 of NORTH CAROLINA
 at CHAPEL HILL

Chilled Water Infrastructure Expansion
 SC0# 22-25588-02A
 CODE# 42123-355 / 42323-305
 UNC BLDG. NO XXX

Sheet Title
MECHANICAL PIPING PLAN - DUNNAGE LEVEL - AREA A

Scale
 As Indicated


Date: 07/11/25
 Drawn By: JBG

Project No.: 23480-01
 Checked By: GAH


Sheet No.
B.M.215A

FIRE SEPARATION LEGEND


- 1 HR RATED FIRE SEPARATION
- 2 HR RATED FIRE SEPARATION




KEYPLAN



1 MECHANICAL PIPING PLAN - DUNNAGE LEVEL - AREA A
 SCALE: 1/4" = 1'-0"





Sheet Notes:

- CONTRACTOR TO ROTATE CONTROL VALVE SUCH THAT ACTUATOR IS OUT OF WALKWAY. COORDINATE ROTATION IN THE FIELD WITH THE OWNER.
- TERMINATE PIPING WITH GOOSENECK 2" ABOVE TOP OF BASIN WALL.

Rev	Date	Description of Issue
A	07/11/25	CD FOR REVIEW



THE UNIVERSITY
 of NORTH CAROLINA
 at CHAPEL HILL

Chilled Water Infrastructure Expansion
 SCD# 22-25588-02A
 CODE# 42123-355 / 42323-305
 UNC BLDG. NO XXX

Sheet Title
MECHANICAL PIPING PLAN - DUNNAGE LEVEL - AREA B

Scale
 As Indicated


Date: 07/11/25
 Drawn By: JBG

Project No.: 23480-01
 Checked By: GAH


Sheet No.
B.M.215B

FIRE SEPARATION LEGEND



- 1 HR RATED FIRE SEPARATION
- 2 HR RATED FIRE SEPARATION




KEYPLAN



1 MECHANICAL PIPING PLAN - DUNNAGE LEVEL - AREA B
 SCALE: 1/4" = 1'-0"





Sheet Keynotes:

Rev	Date	Description of Issue
A	07/11/25	CD FOR REVIEW

Project



THE UNIVERSITY
 of NORTH CAROLINA
 at CHAPEL HILL

Chilled Water Infrastructure Expansion
 SC0# 22-25588-02A
 CODE# 42123-355 / 42323-305
 UNC BLDG. NO XXX

Sheet Title
MECHANICAL PIPING PLAN - FAN DECK LEVEL - AREA A

Scale
 As Indicated

Date
 07/11/25

Drawn By
 JBG


Project No.
 23480-01

Checked By
 GAH



Sheet No.
B.M.216A

FIRE SEPARATION LEGEND


--- 1 HR RATED FIRE SEPARATION
 - - - 2 HR RATED FIRE SEPARATION




KEYPLAN



1 MECHANICAL PIPING PLAN - FAN DECK LEVEL - AREA A





Sheet Keynotes:

Rev	Date	Description of Issue
A	07/11/25	CD FOR REVIEW




THE UNIVERSITY
 of NORTH CAROLINA
 at CHAPEL HILL

**Chilled
 Water
 Infrastructure
 Expansion**
 SCD# 22-25588-02A
 CODE: 42123-355 / 42323-305
 UNC BLDG. NO XXX


Sheet Title
**MECHANICAL PIPING
 PLAN - FAN DECK
 LEVEL - AREA B**

Scale	Date	Drawn By
As Indicated	07/11/25	JBG
Project No.	Checked By	
23480-01	GAH	

Sheet No.
B.M.216B





FIRE SEPARATION LEGEND
 - - - - - 1 HR RATED FIRE SEPARATION
 - - - - - 2 HR RATED FIRE SEPARATION




KEYPLAN

1 MECHANICAL PIPING PLAN - FAN DECK LEVEL - AREA B
 SCALE: 1/4" = 1'-0"






Sheet Keynotes:



1 COOLING TOWERS 1-3 LOOKING SOUTH
 SCALE: 1/4" = 1'-0"



Rev	Date	Description of Issue
B	07/11/25	CD FOR REVIEW
A	12/06/24	DESIGN DEVELOPMENT

Project



THE UNIVERSITY
 of NORTH CAROLINA
 at CHAPEL HILL

**Chilled
 Water
 Infrastructure
 Expansion**

SCD# 22-25588-02A
 CODE: 42123-355 / 42323-305
 UNC BLDG. NO XXX

Sheet Title
SECTIONS

Scale
 1/4" = 1'-0"

Date
 07/11/25

Project No.
 23480-01

Sheet No.
B.M.306



Sheet Keynotes:
 ◊ TERMINATE PIPING WITH GOOSENECK 2' ABOVE TOP OF BASIN WALL.

Rev	Date	Description of Issue
B	07/11/25	CD FOR REVIEW
A	12/06/24	DESIGN DEVELOPMENT




THE UNIVERSITY
 of NORTH CAROLINA
 at CHAPEL HILL
**Chilled
 Water
 Infrastructure
 Expansion**
 SCO# 22-25588-02A
 CODE# 42123-355 / 42323-305
 UNC BLDG. NO XXX


Sheet Title
SECTIONS

Date	Drawn By
07/11/25	JBG
Date	Checked By
23480-01	GAH


Sheet No.
B.M.307




1 COOLING TOWERS 4-5 LOOKING SOUTH
 SCALE: 1/4" = 1'-0"



2 COOLING TOWER 5 LOOKING WEST
 SCALE: 1/4" = 1'-0"





1 BCP-CONDENSER WATER FLOW DIAGRAM (DSC CONTROLS BY DIVISION 25)
SCALE: NONE

Affiliated Engineers, Inc.
1414 Raleigh Road, Suite 205
Chapel Hill, NC 27517
Tel 919.478.9892
www.aeieng.com
NC Lic. No. C-2382



Sheet Keynotes:
1 EXTERIOR PIPING AND VALVES 8" AND SMALLER AND ALL SPECIALTIES AND INSTRUMENTATION LINES SHALL BE INSULATED AND PROVIDED WITH HEAT TRACE.

Rev	Date	Description of Issue
B	07/11/25	CD FOR REVIEW
A	12/06/24	DESIGN DEVELOPMENT



THE UNIVERSITY
of NORTH CAROLINA
at CHAPEL HILL

**Chilled
Water
Infrastructure
Expansion**
SC0# 22-25688-02A
CODE: 42123-355 / 42323-308
UNC BLDG. NO XXX

Sheet Title
**CONDENSER WATER
P&ID**

Scale	NTS
Date	07/11/25
Drawn By	JBG
Project No.	23480-01
Checked By	BJP

Sheet No.
B.M.403

COOLING TOWERS													23 0510
MARK CTP	LOCATION	GPM EACH CELL	MIN. FLOW EACH CELL	MAX. PD (FT) (2)	TEMPERATURE (°F)			FAN MOTOR (EACH CELL)			CONTROLLER	REMARKS	
					AIR WB	EWT	LWT	MAX. HP	VOLT	PHASE			
301B	ROOF	7,500	3,750	25	80	95	85	200	480	3	Y	(1)	
302B	ROOF	7,500	3,750	25	80	95	85	200	480	3	Y	(1)	
303B	ROOF	7,500	3,750	25	80	95	85	200	480	3	Y	(1)	
304B	ROOF	7,500	3,750	25	80	95	85	200	480	3	Y	(1)	
305B	ROOF	7,500	3,750	25	80	95	85	200	480	3	Y	(1)	

NOTES:
1. VFD FOR DIRECT DRIVE COOLING TOWER FAN MOTOR PROVIDED BY COOLING TOWER MANUFACTURER.
2. FROM INLET FLANGE CONNECTION.

WATER FLOW METERS										23 0503
MARK FIT	SYSTEM	SERVICE	TYPE	CAPACITY (GPM)	SIZE (IN)	MAX. PD (FT)	VOLTAGE	REMARKS		
101_2B	CWS	CRM 1_2B	INLINE MAGNETIC	7,500	20	N/A	24			
102_2B	CWS	CRM 2_2B	INLINE MAGNETIC	7,500	20	N/A	24			
103_2B	CWS	CRM 3_2B	INLINE MAGNETIC	7,500	20	N/A	24			
104_2B	CWS	CRM 4_2B	INLINE MAGNETIC	7,500	20	N/A	24			
105_2B	CWS	CRM 5_2B	INLINE MAGNETIC	7,500	20	N/A	24			
201_1B	CHR	CRM 1_1B	INLINE MAGNETIC	4,275	16	N/A	24			
202_1B	CHR	CRM 2_1B	INLINE MAGNETIC	4,275	16	N/A	24			
203_1B	CHR	CRM 3_1B	INLINE MAGNETIC	4,275	16	N/A	24			
204_1B	CHR	CRM 4_1B	INLINE MAGNETIC	4,275	16	N/A	24			
205_1B	CHR	CRM 5_1B	INLINE MAGNETIC	4,275	16	N/A	24			
800A	MU	CHW MAKE-UP	INLINE MAGNETIC	80	2.5	N/A	24			
800B	MU	CHW MAKE-UP	INLINE MAGNETIC	470	4	N/A	24			
200B	CHS	MINIMUM FLOW BYPASS	INLINE MAGNETIC	2,138	10	N/A	24			
300BB	CWS	TOWER BLEED	INLINE MAGNETIC	190	4	N/A	24			
300AB	MU	CW MAKEUP	INLINE MAGNETIC	565	8	N/A	24			
350B	RCW	CW MAKEUP	INLINE MAGNETIC	565	8	N/A	24			

CHILLERS														24 0000
MARK CRM	COMPRESSOR TYPE	CHILLER ARRANGEMENT	MAX. OPER. WEIGHT (LBS)	REFRIGERANT CLASSIFICATION	CAPACITY (TONS)	MAXIMUM KW/TON	EVAPORATOR					REMARKS		
							GPM	EWT (°F)	LWT (°F)	PASS	MAX. PD (FT)		FOULING FACTOR	
1_1B	CENTRIFUGAL	SERIES-COUNTERFLOW	60,000	A1 OR B1	1,225	0.57	4,275	56	49	1	10.9	0.0001	(1)	
1_2B	CENTRIFUGAL	SERIES-COUNTERFLOW	60,000	A1 OR B1	1,275			49	42	1	10.9	0.0001	(1)	
2_1B	CENTRIFUGAL	SERIES-COUNTERFLOW	60,000	A1 OR B1	1,225	0.57	4,275	56	49	1	10.9	0.0001	(1)	
2_2B	CENTRIFUGAL	SERIES-COUNTERFLOW	60,000	A1 OR B1	1,275			49	42	1	10.9	0.0001	(1)	
3_1B	CENTRIFUGAL	SERIES-COUNTERFLOW	60,000	A1 OR B1	1,225	0.57	4,275	56	49	1	10.9	0.0001	(1)	
3_2B	CENTRIFUGAL	SERIES-COUNTERFLOW	60,000	A1 OR B1	1,275			49	42	1	10.9	0.0001	(1)	
4_1B	CENTRIFUGAL	SERIES-COUNTERFLOW	60,000	A1 OR B1	1,225	0.57	4,275	56	49	1	10.9	0.0001	(1)	
4_2B	CENTRIFUGAL	SERIES-COUNTERFLOW	60,000	A1 OR B1	1,275			49	42	1	10.9	0.0001	(1)	
5_1B	CENTRIFUGAL	SERIES-COUNTERFLOW	60,000	A1 OR B1	1,225	0.57	4,275	56	49	1	10.9	0.0001	(1)	
5_2B	CENTRIFUGAL	SERIES-COUNTERFLOW	60,000	A1 OR B1	1,275			49	42	1	10.9	0.0001	(1)	

CHILLERS														23 0503			
MARK CRM	CONDENSER GPM	EWT (°F)	LWT (°F)	PASS	MAX. PD (FT)	FOULING FACTOR	ELECTRICAL										STARTER TYPE
							MAX. POWER INPUT (KW)	MCA (AMPS)	MOP (AMPS)	LRA (AMPS)	RLA (AMPS)	INRUSH	VOLT	PH			
1_1B	7,500	90	95	1	10.8	0.00025	686					6440	--	--	480	3	VFD (UNIT MOUNTED)
1_2B		85	90	1	10.8	0.00025	704					6440	--	--	480	3	VFD (UNIT MOUNTED)
2_1B	7,500	90	95	1	10.8	0.00025	686					6440	--	--	480	3	VFD (UNIT MOUNTED)
2_2B		85	90	1	10.8	0.00025	704					6440	--	--	480	3	VFD (UNIT MOUNTED)
3_1B	7,500	90	95	1	10.8	0.00025	686					6440	--	--	480	3	VFD (UNIT MOUNTED)
3_2B		85	90	1	10.8	0.00025	704					6440	--	--	480	3	VFD (UNIT MOUNTED)
4_1B	7,500	90	95	1	10.8	0.00025	686					6440	--	--	480	3	VFD (UNIT MOUNTED)
4_2B		85	90	1	10.8	0.00025	704					6440	--	--	480	3	VFD (UNIT MOUNTED)
5_1B	7,500	90	95	1	10.8	0.00025	686					6440	--	--	480	3	VFD (UNIT MOUNTED)
5_2B		85	90	1	10.8	0.00025	704					6440	--	--	480	3	VFD (UNIT MOUNTED)

NOTES:
1. TWO (2) CHILLERS CONNECTED IN SERIES-COUNTERFLOW (SC) ARRANGEMENT.

PUMPS														23 2123		
MARK P	LOCATION	SERVICE	TYPE	MAX. OPER. WEIGHT (LBS)	CAP. (GPM)	HEAD (FT)	MAX. NPSHR (FT)	MIN. EFF. (%)	SIZE (IN)		ELECTRICAL CHARACTERISTICS					REMARKS
									SUCT.	DISCH.	VFD	HP	RPM	VOLT	PH	
101B	MECHANICAL ROOM	CONDENSER WATER	HORIZONTAL SPLIT CASE	9,000	12,500	100	30	81	20	16	YES	400	1200	480	3	(1)
102B	MECHANICAL ROOM	CONDENSER WATER	HORIZONTAL SPLIT CASE	9,000	12,500	100	30	81	20	16	YES	400	1200	480	3	(1)
103B	MECHANICAL ROOM	CONDENSER WATER	HORIZONTAL SPLIT CASE	9,000	12,500	100	30	81	20	16	YES	400	1200	480	3	(1)
104B	MECHANICAL ROOM	CONDENSER WATER	HORIZONTAL SPLIT CASE	9,000	12,500	100	30	81	20	16	YES	400	1200	480	3	(1)
201B	MECHANICAL ROOM	CHILLED WATER	HORIZONTAL SPLIT CASE	9,000	7,125	150	18	83	16	12	YES	350	1200	480	3	(1)
202B	MECHANICAL ROOM	CHILLED WATER	HORIZONTAL SPLIT CASE	9,000	7,125	150	18	83	16	12	YES	350	1200	480	3	(1)
203B	MECHANICAL ROOM	CHILLED WATER	HORIZONTAL SPLIT CASE	9,000	7,125	150	18	83	16	12	YES	350	1200	480	3	(1)
204B	MECHANICAL ROOM	CHILLED WATER	HORIZONTAL SPLIT CASE	9,000	7,125	150	18	83	16	12	YES	350	1200	480	3	(1)
701B	MECHANICAL ROOM	CHILLED WATER	VERTICAL INLINE	1,000	645	75	10	76	5	5	YES	20	1800	480	3	

NOTES:
1. OWNER PREPURCHASED AND FURNISHED TO INSTALL.

VARIABLE FREQUENCY DRIVES														23 0515	
MARK VFD	EQUIPMENT	LOCATION	HP	VOLTS	RPM	PULSE	MAX. ENCL. SIZE (LxWxH)	INPUT CIRCUIT BREAKER	INTERNAL POWER- TO MTR HEATER	OUTPUT REACTOR	OUTPUT DVIDT FILTER	BYPASS STARTER	HARMONIC TRAP	SINGLE ENCLOSURE	REMARKS
P-102B	CW PUMP	FIRST FLOOR	400	460	1200	6	70"x32"x86"	Y	N	N	N	N	N	Y	OFCI
P-103B	CW PUMP	FIRST FLOOR	400	460	1200	6	70"x32"x86"	Y	N	N	N	N	N	Y	OFCI
P-104B	CW PUMP	FIRST FLOOR	400	460	1200	6	70"x32"x86"	Y	N	N	N	N	N	Y	OFCI
P-201B	CHW PUMP	FIRST FLOOR	350	460	1200	6	42"x32"x86"	Y	N	N	N	N	N	Y	OFCI
P-202B	CHW PUMP	FIRST FLOOR	350	460	1200	6	42"x32"x86"	Y	N	N	N	N	N	Y	OFCI
P-203B	CHW PUMP	FIRST FLOOR	350	460	1200	6	42"x32"x86"	Y	N	N	N	N	N	Y	OFCI
P-204B	CHW PUMP	FIRST FLOOR	350	460	1200	6	42"x32"x86"	Y	N	N	N	N	N	Y	OFCI
P-701B	CHW HVAC PUMP	FIRST FLOOR	20	460	-	6	24"x18"x36"	Y	N	N	N	N	N	Y	OFCI
CTF-301B	COOLING TOWER FAN	MEZZANINE	200	460	-	6	35"x22"x56"	Y	Y	N	N	N	N	Y	1.2 OFCI
CTF-302B	COOLING TOWER FAN	MEZZANINE	200	460	-	6	35"x22"x56"	Y	Y	N	N	N	N	Y	1.2 OFCI
CTF-303B	COOLING TOWER FAN	MEZZANINE	200	460	-	6	35"x22"x56"	Y	Y	N	N	N	N	Y	1.2 OFCI
CTF-304B	COOLING TOWER FAN	MEZZANINE	200	460	-	6	35"x22"x56"	Y	Y	N	N	N	N	Y	1.2 OFCI
CTF-305B	COOLING TOWER FAN	MEZZANINE	200	460	-	6	35"x22"x56"	Y	Y	N	N	N	N	Y	1.2 OFCI
EF-1	PAINT BOOTH EXHAUST	MEZZANINE	5	460	-	6	24"x18"x36"	Y	N	N	N	N	N	Y	
EF-2	REFRIGERANT EXHAUST	MEZZANINE	10	460	-	6	24"x18"x36"	Y	N	N	N	N	N	Y	
SF-1-1	AHU-1	FIRST FLOOR	25	460	-	6	24"x18"x36"	Y	N	N	N	N	N	Y	
SF-1-2	AHU-1	FIRST FLOOR	25	460	-	6	24"x18"x36"	Y	N	N	N	N	N	Y	
SF-2-1	AHU-2	FIRST FLOOR	20	460	-	6	24"x18"x36"	Y	N	N	N	N	N	Y	
SF-2-2	AHU-2	FIRST FLOOR	20	460	-	6	24"x18"x36"	Y	N	N	N	N	N	Y	
SF-3-1	AHU-3	MEZZANINE	25	460	-	6	24"x18"x36"	Y	N	N	N	N	N	Y	
SF-3-2	AHU-3	MEZZANINE	25	460	-	6	24"x18"x36"	Y	N	N	N	N	N	Y	
SF-4-1	AHU-4	MEZZANINE	15	460	-	6	24"x18"x36"	Y	N	N	N	N	N	Y	
SF-4-2	AHU-4	MEZZANINE	15	460	-	6	24"x18"x36"	Y	N	N	N	N	N	Y	
RF-4-1	AHU-4	MEZZANINE	3	460	-	6	24"x18"x36"	Y	N	N	N	N	N	Y	
RF-4-2	AHU-4	MEZZANINE	3	460	-	6	24"x18"x36"	Y	N	N	N	N	N	Y	

NOTES:
1. VFD FOR COOLING TOWER PERMANENT MAGNET ROTOR (PMR) APPLICATION SHALL BE PROVIDED WITH THE COOLING TOWER VENDOR AND COORDINATED FOR THE SPECIFIC APPLICATION.
2. REFER TO THE 'E SERIES' SHEETS FOR THE DESIGN INTENT FOR THE VFD WIRING SCHEMATIC TO INCLUDE 120V AND LV WIRING BETWEEN THE VFD AND THE COOLING TOWER COMPONENTS.



Sheet Keynotes:
07/22/25

Rev	Date	Description of Issue
C	07/11/25	CD FOR REVIEW
B	12/06/24	DESIGN DEVELOPMENT
A	06/14/24	SCHEMATIC DESIGN



THE UNIVERSITY
of NORTH CAROLINA
at CHAPEL HILL
**Chilled
Water
Infrastructure
Expansion**
SCOW 22-25588-02A
CODE: 42123-355 / 42323-305
UNC BLDG. NO XXX

Sheet Title
SCHEDULES

Scale
NTS
Date
07/11/25
Project No.
23480-01
Sheet No.
B.M.601

Drawn By
JBG
Checked By
GAH