



Friday, March 14, 2025
Addendum #2

Moore Strong Residence Hall – HVAC Renovation Phase 2
UNC Greensboro
SCO # 22-24777-01A

This addendum shall become a part of plans and specifications. Contractor shall acknowledge receipt of this addendum in the bid proposal.

ITEM 1 – CONTRACTOR QUESTIONS

- a) Q: Can you provide the make and model of the buildings fire alarm system?
A: The existing FACP is Simplex Model 4100ES.

ITEM 2 – CORRECTIONS AND CLARIFICATIONS

- a) Refer to Specifications Section 230900:
Amend section 1.3-A to the following: "Provide Owner-Preferred Alternate Bid to provide Distech controls as installed by CMS Controls."

End of Addendum