



Addendum 4

October 9, 2024

Bid Set A

**Penny Road Sidewalk
Cary Project No.: ST4003**

**Optimist Farm Road Sidewalk
Cary Project No.: ST4007**

**West Lake Road Sidewalk
Cary Project No.: ST4008**


The following items shall be taken into consideration when preparing bids for this project and this addendum shall become a part of and take precedence over anything contrarily shown or described in the Contract Documents.

Addendum 4

Item 1 – Questions

Question 1: For the LED enhanced signs will one or two push buttons be required per signpost?

Answer 1: The intent of the LED Enhanced Sign is to have one push button per sign post. As noted in the special provision, the face of the push button shall be parallel to its associated crosswalk.


Jeffrey W Meador, PE