



307 E Jefferson St Monroe, NC  
28112

Craig Reeder

craig.reeder@ucps.k12.nc.us

ucps.k12.nc.us

## Purchasing and Contracts

### ADDENDUM 1

**BID#: 5-97348011**

**DUE DATE: Tuesday, January 7, 2025, at 2:00PM**

**Contractor shall fulfill all requirements listed within the bid documents, including additions and changes noted below.**

1. Are there preferred vendors for these partitions. I did not see any specs.

**Kwik-Wall 2030 or Moderco's 842 series with a STC rating of 51/52 with HPL Faces**

2. No specs on type of wall or approved product.

**Kwik-Wall 2030 or Moderco's 842 series with a STC rating of 51/52 with HPL Faces**

3. For this project are there any details like plans specs or bid manual, or any forms needed? **No**

4. Builders' risk/ P&P bond/ Bid Bond Etc?

**Yes, the forms are attached to the BID document**

5. And does Jennifer West have a contact number?

**Jennifer West 704-208-6307**

**End of Addendum 1**