

City of Havelock,

Request for Proposals for CCTV/Cleaning of a portion of the Sanitary Sewer System

Addendum 1

May 23, 2025

1. It is unusual to group 15" and 18" pipe diameters with 8"-12" pipe diameters. Can 15" and 18" be another line item?

Bid Form modified to reflect 8-12"

2. Pineview LS to Oakwood and Oakwood to the WWTP is a complex easement project with dual lines. Easement work is typically priced at a different rate because of additional equipment (easement machine, side by side and scaffolding) needed. Do you intend to add another line item for the easement work?

Oakwood to the WWTP is not anticipated to be inspected as a part of this contract (see revised bid form to note pricing for only 12" and smaller below.)

3. Will the easements be cleared, specifically the large swampy easement from Fontana to the WWTP?

See answer to Question 2) this line is not anticipated to be inspected as a part of this project. If easement clearing is required to access an inspection, the City will be responsible for clearing the easement. This project is primarily small diameter lines in street, but may include some easement lines.

4. Bid documents state that this project does not require bypass pumping; however, in past years, it has been needed at the end of the Oakwood through that easement. What has changed for that not to be required?

See answers to prior questions, this line is not anticipated to be inspected as a part of this project. Downstream improvements have been completed which should help alleviate capacity constraint.

5. There is no line item for heavy cleaning although it states in the bid documents that there will be some root removal, pipe descaling, etc. Would it be possible to add this as a separate line item?

Added a City controlled allowance for heavy cleaning and a line item for heavy cleaning when authorized under the allowance.

ATTACHMENT D: BID FORM

Item No.	Item Description (Unit Price to be written in words)	Estimated Quantity Only	Unit Of Measure	Unit Price	Total Price
1	Clean and inspect with CCTV sewer mains 6-inch diameter _____ Dollars and _____ Cents	1000	Linear Foot		
2	Clean and inspect with CCTV sewer mains 8-inch to 12-inch diameter _____ Dollars and _____ Cents	29,000	Linear Foot		
3	City controlled allowance for heavy cleaning	N/A	N/A	N/A	\$10,000
4	Unit Price for heavy cleaning _____ Dollars and _____ Cents	N/A	Linear Foot		N/A
	CCTV TOTAL				
	GRAND TOTAL	30,000	Linear Foot		