



Internal Services Department

Facilities Management Division · Fleet Management Division · Landscaping & Grounds Division

CUMBERLAND COUNTY JUDGE E. MAURICE BRASWELL COURTHOUSE COOLING TOWER REBUILD

ADDENDUM I – QUESTIONS & ANSWERS (Answers in red)

1. Will the County accept the use of aftermarket parts to replace original OEM parts?

The base bid should be for the use of exclusively OEM parts within both cooling towers. If the Contractor intends to use any aftermarket parts in place of OEM parts they should provide separately an alternate bid with a detailed list of what will be replaced with aftermarket parts. Contractor should also provide a written plan for maintaining OEM design characteristics specifically as it relates to the aftermarket parts being used in the rebuild.

2. Is there a minimum specific material thickness for new fill media?

New fill media should be a minimum 15 mil thickness if being supported from below to prevent compression. Upper level fill media may be only 10 mil thickness.

Fleet Management
426 Mayview Street
Fayetteville, NC 28306
910 321-6963

Facilities Management
420 Mayview Street
Fayetteville, NC 28306
910-678-7699

Landscaping & Grounds
807 Grove Street
Fayetteville, NC 28302
910-678-7560