



ADDENDUM 1

102-359 – Commercial Gas Water Heater Project

March 28, 2025

Listing of the attendees of the mandatory pre-bid site visit on March 27, 2025 at 10:00 AM at the Administration Building.

(286 ICC Loop Road, Spindale, NC 28160 – Room 127 Auditorium)

- Enbridge Gas NC
- Envirotrol
- Hoyle Plumbing

Questions submitted and responses listed below as follows:

1. What is the main gas pressure on the gas line?

Response: 2 psi

2. How much gas pressure will the new water heaters require?

Response: We believe the new water heaters will require the same 2psi, but please confirm this with the product specifications of a Phoenix Water Heaters: Model PH199-119.

Heather Maples

Procurement & Equipment Coordinator