

City of Havelock,  
2024 Aeration Piping at the Waste Water Treatment Facility

Addendum 2

September 5, 2024

**Questions Received**

1. The aeration vendor states it may take 8-12 weeks to receive the diffuser, the completion time noted in the scope of work is only 30 days. Please advise.

Material lead time will be taken into consideration in scheduling once the project has been awarded.

2. The scope of work states the contractor is responsible for removal and disposal of all sediment and sludge in the wasting basin. It seems the most economical method would be to pump the residual sludge to the sludge holding tank so the already contracted sludge hauler can process the sludge. Or the sludge can be pumped back to the "head of the plant" and be re-processed. Please advise?

The sediment and sludge cannot be introduced into the sludge holding tank due to the current levels within the tank. The sediment and sludge can be pumped back into the head of the plant to be re-processed.

3. Who is the current sludge hauler?

The sludge is currently hauled by Lewis Farms.

4. Can the contractor use the onsite drying bed if needed?

No, we do not want to take the chance of overwhelming the levels within the drying bed.