

ADDENDUM 3

May 31, 2024

**INTERMODAL YARD IMPROVEMENTS, PORT OF WILMINGTON
SCO#: 23-26203-01A**

LOCATION: Intermodal Yard
Port of Wilmington
2202 Burnett Boulevard
Wilmington, NC 28401

OWNER: North Carolina State Ports Authority
2202 Burnett Boulevard
Wilmington, NC 28401

DESIGNER: Mott MacDonald
930 Main Campus Drive, Suite 200
Raleigh NC, 27606

BIDS DUE: Thursday, June 6, 2024 @ 2:00 PM
North Carolina State Ports Authority
Room 100A, North Carolina Maritime Building
2202 Burnett Boulevard, Wilmington, NC 28401

Contract

1. **REVISION:** Replace ASPHALT PAVING 321216-2, 2.2 ASPHALT MATERIALS A. Asphalt Binder: AASHTO M 320, PG 64-22 with **ASPHALT PAVING 321216-2, 2.2 ASPHALT MATERIALS A. Asphalt Binder: AASHTO M 320, PG 76-22, (PG 64-22 binder shall be SBS polymer modified). The number of compactor gyrations shall be 75.**
2. **REVISION:** Replace ASPHALT PAVING 321216-2, 2.4 MIXES A.2. Base Course: Refer to plans with **ASPHALT PAVING 321216-2, 2.4 MIXES A.2. Base Course: Provide NCDOT mix B25.0C. The B25.0C course shall contain no more than 20% by weight of reclaimed asphalt pavement (RAP) and shall not contain reclaimed asphalt shingles.**
3. **REVISION:** Replace ASPHALT PAVING 321216-2, 2.4 MIXES A. 3. Surface Course: Refer to plans with **ASPHALT PAVING 321216-2, 2.4 MIXES A. 3. Surface Course: Provide NCDOT mix I19.0C. The I19.0C course shall not contain reclaimed asphalt pavement (RAP) and shall not contain reclaimed asphalt shingles.**
4. **Form of Proposal, Page C-2, Item 17 ASP FOR PLANT MIX shall be AASHTO M 320, PG 76-22, (PG 64-22 binder shall be SBS polymer modified).**

Plan Set

REVISION: All plan references to asphalt binder shall be revised to: **Asphalt Binder: AASHTO M 320, PG 76-22, (PG 64-22 binder shall be SBS polymer modified).**

End of Addendum 3