



**Invitation for Bid No. 2025-041**

**Hwy 75 Pump and Motor Replacement**

---

**ADDENDUM No. 1**

**ISSUE DATE: April 3, 2025**

Responding Offerors on this project are hereby notified that this Addendum shall be made a part of the above named IFB document.

The following items add to, modify, and/or clarify the IFB documents and shall have the full force and effect of the original Documents. This Addendum shall be acknowledged by the Offeror in the IFB document.

## **Questions/Answers**

1. Please provide a picture of the existing pump name plate and its serial# for Bid# 2025-041.

Answer: Please see Attachment 1.

*End of Questions/Answers Sections*

## **Attachment**

1. Photo of Existing Pump

End of Addendum 1

**Robinson**

A SUBSIDIARY OF THE GORMAN-RUPP CO.  
TOCCOA, GEORGIA

SIZE - TYPE

5 X 4 MAC

CAPACITY

740

SERIAL NO.

C017361-02

HEAD

270

R.P.M.

3570

MADE IN U.S.A.