



## **STATE OF NORTH CAROLINA**

**Fayetteville State University**

**Invitation for Bid #: 58-IFB252002-REBID**

**Health & Wellness Center Transformer**

**Date Issued: March 10, 2025**

**Bid Opening Date: March 21, 2025**

**At 11:00 AM ET**

**Direct all inquiries concerning this IFB to:**

Victoria McAllister

Chief Procurement Officer

Email: [vmcallister@uncfsu.edu](mailto:vmcallister@uncfsu.edu)

Phone: 910-672-1082



## STATE OF NORTH CAROLINA

### Invitation for Bids #

**58-IFB252002-REBID**

---

For internal State agency processing, including tabulation of bids, provide your company's eVP (Electronic Vendor Portal) Number. Pursuant to G.S. 132-1.10(b) this identification number shall not be released to the public. **This page will be removed and shredded, or otherwise kept confidential**, before the procurement file is made available for public inspection.

**This page shall be filled out and returned with your bid.  
Failure to do so shall be sufficient cause to reject your bid.**

---

Vendor Name

---

Vendor eVP #

Note: For a contract to be awarded to you, your company (you) must be a North Carolina registered vendor in good standing. You must enter the vendor number assigned through eVP (Electronic Vendor Portal). If you do not have a vendor number, register at <https://vendor.ncgov.com/vendor/login>

*Electronic responses ONLY will be accepted for this solicitation via Bonfire.*

**STATE OF NORTH CAROLINA  
Fayetteville State University**

Refer <u>ALL</u> Inquiries regarding this IFB to: <b>Victoria McAllister</b> Chief Procurement Officer vmcallister@uncfsu.edu	Invitation for Bids # 58-IFB252002-REBID	
	Bids will be publicly opened: Friday, March 21, 2025 at 11:30 A.M. E.T via MS. Teams. See meeting details in Section 2.4 IFB Schedule.	
Using Agency: Fayetteville State University	Commodity No. and Description: 39121001-Distribution power transformers	
Requisition No.: N/A		

**EXECUTION**

In compliance with this Invitation for Bids (IFB), and subject to all the conditions herein, the undersigned Vendor offers and agrees to furnish and deliver any or all items upon which prices are bid, at the prices set opposite each item within the time specified herein.

By executing this bid, the undersigned Vendor understands that false certification is a Class I felony and certifies that:

- this bid is submitted competitively and without collusion (G.S. 143-54),
- that none of its officers, directors, or owners of an unincorporated business entity has been convicted of any violations of Chapter 78A of the General Statutes, the Securities Act of 1933, or the Securities Exchange Act of 1934 (G.S. 143-59.2), and
- it is not an ineligible Vendor as set forth in G.S. 143-59.1.

Furthermore, by executing this bid, the undersigned certifies to the best of Vendor’s knowledge and belief, that:

- it and its principals are not presently debarred, suspended, proposed for debarment, declared ineligible or voluntarily excluded from covered transactions by any Federal or State department or agency.

As required by G.S. 143-48.5, the undersigned Vendor certifies that it, and each of its sub-Contractors for any Contract awarded as a result of this IFB, complies with the requirements of Article 2 of Chapter 64 of the NC General Statutes, including the requirement for each employer with more than 25 employees in North Carolina to verify the work authorization of its employees through the federal E-Verify system.

As required by Executive Order 24 (2017), the undersigned vendor certifies will comply with all Federal and State requirements concerning fair employment and that it does not and will not discriminate, harass, or retaliate against any employee in connection with performance of any Contract arising from this solicitation.

G.S. 133-32 and Executive Order 24 (2009) prohibit the offer to, or acceptance by, any State Employee associated with the preparing plans, specifications, estimates for public Contract; or awarding or administering public Contracts; or inspecting or supervising delivery of the public Contract of any gift from anyone with a Contract with the State, or from any person seeking to do business with the State. By execution of this bid response to the IFB, the undersigned certifies, for Vendor’s entire organization and its employees or agents, that Vendor are not aware that any such gift has been offered, accepted, or promised by any employees or agents of Vendor’s organization.

By executing this bid, Vendor certifies that it has read and agreed to the **INSTRUCTION TO VENDORS** and the **NORTH CAROLINA GENERAL TERMS AND CONDITIONS incorporated herein**. These documents can be accessed from the ATTACHMENTS page within this document.

**Failure to execute/sign bid prior to submittal may render bid invalid and it MAY BE REJECTED. Late bids cannot be accepted.**

COMPLETE/FORMAL NAME OF VENDOR:		
STREET ADDRESS:	P.O. BOX:	ZIP:
CITY & STATE & ZIP:	TELEPHONE NUMBER:	TOLL FREE TEL. NO:
PRINCIPAL PLACE OF BUSINESS ADDRESS IF DIFFERENT FROM ABOVE (SEE INSTRUCTIONS TO VENDORS ITEM #21):		
PRINT NAME & TITLE OF PERSON SIGNING ON BEHALF OF VENDOR:	FAX NUMBER:	
VENDOR’S AUTHORIZED SIGNATURE:	DATE:	E-MAIL:

Bid Number: 58-IFB252002-REBID

Vendor: \_\_\_\_\_

**VALIDITY PERIOD**

Offer shall be valid for at least sixty (60) days from date of bid opening, unless otherwise stated here: \_\_\_\_\_ days, or if extended by mutual agreement of the parties. Any withdrawal of this offer shall be made in writing, effective upon receipt by the agency issuing this IFB.

**BID ACCEPTANCE**

If your bid is accepted, all provisions of this IFB, along with the written results of any negotiations, shall constitute the written agreement between the parties ("Contract"). The NORTH CAROLINA GENERAL TERMS AND CONDITIONS are incorporated herein and shall apply. Depending upon the Goods or Services being offered, other terms and conditions may apply, as mutually agreed.

**FOR STATE USE ONLY:** Offer accepted and Contract awarded this \_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_, as indicated on the attached certification, by \_\_\_\_\_  
**(Authorized Representative of Fayetteville State University)**

**1.0 PURPOSE AND BACKGROUND ..... 5**

**2.0 GENERAL INFORMATION ..... 5**

2.1 INVITATION FOR BID DOCUMENT ..... 5

2.2 E-PROCUREMENT FEE ..... 5

2.3 NOTICE TO VENDORS REGARDING IFB TERMS AND CONDITIONS ..... 5

2.4 IFB SCHEDULE ..... 5

2.5 BID QUESTIONS ..... 6

2.7 BID SUBMITTAL ..... 6

2.8 BID CONTENTS ..... 7

2.9 ALTERNATE BIDS ..... 7

2.10 DEFINITIONS, ACRONYMS, AND ABBREVIATIONS ..... 8

**3.0 METHOD OF AWARD AND BID EVALUATION PROCESS ..... 8**

3.1 METHOD OF AWARD ..... 8

3.2 CONFIDENTIALITY AND PROHIBITED COMMUNICATIONS DURING EVALUATION ..... 8

3.3 BID EVALUATION PROCESS ..... 8

3.4 PERFORMANCE OUTSIDE THE UNITED STATES ..... 9

3.5 INTERPRETATION OF TERMS AND PHRASES ..... 10

**4.0 REQUIREMENTS ..... 10**

4.1 PRICING ..... 10

4.2 PRODUCT IDENTIFICATION ..... 10

4.4 TRANSPORTATION AND IDENTIFICATION ..... 10

4.5 DELIVERY ..... 10

4.6 AUTHORIZED RESELLER ..... 11

4.7 WARRANTY ..... 11

4.8 MAINTENANCE OPTION ..... 11

4.9 DESCRIPTIVE LITERATURE ..... 11

4.10 HUB PARTICIPATION ..... 12

4.11 REFERENCES ..... 12

4.12 VENDOR’S REPRESENTATIONS ..... 12

4.13 FINANCIAL STABILITY ..... 12

4.14 AGENCY INSURANCE REQUIREMENTS MODIFICATION ..... 12

**5.0 PRODUCT SPECIFICATIONS ..... 13**

5.1 SPECIFICATIONS ..... 13

5.2 CERTIFICATION AND SAFETY LABELS ..... 13

5.3 DEVIATIONS ..... 13

**6.0 CONTRACT ADMINISTRATION ..... 13**

6.1 CONTRACT MANAGER AND CUSTOMER SERVICE ..... 13

6.3 CONTINUOUS IMPROVEMENT ..... 14

6.6 INVOICES ..... 14

6.7 DISPUTE RESOLUTION ..... 14

6.8 PRODUCT RECALL ..... 15

6.9.1 PRICE ADJUSTMENTS ..... 15

6.10 CONTRACT CHANGES ..... 15

**7.0 ATTACHMENTS ..... 16**

**ATTACHMENT A: PRICING..... 16**

**ATTACHMENT B: INSTRUCTIONS TO VENDORS ..... 16**

**ATTACHMENT C: NORTH CAROLINA GENERAL TERMS & CONDITIONS ..... 16**

**ATTACHMENT D: HUB SUPPLEMENTAL VENDOR INFORMATION ..... 16**

**ATTACHMENT E: CUSTOMER REFERENCE FORM ..... 16**

**ATTACHMENT F: LOCATION OF WORKERS UTILIZED BY VENDOR..... 16**

**ATTACHMENT G: CERTIFICATION OF FINANCIAL CONDITION ..... 16**

**ATTACHMENT H: VENDOR REQUEST FOR EO50 PRICE-MATCHING..... 16**

**ATTACHMENT I: MEDIUM VOLTAGE PAD MOUNTED TRANSFORMER SPECIFICATIONS ..... 17**

## 1.0 PURPOSE AND BACKGROUND

The purpose of this Invitation for Bids is to seek competitive sealed bids from qualified vendors to furnish and deliver one (1) transformer meeting specifications outlined herein to be utilized for the University’s Health and Wellness Center. The University will pre-purchase the equipment identified in this IFB and provide it to others to install. Although the University wishes to have the equipment delivered within six months of award, we understand the current supply chain challenges and encourage all vendors to bid regardless of delivery capabilities.

The intent of this solicitation is to award an Agency Specific Contract.

## 2.0 GENERAL INFORMATION

### 2.1 INVITATION FOR BID DOCUMENT

The IFB is comprised of the base IFB document, any attachments, and any addenda released before Contract award, which are incorporated herein by reference.

### 2.2 E-PROCUREMENT FEE

**ATTENTION: The E-Procurement does not apply to this solicitation. See paragraph entitled ELECTRONIC PROCUREMENT of the North Carolina General Terms and Conditions.**

General information on the E-Procurement Services can be found at: <http://eprourement.nc.gov/>.

### 2.3 NOTICE TO VENDORS REGARDING IFB TERMS AND CONDITIONS

It shall be the Vendor’s responsibility to read the Instructions to Vendors, the North Carolina General Terms and Conditions, all relevant exhibits and attachments, and any other components made a part of this IFB and comply with all requirements and specifications herein. Vendors also are responsible for obtaining and complying with all Addenda and other changes that may be issued in connection with this IFB.

If Vendors have questions or issues, or exceptions regarding any component within this IFB, those must be submitted as questions in accordance with the instructions in the BID QUESTIONS Section. If the State determines that any changes will be made as a result of the questions asked, then such decisions will be communicated in the form of an IFB addendum. The State may also elect to leave open the possibility for later negotiation of specific provisions of the Contract that have been addressed during the question-and-answer period, prior to contact award.

Other than through this process or negotiation under 01 NCAC 05B.0503, the State rejects and will not be required to evaluate or consider any additional or modified terms and conditions submitted with Vendor’s bid. This applies to any language appearing in or attached to the document as part of the Vendor’s bid that purports to vary any terms and conditions or Vendors’ instructions herein or to render the bid non-binding or subject to further negotiation. Vendor’s bid shall constitute a firm offer that shall be held open for the period required herein (“Validity Period” above).


**The State may exercise its discretion to consider Vendor proposed modifications. By execution and delivery of this IFB Response, the Vendor agrees that any additional or modified terms and conditions, whether submitted purposely or inadvertently, shall have no force or effect, and will be disregarded unless expressly agreed upon through negotiations**

**and incorporated by way of a Best and Final Offer (BAFO). Noncompliance with, or any attempt to alter or delete, this paragraph shall constitute sufficient grounds to reject Vendor’s bid as nonresponsive.**

### 2.4 IFB SCHEDULE

The table below shows the *intended* schedule for this IFB. The State will make every effort to adhere to this schedule.

Event	Responsibility	Date and Time
Issue IFB	State	March 10, 2025

Submit Written Questions	Vendor	March 14, 2025, by 5:00 P.M. E.T.
Provide Responses to Questions	State	March 18, 2025 by 5:00 P.M. E.T.
Submit Bids	Vendor	March 21, 2025 by 11:00 A.M. E.T.
Virtual Public Bid Opening	State	<p>March 21, 2025 by 11:30 A.M. E.T.</p> <p><b>Virtual Public Bid Opening Details</b></p> <hr/> <p><b>Microsoft Teams <a href="#">Need help?</a></b>  <a href="#">Join the meeting now</a>  <b>Meeting ID: 263 636 413 824</b>  <b>Passcode: yN2iX2ZZ</b></p> <hr/> <p><b>Dial in by phone</b>  <a href="#">+1 910-491-9484,,938171794# United States, Fayetteville</a>  <a href="#">Find a local number</a>  <b>Phone conference ID: 938 171 794#</b>  <b>Join on a video conferencing device</b>  <b>Tenant key: <a href="mailto:uncfsu@m.webex.com">uncfsu@m.webex.com</a></b>  <b>Video ID: 114 674 624 8</b>  <a href="#">More info</a>  <b>For organizers: <a href="#">Meeting options</a>   <a href="#">Reset dial-in PIN</a></b></p>  <p><a href="#">Org help</a>   <a href="#">Privacy and security</a></p>
Contract Award	State	TBD

**2.5 BID QUESTIONS**

Upon review of the IFB documents, Vendors may have questions to clarify or interpret the IFB in order to submit the best bid possible. To accommodate the Bid Questions process, Vendors shall submit any such questions by the “Submit Written Questions” date and time provided in the IFB SCHEDULE Section above, unless modified by Addendum.

Written questions shall be e-mailed to [purchasing@uncfsu.edu](mailto:purchasing@uncfsu.edu) by the date and time specified above. Vendors will enter “**IFB #58-IFB252002-REBID: Questions**” as the subject for the email. Question submittals will include a reference to the applicable IFB section and be submitted in a format shown below:

Reference	Vendor Question
IFB Section, Page Number	Vendor question ...?

Questions received prior to the submission deadline date, the State’s response, and any additional terms deemed necessary by the State will be posted in the form of an addendum to *the electronic Vendor Portal (eVP)*, <https://evp.nc.gov>, and shall become an Addendum to this IFB. No information, instruction or advice provided orally or informally by any State personnel, whether made in response to a question or otherwise in connection with this IFB, shall be considered authoritative or binding. Vendors shall rely *only* on written material contained in an Addendum to this IFB.

**2.7 BID SUBMITTAL**

**IMPORTANT NOTE: This is an absolute requirement.** Vendor shall bear the risk of late submission due to unintended or unanticipated delay. It is the Vendor’s sole responsibility to ensure its bid has been received as described in this IFB by the

specified time and date of opening. The date and time of receipt will be marked on each bid when received. Any bid or portion thereof received after the bid submission deadline will be rejected.

## **BONFIRE**

All proposal responses shall be submitted electronically via the University's Bonfire Portal). Please see link below:

<https://uncfsu.bonfirehub.com/portal/?tab=openOpportunities>

Failure to submit a bid in strict accordance with these instructions shall constitute sufficient cause to reject a Vendor's bid(s). Vendors are strongly encouraged to allow sufficient time to upload bids.

Critical updated information may be included in Addenda to this IFB. It is important that all Vendors responding on this IFB periodically check the State's eVP website for any Addenda that may be issued prior to the bid opening date. All Vendors shall be deemed to have read and understood all information in this IFB and all Addenda thereto.

### **2.8 BID CONTENTS**

Vendors shall populate all attachments of this IFB that require the Vendor to provide information and include an authorized signature where requested. Failure to provide all required items, or Vendor's submission of incomplete items, may result in the State rejecting Vendor's bid, in the State's sole discretion

Vendor IFB responses shall include the following items and attachments, which shall be arranged in the following order:

- a) Cover Letter, which must contain all of the following; (i) a statement that confirms that the Vendor has read the IFB in its entirety, including all links, and all Addenda released in conjunction with the IFB; (ii) a statement that the Vendor agrees to perform in accordance with the scope of work, requirements, and specifications contained herein; and (iii) Vendor's agreement to comply with all instructions, terms and conditions, and attachments.
- b) Title Page: Include the company name, address, phone number and authorized representative along with the Bid Number.
- c) Completed and signed version of EXECUTION PAGES, along with the body of the IFB.
- d) Signed receipt pages of any addenda released in conjunction with this IFB, if required to be returned.
- e) Vendor Response (See Section 4.0 Requirements for details)
- f) Completed version of ATTACHMENT A: PRICING
- g) Completed version of ATTACHMENT D: HUB SUPPLEMENTAL VENDOR INFORMATION
- h) Completed version of ATTACHMENT E: CUSTOMER REFERENCE FORM
- i) Completed version of ATTACHMENT F: LOCATION OF WORKERS UTILIZED BY VENDOR
- j) Completed and signed version of ATTACHMENT G: CERTIFICATION OF FINANCIAL CONDITION
- k) Completed and signed version of ATTACHMENT H: VENDOR REQUEST FOR EO50 PRICE-MATCHING, if applicable

### **2.9 ALTERNATE BIDS**

Unless provided otherwise in this IFB, Vendor may submit alternate bids for comparable Goods, various methods or levels of Service(s), or that propose different options. Alternate bids must specifically identify the IFB requirements and advantage(s) addressed by the alternate bid. Any alternate bid, in addition to the marking described above, must be clearly marked with the legend: "Alternate Bid # \_\_\_ [for 'name of Vendor']". Each bid must be for a specific set of Goods and Services and must include specific pricing. If a Vendor chooses to respond with various offerings, each must be offered with a separate price and be contained in a separate bid. Each bid must be complete and independent of other bids offered.

## **2.10 DEFINITIONS, ACRONYMS, AND ABBREVIATIONS**

Relevant definitions for this IFB are provided in 01 NCAC 05A .0112 and in the Instructions to Vendors referenced below which are incorporated herein by this reference.

## **3.0 METHOD OF AWARD AND BID EVALUATION PROCESS**

---

### **3.1 METHOD OF AWARD**

North Carolina G.S. 143-52 provides a general list of criteria the State shall use to award contracts, as supplemented by the additional criteria herein. The Goods or Services being procured shall dictate the application and order of criteria; however, all award decisions shall be in the State’s best interest.

All responsive bids will be reviewed, and award or awards will be based on the responsive bid(s) offering the lowest price that meets the specifications to include any required verifications set out herein such as but not limited to past performance, references, and financial documents.

While the intent of this IFB is to award a Contract(s) to a single Vendor for all line items, the State reserves the right to make separate awards to different Vendors for one or more line items, to not award one or more line items or to cancel this IFB in its entirety without awarding a Contract, if it is considered to be most advantageous to the State to do so.

If a Vendor selected for award is determined by the State to be a non-resident of North Carolina, all responsive bids will be reviewed to determine if any of them were submitted by a North Carolina resident Vendor who requested an opportunity to match the price of the winning bid, pursuant to Executive Order #50 and G.S. 143-59 (for more information, please refer to ATTACHMENT H: VENDOR REQUEST FOR EXECUTIVE ORDER #50 PRICE MATCHING. If such bid(s) are identified, the State will then determine whether any such bid falls within the price-match range, and, if so, make a Contract award in accordance with the process that implements G.S. 143-59 and Executive Order #50.

The State reserves the right to waive any minor informality or technicality in bids received.

### **3.2 CONFIDENTIALITY AND PROHIBITED COMMUNICATIONS DURING EVALUATION**

While this IFB is under evaluation, the responding Vendor, including any subcontractors and suppliers, is prohibited from engaging in conversations intended to influence the outcome of the evaluation. See the Paragraph 29 of the Instructions To Vendors entitled COMMUNICATIONS BY VENDORS.

Each Vendor submitting a bid to this IFB, including its employees, agents, subcontractors, suppliers, subsidiaries and affiliates, is prohibited from having any communications with any person inside or outside the using agency; issuing agency; other government agency office or body (including the purchaser named above, any department secretary, agency head, members of the General Assembly and Governor’s office); or private entity, if the communication refers to the content of Vendor’s bid or qualifications, the content of another Vendor’s proposal, another Vendor’s qualifications or ability to perform a resulting contract, and/or the transmittal of any other communication of information that could be reasonably considered to have the effect of directly or indirectly influencing the evaluation of proposals, the award of a contract, or both.

Any Vendor not in compliance with this provision shall be disqualified from evaluation and award. A Vendor’s proposal may be disqualified if its subcontractor and/or supplier engage in any of the foregoing communications during the time that the procurement is active (*i.e.*, the issuance date of the procurement until the date of contract award or cancellation of the procurement). Only those discussions, communications or transmittals of information authorized or initiated by the issuing agency for this IFB or inquiries directed to the purchaser named in this IFB regarding requirements of the IFB (prior to proposal submission) or the status of the award (after submission) are excepted from this provision.

### **3.3 BID EVALUATION PROCESS**

Only responsive submissions will be evaluated.

**The State will conduct an evaluation of responsive Bids, as follows:**

Bids will be received according to the method stated in the Bid Submittal section above.

All bids must be received by the issuing agency not later than the date and time specified in the IFB SCHEDULE Section above, unless modified by Addendum. Vendors are cautioned that this is a request for offers, not an offer or request to contract, and the State reserves the unqualified right to reject any and all offers at any time if such rejection is deemed to be in the best interest of the State.

At the date and time provided in the IFB SCHEDULE Section above, unless modified by Addendum, the bids from each responding Vendor will be opened publicly and all offers (except those that have been previously withdrawn, or voided bids) will be tabulated. The tabulation shall be made public at the time it is created. When negotiations after receipt of bids is authorized pursuant to G.S. 143-49 and 01 NCAC 05B.0503, only the names of offerors and the Goods and Services offered shall be tabulated at the time of opening. If negotiation is anticipated, cost and price shall become available for public inspection at the time of the award. Interested parties are cautioned that these costs and their components are subject to further evaluation for completeness and correctness and therefore may not be an exact indicator of a Vendor's pricing position.

At their option, the evaluators may request oral presentations or discussions with any or all Vendors for clarification or to amplify the materials presented in any part of the bid. Vendors are cautioned, however, that the evaluators are not required to request presentations or other clarification—and often do not. Therefore, all bids should be complete and reflect the most favorable terms available from the Vendor. Prices bid cannot be altered or modified as part of a clarification.

Bids will generally be evaluated, based on completeness, content, cost and responsibility of the Vendor to supply the requested Goods and Services. Specific evaluation criteria are listed in Section 3.1 METHOD OF AWARD.

Upon completion of the evaluation process, the State will make Award(s) based on the evaluation and post the award(s) to the State's eVP website under the IFB number for this solicitation. Award of a Contract to one Vendor does not mean that the other bids lacked merit, but that, all factors considered, the selected bid was deemed most advantageous and represented the best value to the State.

The State reserves the right to negotiate with one or more Vendors, or to reject all original offers and negotiate with one or more sources of supply that may be capable of satisfying the requirement, and in either case to require Vendor to submit a Best and Final Offer (BAFO) based on discussions and negotiations with the State.

**3.4 PERFORMANCE OUTSIDE THE UNITED STATES**

Vendor shall complete ATTACHMENT F: LOCATION OF WORKERS UTILIZED BY VENDOR. In addition to any other evaluation criteria identified in this IFB, the State may also consider, for purposes of evaluating proposed or actual contract performance outside of the United States, how that performance may affect the following factors to ensure that any award will be in the best interest of the State:

- a) Total cost to the State
- b) Level of quality provided by the Vendor
- c) Process and performance capability across multiple jurisdictions
- d) Protection of the State's information and intellectual property
- e) Availability of pertinent skills
- f) Ability to understand the State's business requirements and internal operational culture
- g) Particular risk factors such as the security of the State's information technology
- h) Relations with citizens and employees
- i) Contract enforcement jurisdictional issues

**3.5 INTERPRETATION OF TERMS AND PHRASES**

This IFB serves two functions: (1) to advise potential Vendors of the parameters of the solution being sought by the State; and (2) to provide (together with other specified documents) the terms of the Contract resulting from this procurement. The use of phrases such as “shall,” “must,” and “requirements” are intended to create enforceable contract conditions. In determining whether bids should be evaluated or rejected, the State will take into consideration the degree to which Vendors have proposed or failed to propose solutions that will satisfy the State’s needs as described in the IFB. Except as specifically stated in the IFB, no one requirement shall automatically disqualify a Vendor from consideration. However, failure to comply with any single requirement may result in the State exercising its discretion to reject a bid in its entirety.

**4.0 REQUIREMENTS**

---

This Section lists the requirements related to this IFB. By submitting a bid, the Vendor agrees to meet all stated requirements in this Section, as well as any other specifications, requirements, and terms and conditions stated in this IFB. If a Vendor is unclear about a requirement or specification, or believes a change in a requirement would allow for the State to receive a better bid, the Vendor is encouraged to submit these items in the form of a question during the question and answer period in accordance with the Bid Questions Section above.

**4.1 PRICING**

Bid price shall constitute the total cost to the State for delivery fully assembled and ready for use, including all applicable charges for shipping, delivery, handling, administrative and other similar fees. Complete ATTACHMENT A: PRICING FORM and include in Vendor’s response.

**4.2 PRODUCT IDENTIFICATION**

**SUITABILITY FOR INTENDED USE**

Vendors are requested to offer only items directly complying with the specifications herein or comparable items which will provide the equivalent capabilities, features and diversity called for herein. The State reserves the right to evaluate all bids for suitability for the required use and to award the one best meeting requirements and considered to be in the State’s best interest.

**4.4 TRANSPORTATION AND IDENTIFICATION**

The Vendor shall deliver Free-On-Board (FOB) Destination to any requested location within the State of North Carolina with all transportation costs and fees included in the total bid price.

When an order is placed using a purchase order, the purchase order number shall be shown on all packages and shipping manifests to ensure proper identification and payment of invoices. If an order is placed without using a purchase order, such as via phone, the Buyer’s name shall be show on all packages. A complete packing list shall accompany each shipment. Vendors shall not ship any products until they have received an order.

**4.5 DELIVERY**

The Vendor shall deliver Free-On-Board (FOB) Destination to the following location(s):

**Fayetteville State University  
1200 Murchison Road  
Fayetteville, NC 28301**

Vendor should complete delivery within one hundred eighty (180) consecutive calendar days after receipt of purchase order.

For completion by Vendor: Delivery will be made from \_\_\_\_\_ (city, state) within \_\_\_\_\_ consecutive calendar days after receipt of purchase order. Promptness of delivery may be used as a factor in the award criteria.

**4.6 AUTHORIZED RESELLER**

The Vendor shall be authorized by the manufacturer to distribute or resell the products and/or maintenance offered in this IFB. The Vendor shall provide a signed statement from the manufacturer confirming authorization upon request from the agency. Failure to provide this statement shall constitute sufficient grounds for rejection of Vendor’s offer, at the discretion of the State.

Vendor is the:  Manufacturer  Dealer  Reseller  Distributor

Authorized:  Yes  No Attached Manufacturer’s Authority:  Yes  No

**4.7 WARRANTY.**

Vendor warrants that all equipment furnished under this IFB will be newly manufactured, of good material and workmanship. The warranty will apply from date equipment is put into operation for a minimum period of twelve (12) months or the length of the manufacturer’s warranty, whichever is longer. Such warranty shall cover the cost of all defective parts replacement, labor, freight, and technicians’ travel at no additional cost to the State, or as specified by the Purchasing Agency herein. To the extent not superseded by the terms of this paragraph, manufacturer’s warranty terms shall apply. Vendor’s warranty shall be at least the level of coverage provided for its comparable customers.

The report of a problem does not presuppose that every call must result in an “on-site” visit for service/repair. The Vendor and/or service sub-contractor shall utilize best efforts to resolve problems in a timely fashion by using acceptable servicing methods to include, but not limited to, verbal problem analysis and remote diagnosis. The warranty requirement does not impose any additional duty on the State to make other than normal and good faith problem resolution efforts or expenditures of time. Vendor shall be responsible for compliance with warranty terms by any third-party service provider. Vendor shall provide contact information for warranty service provider, below.

Vendor is authorized by manufacturer to repair equipment offered during the warranty period?  YES  NO

Will the Vendor provide warranty service?  YES  NO, a manufacturer-authorized third party will perform warranty service.

**Contact information** for warranty service provider:

Company Name: \_\_\_\_\_

Company Address: \_\_\_\_\_

\_\_\_\_\_

Contact Person (name): \_\_\_\_\_

Contact Person (phone number): \_\_\_\_\_

Contact Person (email): \_\_\_\_\_

**4.8 MAINTENANCE OPTION**

Following expiration of the above warranty, Vendor, or its third-party service provider, shall maintain the system specifications and performance level in accordance with the manufacturer’s published specifications and those of this IFB. Maintenance shall include all parts, remedial maintenance labor, travel and living expenses incurred. Except as specifically provided for elsewhere herein, coverage shall be at least for 8:00 am ET to 5:00 pm ET, Monday through Friday, except State recognized holidays and shall include a minimum of two (2) preventive and safety maintenance inspections per year. The State shall have the option to accept the maintenance coverage in this paragraph at the price offered in ATTACHMENT A: PRICING of this IFB, if applicable.

**4.9 DESCRIPTIVE LITERATURE**

**DESCRIPTIVE LITERATURE/CERTIFICATION**

Each bid shall be accompanied by complete descriptive literature, specifications, certifications, and all other pertinent data necessary for thorough evaluation of the item(s) offered and sufficient to determine compliance of the item(s) with the specifications. Failure to include such information to shall be a sufficient basis for rejection of the bid.

**4.10 HUB PARTICIPATION**

Pursuant to North Carolina General Statute G.S. 143-48, it is State policy to encourage and promote the use of small, minority, physically handicapped, and women contractors in purchasing Goods and Services. As such, this IFB will serve to identify those Vendors that are minority owned or have a strategic plan to support the State’s Historically Underutilized Business program by meeting or exceeding the goal of 10% utilization of diverse firms as 1st or 2nd tier subcontractors. Vendor shall complete ATTACHMENT D: HUB SUPPLEMENTAL VENDOR INFORMATION.

**4.11 REFERENCES**

Vendors shall provide at least three (3) references, using ATTACHMENT E: CUSTOMER REFERENCE FORM, for which your company has supplied the exact model of equipment offered. The State *may* contact these users to determine quality level of the offered equipment; as well as, but not limited to user satisfaction with Vendor performance. Information obtained *may* be considered in the evaluation of the bid.

**4.12 VENDOR’S REPRESENTATIONS**

If the bid results in an award, Vendor agrees that it will not enter any agreement with a third party that may abridge any rights of the State under the Contract. If any Services, deliverables, functions, or responsibilities not specifically described in this solicitation are required for Vendor’s proper performance, provision and delivery of the Service and deliverables under a resulting Contract, or are an inherent part of or necessary sub-task included within such service, they will be deemed to be implied by and included within the scope of the contract to the same extent and in the same manner as if specifically described in the Contract. Unless otherwise expressly provided herein, Vendor will furnish all of its own necessary management, supervision, labor, facilities, furniture, computer and telecommunications equipment, software, supplies and materials necessary for the Vendor to provide and deliver the Services and/or other Deliverables.

**4.13 FINANCIAL STABILITY**

As a condition of contract award, the Vendor must certify that it has the financial capacity to perform and to continue to perform its obligations under the Contract; that Vendor has no constructive or actual knowledge of an actual or potential legal proceeding being brought against Vendor that could materially adversely affect performance of this Contract; and that entering into this Contract is not prohibited by any contract, or order by any court of competent jurisdiction

Each Vendor shall certify it is financially stable by completing the ATTACHMENT G: CERTIFICATION OF FINANCIAL CONDITION. The State is requiring this certification to minimize potential performance issues from contracting with a Vendor that is financially unstable. This Certification shall be deemed continuing, and from the date of the Certification to the expiration of the Contract, the Vendor shall notify the State within thirty (30) days of any occurrence or condition that materially alters the truth of any statement made in this Certification.

**4.14 AGENCY INSURANCE REQUIREMENTS MODIFICATION**

A. Default Insurance Coverage from the General Terms and Conditions applicable to this Solicitation:

- Small Purchases
- Contract value in excess of the Small Purchase threshold, but up to \$1,000,000.00
- Contract value in excess of \$1,000,000.00

B. The Purchasing Agency has conducted a risk assessment and determined that certain default coverage provisions in the North Carolina General Terms and Conditions, paragraph entitled *Insurance*, should be increased from the minimums stated. Increased or additional insurance coverage amounts for this Solicitation are as follows. Coverages not changed here remain as stated in the General Terms and Conditions.

- a) **Employer’s Liability**                                 \$ \_\_\_\_\_
- b) **Commercial General Liability**                 \$ \_\_\_\_\_ Combined Single Limit
- c) **Automobile**   \$ \_\_\_\_\_ Bodily injury and property damage  
    \$ \_\_\_\_\_ Uninsured/under insured motorist  
    \$ \_\_\_\_\_ Medical payment

**5.0 PRODUCT SPECIFICATIONS**

---

**5.1 SPECIFICATIONS**

The specific items and any specifications that the Purchasing Agency is seeking are listed below. Items offered by the Vendor must meet or exceed the listed Specifications.

<i>Item #</i>	<i>Specifications</i>
1	<i>1 (One) Medium Voltage Pad Mounted Transformer that meets specifications identified within attachment labeled ATTACHMENT I: MEDIUM VOLTAGE PAD MOUNTED TRANSFORMER SPECIFICATIONS</i>

**5.2 CERTIFICATION AND SAFETY LABELS**

All manufactured items and/or fabricated assemblies subject to operation under pressure, operation by connection to an electric source, or operation involving a connection to a manufactured, natural, or LP gas source shall be constructed and approved in a manner acceptable to the appropriate state inspector which customarily requires the label or re-examination listing or identification marking of the appropriate safety standard organization; such as the American Society of Mechanical Engineers for pressure vessels; the Underwriters Laboratories and /or National Electrical Manufacturers’ Association for electrically operated assemblies; or the American Gas Association for gas operated assemblies, where such approvals of listings have been established for the type of device offered and furnished. Further, all items furnished shall meet all requirements of the Occupational Safety and Health Act (OSHA), and state and federal requirements relating to clean air and water pollution.

**5.3 DEVIATIONS**

The nature of all deviations from the Specifications listed herein shall be clearly described by the Vendor. Otherwise, it will be considered that items offered by the Vendor are in strict compliance with the Specifications provided herein, and the successful Vendor shall be required to supply conforming goods. Deviations shall be explained in detail on an attached sheet. However, no implication is made or intended by the State that any deviation will be acceptable. Do not list objections to the North Carolina General Terms and Conditions in this section.

**6.0 CONTRACT ADMINISTRATION**

---

All Contract Administration requirements are conditioned on an award resulting from this solicitation. This information is provided for the Vendor’s planning purposes

**6.1 CONTRACT MANAGER AND CUSTOMER SERVICE**

The Vendor shall be required to designate and make available to the State a contract manager. The contract manager shall be the State’s point of contact for Contract related issues and issues concerning performance, progress review, scheduling, and service.

<b>Contract Manager Point of Contact</b>	
Name:	
Office Phone #:	
Mobile Phone #:	
Email:	

<p>The Vendor shall be required to designate and make available to the State for customer service. The customer service point of contact shall be the State’s point of contact for customer service-related issues (define roles and responsibilities).</p>	
<b>Customer Service Point of Contact</b>	
Name:	
Office Phone #:	
Mobile Phone #:	
Email:	

**6.3 CONTINUOUS IMPROVEMENT**

The State encourages the Vendor to identify opportunities to reduce the total cost the State. A continuous improvement effort consisting of various ideas to enhance business efficiencies as performance progresses.

**6.6 INVOICES**

Vendor shall invoice the Purchasing Agency. The standard format for invoicing shall be Single Invoices meaning that the Vendor shall provide the Purchasing Agency with an invoice for each order. Invoices shall include detailed line item information to allow Purchasing Agency to verify pricing at point of receipt matches the correct price from the original date of order. At a minimum, the following fields shall be included on all invoices:

Vendor’s Billing Address, Customer Account Number, NC Contract Number, Order Date, Buyer’s Order Number, Manufacturer Part Numbers, Vendor Part Numbers, Item Descriptions, Price, Quantity, and Unit of Measure.

**INVOICES MAY NOT BE PAID UNTIL AN INSPECTION HAS OCCURRED AND THE GOODS ACCEPTED.**

**6.7 DISPUTE RESOLUTION**

During the performance of the Contract, the Parties agree that it is in their mutual interest to resolve disputes informally. Any claims by the Vendor shall be submitted in writing to the State’s Contract Manager for resolution. Any claims by the State shall be submitted in writing to the Vendor’s Project Manager for resolution. The Parties shall agree to negotiate in good faith and use all reasonable efforts to resolve such dispute(s).

During the time the Parties are attempting to resolve any dispute, each shall proceed diligently to perform their respective duties and responsibilities under this Contract. The Parties will agree on a reasonable amount of time to resolve a dispute. If a dispute cannot be resolved between the Parties within the agreed upon period, either Party may elect to exercise any other remedies available under the Contract, or at law. This provision, when agreed in the Contract, shall not constitute an agreement by either party to mediate or arbitrate any dispute.

**6.8 PRODUCT RECALL**

Vendor expressly assumes full responsibility for prompt notification to the Buyer listed on the face of this IFB of any product recall in accordance with the applicable state or federal regulations. The Vendor shall support the State, as necessary, to promptly replace any such products, at no cost to the State.

**6.9.1 PRICE ADJUSTMENTS**

Prices proposed by the Vendor shall be firm against any increase for three hundred sixty-five (365) days from the effective date of the Contract.

Price increase requests shall be submitted in writing to the Contract Lead, which shall include the reason(s) for the request and contain supporting documentation for the need. Price increases will be negotiated and agreed to by both the State and Vendor in advance of any price increase going into effect. The State is not obligated to accept pricing adjustments or increases and reserves the right to accept or reject them in part or in whole. Price de-escalation or decreases may be requested by the State at any time.

It is understood and agreed that orders will be shipped at the established Contract prices in effect on the date an order is placed. Invoicing that deviates from this provision may result in Contract to cancellation.

**6.10 CONTRACT CHANGES**

Contract changes, if any, over the life of the Contract shall be implemented by contract amendments agreed to in writing by the State and Vendor. Amendments to the contract can only be made through the contract administrator.

**The remainder of this page is intentionally left blank**

## 7.0 ATTACHMENTS

---

### **\*\*IMPORTANT NOTICE\*\***

**RETURN THE REQUIRED ATTACHMENTS WITH YOUR RESPONSE**  
FOLLOW THE LINKS TO ACCESS EACH ATTACHMENT

#### **ATTACHMENT A: PRICING**

---

Complete and return the Pricing associated with this IFB, which can be found in the table below:

Item #	Description	Qty	Manufacturer	Model Number	Delivery Time in Days	Price
1	Medium Voltage Pad Mounted Transformer	1				

#### **ATTACHMENT B: INSTRUCTIONS TO VENDORS**

---

The Instructions to Vendors, which are incorporated herein by this reference, may be found here:

<https://ncadmin.nc.gov/formnorth-carolina-instructions-vendors032023/download?attachment>

#### **ATTACHMENT C: NORTH CAROLINA GENERAL TERMS & CONDITIONS**

---

The North Carolina General Terms and Conditions, which are incorporated herein by this reference, may be found here:

<https://www.doa.nc.gov/form-north-carolina-general-terms-and-conditions-11-2023/open>

#### **ATTACHMENT D: HUB SUPPLEMENTAL VENDOR INFORMATION**

---

Complete and return the Historically Underutilized Businesses (HUB) Vendor Information form, which can be found at the following link:

<https://www.doa.nc.gov/pandc/onlineforms/form-hub-supplemental-vendor-information-9-2021/download>

#### **ATTACHMENT E: CUSTOMER REFERENCE FORM**

---

Complete and return the Customer Reference Form, which can be found at the following link:

<https://ncadmin.nc.gov/media/15503/open>

#### **ATTACHMENT F: LOCATION OF WORKERS UTILIZED BY VENDOR**

---

Complete and return the Location of Workers Utilized by Vendor, which can be found at the following link:

<https://www.doa.nc.gov/pandc/onlineforms/form-location-workers-09-2021/download>

#### **ATTACHMENT G: CERTIFICATION OF FINANCIAL CONDITION**

---

Complete, sign, and return the Certification of Financial Condition, which can be found at the following link:

<https://www.doa.nc.gov/pandc/onlineforms/form-certification-financial-condition-09-2021/download>

#### **ATTACHMENT H: VENDOR REQUEST FOR EO50 PRICE-MATCHING**

---

Complete, sign, and return the Vendor Request for EO50 Price-Matching, which can be found at the following link:

[https://files.nc.gov/ncdoa/pandc/OnlineForms/Form\\_Vendor-Price-Matching-Opportunity\\_09.2021.pdf](https://files.nc.gov/ncdoa/pandc/OnlineForms/Form_Vendor-Price-Matching-Opportunity_09.2021.pdf)

**ATTACHMENT I: MEDIUM VOLTAGE PAD MOUNTED TRANSFORMER SPECIFICATIONS**

---

*Specification details provided for bidding purposes only.*

**\*\*\* Failure to Return the Required Attachments May Eliminate  
Your Response from Further Consideration \*\*\***

## ATTACHMENT I

### SECTION 260517 – MEDIUM VOLTAGE PAD MOUNTED TRANSFORMERS

#### PART 1: GENERAL

##### 1.1 SCOPE:

- A. The Transformer is to be Owner-furnished and Contractor-installed, as herein specified and as indicated on drawings, a 12,470Y/7,200 volt, 3 phase, 4 wire primary to 480Y/277 volt, 3 phase, 4 wire secondary compartmental pad mounted transformer.

#### PART 2: PRODUCTS

##### 2.1 COMPARTMENTAL TRANSFORMERS:

- A. Transformer construction and installation shall comply with latest applicable standards of NEMA and ANSI/IEEE including:
  - a. C57.12.00 Standard General Requirements for Liquid Immersed Distribution, Power, and Regulating Transformers.
  - b. C57.12.10 Standard Requirement for Liquid Immersed Transformers
  - c. C57.12.28 Switchgear and Transformers, Pad-Mounted Equipment—Enclosure Integrity.
  - d. C57.12.70 Standard for Standard Terminal Markings and Connections for Distribution and Power Transformers
- B. Transformer tests shall be performed in accordance with C57.12.90 Standard Test Code for Liquid-Immersed Distribution, Power, and Regulating Transformer.
- C. Transformers shall be NCBCC approved third-party listed. Comply with NCGS 133-3 when using brand name specifications.
- D. All characteristics, definitions, terminology, and voltage designations and tests, except as otherwise specified herein, shall be in accordance with the following American National Standard Requirements, Terminology, and Test Code for Distribution, Power and Regulating Transformers:
  - 1. General Requirements C57.12.00 (IEEE Std. 462) (latest revision).
  - 2. Terminal Markings and Connections, C57.12.70 (latest revisions).
  - 3. Terminology, C57.12.80, including Supplement C57.12.80a (latest revision).
  - 4. Test Code, C57.12.90 (IEEE Std 262) (latest revision).
- E. The transformer tank shall be of a sealed-tank construction as specified in ANSI Standard C57.12.26. The tank shall be a minimum of 12-gauge sheet steel, and strong enough to withstand a pressure of 7 psi without permanent distortion and 15 psi without rupturing or displacing of transformer components. A removable main cover may be provided over a bolted-on, tamperproof handhold. Handholds shall be provided for access to high voltage isolation links, three-phase switches, neutral connections, etc. The high and low voltage compartments shall be located side by side, separated by a steel barrier. When facing the transformer, the low voltage compartments shall be on the right. Terminal compartments shall be full height, air-filled, with individual doors. The high voltage door fastenings shall not be accessible until the low voltage door has been opened.
- F. Transformer tank grounding provisions shall be in accordance with ANSI standards. The grounding provisions shall be capped before painting the unit.

- 1 G. The core and coil assembly shall be of a five-legged wound core type design to provide  
2 adequate short-circuit strength and heat dissipation. Transformers connected wye-wye shall  
3 be built with five-legged core-type design to avoid the tank heating problems sometimes  
4 associated with wye-wye connections. When required, corrugated cooling panels shall be  
5 provided on the back and sides of the oil-filled tank to maintain a safe operating temperature.  
6 Internal leads shall be insulated, trained, and anchored to prevent phase-to-phase flashover.  
7
- 8 H. Transformers are to be equipped with four (4) taps rated approximately 2-1/2 percent, with  
9 two (2) above and two (2) below normal. The tap changer shall be externally hook stick  
10 operated and located in the high voltage compartment. The tap changer shall be designed  
11 and marked for de-energized operation. As part of the transformer installation, perform a  
12 turns ratio test between windings at all tap positions with the final tap setting to be set at the  
13 secondary system rated voltage at full load.  
14
- 15 I. The high voltage terminations and equipment shall be of the dead front construction.  
16
- 17 J. Two high voltage bushings per phase shall be provided to permit operating a loop feed dead  
18 front transformer from a looped primary cable system. The high voltage bushings shall be  
19 one-piece type for use with load-break elbow terminators. As an optional method, provide a  
20 radial feed transformer, where applicable, with one bushing well and one load-break feed-thru  
21 insert per phase. Construction shall conform to ANSI/IEEE Standard 386. Bushings shall be  
22 externally clamped and externally removable. High and low voltage winding lead lengths shall  
23 be long enough to permit field replacement of bushings or bushing wells. All gasketed joints  
24 are to afford a sealed tank in accordance with industry standards. Gasket material must be  
25 durable and reusable. Parking stands shall be provided for mounting accessory equipment.  
26
- 27 K. Transformer overcurrent protection shall be a combination of oil-immersed current-limiting  
28 fuses in series with bayonet oil-immersed, overload sensing, expulsion fuses coordinated to  
29 provide full range protection with the expulsion fuse clearing low-current faults and the  
30 current limiting fuses clearing high-current faults up to 50,000 amperes. The fuse assembly  
31 shall have an interrupting rating of (3500A at 8.3 KV) or (1800 A at 15.5 KV) single phase,  
32 and a load break rating of 125A at 80% power-factor for (8.3 KV or 15.5 KV) single phase.  
33 The bayonet fuses must be accessible through the primary compartment. They must be  
34 externally removable and field replaceable using a hot stick. This operation must be  
35 accomplished without having to remove the transformer compartment top. A welded-on oil  
36 drip shield must be located under the bayonet fuse to protect the primary connections.  
37
- 38 L. For wye-wye connected transformers, the high voltage neutral shall be connected internally  
39 to the low voltage neutral with provisions for opening this connection for testing. The neutral  
40 bushing shall be fully insulated but connected to an adjacent ground pad (on the tank) with a  
41 detachable strap sized to carry the maximum fault current available from the transformer.  
42
- 43 M. Full-height, air-filled incoming and outgoing terminal compartments with hinged doors shall be  
44 located side-by-side separated by a steel barrier, with the incoming compartment on the left.  
45 The high-voltage (incoming) compartment will be accessible only after the door to the low-  
46 voltage (outgoing) compartment has been opened. To facilitate making connections and  
47 permit cable pulling, the doors and compartment hood shall be removable. Removable door  
48 sill on compartments shall be provided to permit rolling or skidding of unit into place over  
49 conduit studs in foundation.  
50
- 51 N. The compartments will have hinged doors equipped for latching in the open position. The  
52 high-voltage compartment door will have a fastening device which is accessible only through  
53 the low-voltage compartment.  
54
- 55 O. The hinge assemblies shall be made of corrosion-resistant material. Stainless-steel hinge  
56 pins of 3/8 inch minimum diameter will be provided.

- 1  
2 P. Both compartment doors must be capable of being secured with a single padlock having a  
3 maximum 1/2 inch diameter shackle.  
4  
5 Q. Equipment to be furnished as standard shall include:  
6  
7 a. A 1-inch drain valve with sampling device on units rated 750 kVA and above and 1-  
8 inch filler plug provided on 75–500 kVA.  
9 b. Magnetic liquid level indicator.  
10 c. Dial type thermometer.  
11 d. Pressure vacuum gauge.  
12 e. Lifting, pulling, and jacking provisions.  
13 f. Pressure-relief device suitable for the transformer as recommended by transformer  
14 manufacturer that will automatically relieve pressure and effectively keep the  
15 transformer sealed with no leakage of air or oil or any permanent distortion. Any  
16 pressure-relief device must exclude moisture from the transformer and have a life  
17 equal to the transformer.  
18  
19 R. The instruction nameplate shall be permanently attached and located in the low-voltage  
20 portion of the compartment and shall be readable with cables in place.  
21

22 2.2 TRANSFORMER RATINGS:

- 23  
24 A. Transformer shall be rated 500 KVA, 60 Hz, 12470/7200 volt, 3 phase, 4-wire "WYE" primary  
25 480/277 volt, 3 phase, 4-wire "WYE" secondary and of five-legged core construction.  
26  
27 B. Impedance shall be 5.75% minimum.  
28  
29 C. Transformer insulating fluid shall be "R-Temp" or any \*listed ("less flammable liquid" similar to  
30 BIOTEMP, or FR3, with a fire point of not less than 300-degree C when tested according to  
31 ASTM D92. The less-flammable insulated transformer installation shall comply with the  
32 installation criteria of the NCBCCC approved third-party testing agency per NEC 450-23.  
33 \* NCBCCC approved third-party testing agencies  
34

35 2.6 METERING:

- 36  
37 A. The low voltage bushing compartment shall contain current transformers along with mounting  
38 provisions for metering.  
39  
40 B. Potential transformers shall be provided as required by meter system voltage. When  
41 required, suitable mounting provisions shall be provided with low voltage compartment.  
42  
43 C. Kilo-watt hour demand meter shall be 3 static-seven jaw-type per voltage indicated, with 30  
44 minute demand register, UL listed for wet locations, and be transformer rated as applicable.  
45 Provide a weatherproof type "S" socket assembly.  
46

47 PART 3: EXECUTION

48  
49 3.1 TRANSFORMER:

- 50  
51 A. All installation shall be strictly in accordance with the recommendations of the manufacturer.  
52  
53 B. Contractor shall construct concrete pads as required. Pads shall be not less than 8 inches in  
54 thickness, of 3000 PSI compressive strength concrete, steel reinforced. Refer to detail on  
55 drawings.  
56

- 1 C. Provide grounding connectors as recommended and required by manufacturer.
- 2
- 3
- 4 3.2 METERING:
- 5
- 6 A. Install current transformers (and potential transformers as required) within low voltage
- 7 compartment per manufacturer's instructions. Provide wire and connections to kilo-watt-hour
- 8 demand meter as detailed on meter manufacturer's wiring diagrams. Wire shall be 600 volt
- 9 minimum, rated for temperature required (75 degree centigrade minimum).
- 10
- 11 B. Provide nipple between transformer low-voltage air compartment and side mounted meter
- 12 socket. Completely seal both sides after installation of meter socket wiring.
- 13
- 14 C. Mount meter and meter socket to right side of low voltage compartment when facing.
- 15 Support for transformer housing using gasketed bolt holes. Cut bolt protrusion after
- 16 installation as required. Maximum penetration into transformer shall be 1/2 inch.
- 17
- 18 END OF SECTION 260517