



IFB #26-41-CROWN Commercial Washers

Addendum I

Questions/Answers

(County responses and changes are in red)

Questions/Answers

1. Section 4.01 Scope of Work - Voltage is mentioned as being 240V with 60Hz. Can you confirm this is 3phase?

Yes, our current machines are 3 phase.

2. Section 4.01 Scope of Work - How far away is the Closest 3phase panel?

Electrical work is not required for this quote.

3. Section 4.01 Scope of Work - What size wire is currently running from the panel to the washers? I am trying to determine if we can utilize the breaker and disconnect that is already there onsite, rather than install a new 3phase breaker with disconnect.

Electrical work is not required for this quote.

4. Section 4.01 Scope of Work – What type of machine drainage is The Coliseum currently using?
 - a. Are they cut into the concrete? Trenches?

Drains are cut into the concrete floor.

- b. Do they use flex hose to meet the drain opening from the machine?

Current machines have PVC pipe.

5. Section 4.01 Scope of Work – Do the current machines sit on any type of concrete pad?

The floor is concrete.

6. Section 4.01 Scope of Work – Do you prefer the soap supply dispenser to be automatically dispensed into the machine or a manual dispenser where the operator adds the soap before each wash?

Manual.

7. Section 4.01 Scope of Work – Does the rigging path allow enough room for a pallet jack to be used?

Yes.

8. Section 4.01 Scope of Work – Are we allowed a site visit before or after our proposal submission?

If awarded the bid, a site visit can be scheduled.