

Edgecombe County Sheriff's Office

Addendum No. 1

Invitation to Bid – 911 Center Console Furniture

Date: October 13, 2025

Purpose of Addendum

This Addendum is issued to provide responses to questions received regarding the 911 Center Console Furniture Invitation to Bid. The following questions and answers are provided for clarification purposes only and do not alter the original scope of work unless specifically noted.

Question: Can you please specify the power location — is it coming primarily from the walls?

Answer: Yes, power will be coming from the walls.

Question: Is the flooring raised or solid?

Answer: The flooring is solid.

Question: Please clarify whether you are requesting single-surface or dual-surface workstations. (Page 8 states two adjustable work surfaces, while page 16 refers to a single surface.)

Answer: Dual work surfaces are preferred; however, single-surface configurations will also be acceptable.

Question: What is the model number for the 55" monitors, so we can account for the appropriate weight?

Answer: Dell P5525QC.

Question: Can you provide an equipment list (computers, monitors, keyboards, mice, etc.) including computer dimensions?

Answer: Three computers for CAD, Radio, and Telephone systems; one monitor per computer; keyboard, mouse, KVM switch, and speakers for each CAD/Telephone/Radio setup. CPUs measure approximately 4 inches in width.

Question: How many printers are in use, and what are their dimensions?

Answer: One network printer, approximately 1.5 ft x 1.5 ft square.

Question: Comment (not a question): The County indicated interest in a turnkey approach.

Answer: Correct — the County is seeking a turnkey solution.

Question: Why do the specifications reference Canadian standards?

Answer: These standards are used solely as a baseline reference.

Question: What is the total width required for the three CPUs? Are they all standard large form factor?

Answer: Each CPU is approximately 4 inches wide; allow at least 7 inches of space per unit to accommodate cabling and ventilation.

Question: Would you like us to include the cost to remove and dispose of the existing consoles?

Answer: No, removal and disposal of the existing consoles will be handled by the Edgecombe County Sheriff's Office.

Acknowledgment of Addendum

Company Name	
Authorized Representative (Print Name)	
Signature	
Date	

Issued by:
Edgecombe County Sheriff's Office
Edgecombe County, North Carolina