



City of Raleigh

Bid Solicitation#: 274-ESIFS-SECURITYUPGRADES3-2023

Title: PRCR Security Upgrades Phase 3

Proposal Due Date and Time: January 12, 2024, 2:00 PM

ADDENDUM NO. 1

Issue Date: December 21, 2023

Issuing Department: Engineering Services, IFS

Direct all inquiries concerning this Bid Solicitation to:

Kevin Roberts
Project Manager

Kevin.Roberts@RaleighNC.gov

City of Raleigh
Addendum 1 to Bid Solicitation #274-ESIFS-SECURITYUPGRADES3-2023

Issue Date: December 21, 2023

To: All Proposers

This Addendum, containing the following additions, clarifications, and/or changes, is issued prior to receipt of proposal packages and does hereby become part of the original project manual and supersedes the original project manual in case of conflict.

This addendum includes the pre-bid meetings questions and answers below. Revised site notes, drawings, and the pre-bid meeting sign-in sheet are included in the complete Addendum file. The complete file is too large to attach here. [Please contact Kevin.Roberts@RaleighNC.gov](mailto:Kevin.Roberts@RaleighNC.gov) for a complete copy of Addendum #1.

Receipt of all addenda must be acknowledged in your bid proposal submission (see project manual).

PRE-BID MEETING QUESTIONS & ANSWERS

1. Q: What type of server cabinet should be used at each site?
A: VWMSD-8RU-42-B 8RU (Qty. 1) Vertical Cabinet with Fan Kit (Qty. 1) VWMFK-115 at each site shall be used except for Durant Nature Preserve. At Durant Nature Preserve Training Lodge and Campbell Lodge, the contractor shall install Server Cabinet VWMSD-8RU-42-B 8RU (Qty. 1) and Fan Kit (Qty. 1) in each building. VWMFK-115. Server cabinet VWMSD-4RU-42-B 4RU will not be used.
2. Q: Who is responsible for establishing direct power for LPR cameras?
A: The Contractor is responsible for all electrical work for Phase 3.

Kevin Roberts
Project Manager