

April 4, 2025



To: All Plan Holders

COR Project #: 274-ESIFS-DILLON HVAC-2025
Project: 310 W Martin Street – HVAC Replacement

Addendum #2

The bidders are hereby informed that the following additions, deletions, changes and/or clarifications supersede and supplement the contract documents for the referenced project.

1. Refrigerant piping shall be copper tubing with solder joints. Use of mechanical press fittings for refrigerant pipe will not be allowed.
2. The Pre-Bid meeting held on 3/27 has been changed to **NON-MANDATORY**. Bids from contractors who did not attend the pre-bid meeting can be submitted. Contact Jason Clough, jason.clough@raleighnc.gov if a site visit is needed.

Bradley W. Felts, PE
Client Executive

