



September 17, 2024

ADDENDUM #2

NOTICE TO BIDDERS:

The bid opening is scheduled for 11:00 am on Friday, September 20, 2024, at the Raleigh Municipal Building, Room 303.

PROJECT INTRODUCTION:

The project consists of the installation of Green Stormwater Infrastructure (GSI) elements at multiple locations in Raleigh, North Carolina. The Base Bid contains the following:

- 1) Construction of an approximately 10,000 square foot submerged gravel wetland and appurtenances at Lions Park Location A (off Dennis Avenue).
- 2) Construction of an approximately 2,000 square foot bioswale and appurtenances at Lions Park Location B (adjacent to Community Center).
- 3) Construction of an approximately 500 square foot bump-out bioretention with a tree well, suspended pavement system, and appurtenances in the Levister Court right-of-way.

There are two Add Alternate Bids for this project:

- 1) Installation of 1,200 square foot bump-out bioretention in the Crest Road right-of-way.
Alternate #1 includes installation of 95 lf of underdrain via open-cut excavation.
- 2) Installation of 1,200 square foot bump-out bioretention in the Crest Road right-of-way.
Alternate #2 includes installation of 95 lf of underdrain via jack-and-bore techniques.

This project is ARPA-funded.

QUESTIONS AND RESPONSES:

- 1) Please confirm that the “Acknowledgment of MWBE Policy” form is to be completed in lieu of the “Nondiscrimination Agreement” form for the bid submission.
 - Confirmed, refer to Section 440 for “Acknowledgement of MWBE Policy”. See attached updated Bidders Checklist.
- 2) Please identify flow down provision stipulations that the Contractor needs to be made aware of due to grant and ARPA funding.
 - The ARPA funding is classified as “revenue replacement”. There are no additional stipulations due to the ARPA funding. This project will follow the City’s standard procurement and contracting guidelines.
- 3) Requesting a milestone extension of an additional 20 calendar days for the infiltration testing.
 - Milestone extension of additional 20 calendar days (from 60 to 80) is acceptable to the City.



- 4) Requesting the cut/fill numbers for each project site.
- See table below for cut/fill estimates.

Location	Cut (CY)	Fill (CY)
Lions Park - A	1,192	50
Lions Park - B	415	14
Crest	220	0.5
Levister	128	0

- 5) Requesting the CAD file.
- Please email Erik Mayr, PE (erik.mayr@raleighnc.gov) to request CAD files for Lions Park and the UHI sites before the bid opening.